

"A" Street, Peaks Is. 87-H-13



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT ISSUED
01106 2 1973
CITY of PORTLAND

Portland, Maine, October 1, 1973

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 87-H-13, Peaks Island Use of Building dwelling No. Stories 1 New Building Existing "

Name and address of owner of appliance Edward Ivers

Installer's name and address Richard Benis, Willow St, Peaks Island Telephone 766-2809

General Description of Work

To install a forced hot air heating system (replacement) for existing FHA system (boiler)

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no

If so, how protected?

Kind of fuel? oil

Minimum distance to burnable material, from top of appliance or casing top of furnace 3'

From top of smoke pipe 3#' From front of appliance 3' From sides or back of appliance 3'

Size of chimney flue 7" Other connections to same flue none

If gas fired, how vented?

Rated maximum demand per hour

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Tappan 140,000 BTU's Labelled by underwriters' laboratories? yes

Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom

Type of floor beneath burner slab Size of vent pipe 1 1/2"

Location of oil storage basement Number and capacity of tanks 1-275

Low water shut off

Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none

Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance

Any burnable material in floor surface or beneath?

If so, how protected?

Height of Legs, if any

Skirting at bottom of appliance?

Distance to combustible material from top of appliance?

From front of appliance

From sides and back

From top of smokepipe

Size of chimney flue

Other connections to same flue

Is hood to be provided?

If so, how vented?

Forced or gravity?

If gas fired, how vented?

Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Tank sitting on concrete blocks.

Amount of fee enclosed? 5.00

APPROVED:

OK 10-1-73 NEC

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Richard Benis

Signature of Installer

INSPECTION COPY

NOTES

1954
10-20-73 *Completed* *AP*

Permit No. 73/1126
Location 411 Street, Rockwell
Owner Edward, Loran
Date of permit 10/2/73
Approved _____

Johnson