

90-N-4 5, 8, 9 Pleasant Avenue

Peaks Island

766-2817 ER

Department of Human Services
Division of Health Engineering
(207) 289-3826

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

PROPERTY ADDRESS

Town Or Plantation: PORTLAND PEAKS ISLAND

Street: PLEASANT AVE
Subdivision Lot #: TAX MAP 90 BLOCK N LOTS 4,5,8,9

PROPERTY OWNERS NAME

Last: WILDES
First: LAURIE

Applicant Name: LAURIE WILDES

Mailing Address of Owner/Applicant (if Different): BEACH ROAD
PEAKS ISLAND, MAINE 04103

Permit # 1,012 STATE COPY

Date Recd: JUL 25 1984

FEE: \$ _____

Local Plumbing Inspector Signature: *[Signature]*

L.P.I. # _____

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: *Laurie Wildes et al*
Date: APR 29 1985

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules.

Local Plumbing Inspector Signature: *[Signature]*
Date Approved: APR 29 1985

PERMIT INFORMATION

THIS APPLICATION IS FOR:

- NEW SYSTEM
- REPLACEMENT SYSTEM
- EXPANDED SYSTEM
- SEASONAL CONVERSION
- EXPERIMENTAL SYSTEM

THIS APPLICATION REQUIRES:

- NO RULE VARIANCE REQUIRED
- NEW SYSTEM VARIANCE
Attach New System Variance Form
- REPLACEMENT SYSTEM VARIANCE
Attach Replacement System Variance Form
- Requires only Local Plumbing Inspector Approval
- Requires both State and Local Plumbing Inspector Approval

INSTALLATION IS COMPLETE SYSTEM:

- NON-ENGINEERED SYSTEM
- PRIMITIVE SYSTEM (Includes Alternative Toilet)
- ENGINEERED (+ 2000 gpd)

INDIVIDUALLY INSTALLED COMPONENTS:

- TREATMENT TANK (ONLY)
- HOLDING TANK
- ALTERNATIVE TOILET (ONLY)
- NON-ENGINEERED DISPOSAL AREA (ONLY)
- ENGINEERED DISPOSAL AREA (ONLY)
- SEPARATED LAUNDRY SYSTEM

IF REPLACEMENT SYSTEM:
YEAR FAILING SYSTEM INSTALLED: 5 P

THE FAILING SYSTEM IS:

- BED
- CHAMBER
- TRENCH
- OTHER CESSPOOL

DISPOSAL SYSTEM TO SERVE:

- SINGLE FAMILY DWELLING
- MODULAR / MOBILE HOME
- MULTIPLE FAMILY DWELLING
- OTHER _____ SPECIFY _____

TYPE OF WATER SUPPLY: PUBLIC WATER

SIZE OF PROPERTY: 22,200 SF. ZONING: R-3

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK

- SEPTIC Regular Low Profile
- AEROBIC

SIZE: 1000 GALS

WATER CONSERVATION

- NONE
- LOW VOLUME TOILET
- SEPARATED LAUNDRY SYSTEM
- ALTERNATIVE TOILET

SPECIFY _____

PUMPING

- NOT REQUIRED
- MAY BE REQUIRED (DEPENDENT ON TREATMENT TANK LOCATION AND ELEVATION)
- REQUIRED

DOSE: _____ GALS

CRITERIA USED FOR DESIGN FLOW (BEDROOMS SEATING EMPLOYEES, WATER RECORDS ETC.): 3 BEDROOM CONSERVATIVE

SOIL CONDITIONS USED FOR DESIGN PURPOSES

PROFILE	CONDITION
7	C

DEPTH TO LIMITING FACTOR: 22

SIZE RATINGS USED FOR DESIGN PURPOSES

- SMALL
- MEDIUM
- MEDIUM-LARGE
- LARGE
- EXTRA LARGE

DISPOSAL AREA TYPE/SIZE

- BED 1500 Sq Ft
- CHAMBER _____ Sq Ft
- TRENCH _____ Linear Ft
- OTHER _____

DESIGN FLOW: 450 (GALLONS/DAY)


SITE EVALUATOR STATEMENT

On JULY 25, 1984 (date) I conducted a site evaluation for this project and certify that the data reported is accurate. The system I propose is in accordance with the Subsurface Wastewater Disposal Rules.

Signature: *William B. Goodwin* 0003/4814
Date: 8/18/84

Local Plumbing Inspector Signature & Local Site Evaluation Waiver under a Local Option

Page 1 of 3
HHE-200 Rev. 4/83



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)																																																															
<p>Observation Hole <u>2</u> <input checked="" type="checkbox"/> Test Pit <input type="checkbox"/> Boring</p> <p><u>2" SOD</u> * Depth of Organic Horizon Above Mineral Soil</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Texture</th> <th>Consistency</th> <th>Color</th> <th>Mottling</th> </tr> </thead> <tbody> <tr> <td>SANDY LOAM</td> <td></td> <td>DARK BROWN</td> <td></td> </tr> <tr> <td>FINE GRAVEL</td> <td></td> <td>BROWN</td> <td>NONE</td> </tr> <tr> <td></td> <td>LOOSE</td> <td></td> <td></td> </tr> <tr> <td>GRAVEL</td> <td></td> <td>GRAY BROWN</td> <td>FEW</td> </tr> <tr> <td></td> <td></td> <td></td> <td>COMMON</td> </tr> <tr> <td>SILTY GRAVEL</td> <td>MODERATELY FRIABLE</td> <td>GRAY</td> <td>NONE</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <tr> <td style="text-align: center;">Soil <u>6</u> <small>Probe</small></td> <td style="text-align: center;">Classification <u>C</u> <small>Common</small></td> <td style="text-align: center;">Slope <u>2</u> %</td> <td style="text-align: center;">Limiting Factor <u>30</u></td> <td> <input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock </td> </tr> </table>	Texture	Consistency	Color	Mottling	SANDY LOAM		DARK BROWN		FINE GRAVEL		BROWN	NONE		LOOSE			GRAVEL		GRAY BROWN	FEW				COMMON	SILTY GRAVEL	MODERATELY FRIABLE	GRAY	NONE	Soil <u>6</u> <small>Probe</small>	Classification <u>C</u> <small>Common</small>	Slope <u>2</u> %	Limiting Factor <u>30</u>	<input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock	<p>Observation Hole <u>2</u> <input checked="" type="checkbox"/> Test Pit <input type="checkbox"/> Boring</p> <p><u>2 1/2" SOD</u> * Depth of Organic Horizon Above Mineral Soil</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Texture</th> <th>Consistency</th> <th>Color</th> <th>Mottling</th> </tr> </thead> <tbody> <tr> <td>SANDY LOAM</td> <td></td> <td>DARK BROWN</td> <td></td> </tr> <tr> <td>GRAVEL</td> <td>LOOSE</td> <td>RED BROWN</td> <td>NONE</td> </tr> <tr> <td></td> <td></td> <td></td> <td>FEW</td> </tr> <tr> <td>SILTY GRAVEL</td> <td>MODERATELY FRIABLE</td> <td>GRAY BROWN</td> <td>COMMON</td> </tr> <tr> <td>CLAYEY GRAVEL</td> <td>FRIABLE</td> <td>GRAY</td> <td>NONE</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <tr> <td style="text-align: center;">Soil <u>7</u> <small>Probe</small></td> <td style="text-align: center;">Classification <u>C</u> <small>Common</small></td> <td style="text-align: center;">Slope <u>2</u> %</td> <td style="text-align: center;">Limiting Factor <u>22</u></td> <td> <input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock </td> </tr> </table>	Texture	Consistency	Color	Mottling	SANDY LOAM		DARK BROWN		GRAVEL	LOOSE	RED BROWN	NONE				FEW	SILTY GRAVEL	MODERATELY FRIABLE	GRAY BROWN	COMMON	CLAYEY GRAVEL	FRIABLE	GRAY	NONE	Soil <u>7</u> <small>Probe</small>	Classification <u>C</u> <small>Common</small>	Slope <u>2</u> %	Limiting Factor <u>22</u>	<input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock
Texture	Consistency	Color	Mottling																																																												
SANDY LOAM		DARK BROWN																																																													
FINE GRAVEL		BROWN	NONE																																																												
	LOOSE																																																														
GRAVEL		GRAY BROWN	FEW																																																												
			COMMON																																																												
SILTY GRAVEL	MODERATELY FRIABLE	GRAY	NONE																																																												
Soil <u>6</u> <small>Probe</small>	Classification <u>C</u> <small>Common</small>	Slope <u>2</u> %	Limiting Factor <u>30</u>	<input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock																																																											
Texture	Consistency	Color	Mottling																																																												
SANDY LOAM		DARK BROWN																																																													
GRAVEL	LOOSE	RED BROWN	NONE																																																												
			FEW																																																												
SILTY GRAVEL	MODERATELY FRIABLE	GRAY BROWN	COMMON																																																												
CLAYEY GRAVEL	FRIABLE	GRAY	NONE																																																												
Soil <u>7</u> <small>Probe</small>	Classification <u>C</u> <small>Common</small>	Slope <u>2</u> %	Limiting Factor <u>22</u>	<input checked="" type="checkbox"/> Ground Water <input type="checkbox"/> Rooting Layer <input type="checkbox"/> Bedrock																																																											

William B. Goodwin 0023/4814 SEP/PE#
6/10/84 Date

Page 2 of 3
HHE-200 Rev 4/83


SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Division of Health Engineering

Town, City, Plantation: **PORTLAND PEAKS ISLAND** Street, Road, Subdivision: **PLEASANT AVE. 90-N-4,5,8,9** Owners Name: **Laurie Wildes**

SUBSURFACE WASTEWATER DISPOSAL PLAN


Scale 1" = 20' FL



FILL REQUIREMENTS		CONSTRUCTION ELEVATIONS		ELEVATION REFERENCE POINT LOCATION & DESCRIPTION	
Depth of Fill (Upslope)	0'	Reference Elevation is	100.00	ALUMINUM SPIKE IN 14" POPLAR	
Depth of Fill (Downslope)	15'	Bottom of Disposal Area	97.96		
		Top of Distribution Lines or Chambers	99.04		

DISPOSAL AREA CROSS SECTION

Scale:
Vertical: 1 inch = 4' FL
Horizontal: 1 inch = 20' FL



William B. Goodwin
Site Evaluator or Professional Engineer's Signature

0003/7814
SE # PE #

8/18/84
Date



APPLICATION FOR AMENDMENT TO PERMIT

PERMIT ISSUED

DEC 4 1984

CITY of PORTLAND

Amendment No. # 1

Portland, Maine, Dec. 3, 1984

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 84-1075 ... pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 98-11-15 Pleasant Ave. Peaks Island Within Fire Limits? Dist. No.

Owner's name and address Laurie Joan Miles Beach Rd. Peaks Isl. Telephone 756-2260

Lessee's name and address Telephone

Contractor's name and address Other Plans filed No. of sheets

Architect No. families

Proposed use of building dwelling No. families

Last use same Additional fee 30.00

Increased cost of work 6,000

Description of Proposed Work

To make additional work not put on permit, as per plans. 1 sheet of plans.

sent in by mail.

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?

Height average grade to top of plate Height average grade to highest point of roof

Size front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar Thickness

Material of underpinning Height Thickness

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining

Framing lumber—Kind Dressed or full size?

Corner posts Sills Girt or ledger board? Size

Girders Size Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On center: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

Approved:

Signature of Owner

Approved: Inspector of Buildings

FILE COPY



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

June 6, 1984

Ms. Laurie Jean Wilders
Beach Road
Peaks Island, Maine 04108

Re: 90-4 & 5 Pleasant Ave., Peaks Island

Dear Ms. Wilders:

Your application to move a single family 16' X20' from 90-N-8 to 90-4-5(N) has been reviewed and your application didn't show what, nor where the septic system was located. Therefore, I cannot issue a building permit until this issue is solved.

If you have any questions concerning this item please contact this office.

Sincerely,

P. Samuel Hoyises
Chief of Inspection Services

PSH/mwp



APPLICATION FOR AMENDMENT TO PERMIT

PERMIT ISSUED

DEC 4 1984

Amendment No. # 1

Portland, Maine, Dec. 3, 1984

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 84-1072 containing 101 building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 90-N-4-5 Pleasant Ave. Peaks Island Within Fire Limits? D.Lt. No. 766-2260
Owner's name and address Laurie Jean Wildes - Beach Rd. Peaks Isl. Telephone
Lessee's name and address
Contractor's name and address Cmen. Telephone
Architect Plans filed No. of sheets
Proposed use of building dwelling No. families 1
Last use sana No. families
Increased cost of work 6,000. Additional fee 30.00

Description of Proposed Work

To make additional work not put on permit, as per plans. 1 sheet of plans.

send in by mail.

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Price per foot Roof covering
No. of chimneys Mater. of chimneys Dressed or full size? of lining
Framing lumber—Kind Girt or led. board? Size
Corner post Girders Size Columns under girders Size Mux. on centers
Studs (outside walls and carrying partitions) 2x4-8" O. C. Bridg. in every floor and flat roof span over 8 feet.
Joists and rafters 1st floor 2nd 3rd roof
O. centers 1st floor 2nd 3rd roof
Maximum span 1st floor 2nd 3rd roof

Signature of Owner
Inspector of Buildings



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

June 6, 1984

Ms. Laurie Jean Wilders
Beach Road
Peaks Island, Maine 04108

Re: 90-4 & 5 Pleasant Ave., Peaks Island

Dear Ms. Wilders:

Your application to move a single family 16' X20' from 90-N-8 to 90-4-5(N) has been reviewed and your application didn't show what, nor where the septic system was located. Therefore, I cannot issue a building permit until this issue is solved.

If you have any questions concerning this item please contact this office.


Sincerely,

A handwritten signature in dark ink, appearing to read "P. Samuel Hoffses".

P. Samuel Hoffses
Chief of Inspection Services

FSH/nsp

RE: TO BE SUBMITTED WITH APPLICATION TO MOVE SINGLE DWELLING 16'x20' FROM 90-N-8 TO (9-4-5(N)) SEPTIC SYSTEM LOCATION IN VIOLET INK.




* House Dimension 16'x20'

* existing Septic is located on lot # 5 and will be usable after House is moved. Septic is over 25' away from House

- Property Boundary
- New Location of House
- Existing Septic
- Previous Location of House

① LOCATION OF SINGLE FAMILY DWELLINGS-




RECEIVED
DEC 1 0 1964
DEPT. OF BLDG. INSP
CITY OF PORTLAND

20-N-415


② FOUNDATION DESCRIPTION
(SAUNA TUBES)

90-N-115

A) NUMBER OF TUBES & POSITION



B) CROSS SECTION OF STUBES




* SAUNA TUBES filled with Cement

③ FLOOR PLAN 1ST FLOOR

7'-0" - 11'-2"

(A)

TO BE REPLACED
BY double Casement
w/ two measuring
3' 4 1/2" x 4' 3 1/2"
w/ 4x4 HERRICK



Block + Lined
CHIMNEY
2' x 2'

TO BE REPLACED BY
LATH HUNG French Door
5' x 6\" w/ 4x4 HERRICK

(1)

(2)

(3)

LAMP
5' x 6'

STAIRS

5' 6\" x 8' 6\"
REFRIG

5' 6\" x 9\"
REFRIG

DOOR
3' x 6' 6'

DOOR
3' x 6' 6'

④ FLOOR PLAN 2ND FLOOR

90-N-4,5

(N)

To be Replaced By
5' x 6' French Door

2' x 3'
Window

CLOSET

WINDOW
2' x 3'

(E)

(E)

2'
2'

CHIMNEY

3'
STAIR
Well


(S)

⑤ SKYLIGHT INSTALLATION

90-N-4.5


SOUTH SIDE OF ROOF

ROOF BEAMS ARE 2' X 3"
2 FT APART



④. BATH ROOM WHICH WILL NOT BE ADDED UNTIL NEXT SPRING WILL RE APPLY FOR PERMIT TO BUILD BATHROOM ALONG WITH PLUMBING + ELECTRICAL PERMIT NEXT SPRING.

BATHROOM CONSTRUCTION WILL BE DESCRIBED WHEN I APPLY FOR ANOTHER PERMIT IN SPRING.



① FINISHED HOUSE

90-N-4,5

②
Deck over Bathrooms
ACCESSIBLE THROUGH
2ND FLOOR

SOUTH SIDE & EAST END




→ EAST

NORTH SIDE & EAST END

③

← EAST




→ Deck over
BATHROOM
ACCESSIBLE THROUGH
BATHROOM

11-26-84

MR. ADDATO,

ENCLOSED IS (\$5000) TO COVER THE FEE FOR OUR BUILDING PERMIT. I APPOLOGIZE FOR NOT APPLYING SOONER, BUT I'VE BEEN BUSY WITH THE RESTAURANT & ALL IT TOTALLY SLIPPED MY MIND. WORK TO BE DONE UNDER THIS PERMIT IS AS FOLLOWS.

INSTALL 2 WINDOWS + 1 DOOR
SHINGLE ROOF & EXTERIOR
FINISH CHIMNEY



IF I HAVEN'T GIVEN YOU ENOUGH INFORMATION, LET ME KNOW + I WILL BE MORE SPECIFIC.


THANKS
S.

P.S. HOUSE IS LOCATED
ON PLEASANT AVE.
LOT # 90-N 415

W. J. J. "S"

existing 16x20
New addition will be 15x12 1/2

90-N-415



EXISTING
BUILDING 16x20
TO BE MOVED 10 FT NORTH
35 FEET WEST

RECEIVED
JUN - 5 1984
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

Laurie Jean Wildes BEACH RD. DEAKS IS ME 766-2260

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP 01073

SEP 4 1984

B.O.C.A. TYPE OF CONSTRUCTION

CITY OF PORTLAND

ZONING LOCATION R-3 PORTLAND, MAINE 6/5/84

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 90-4 & 5 Pleasant Ave., Peaks Island Fire District #1 [] #2 []

1. Owner's name and address Laurie Jean Wildes Beach Rd., Peaks Isl. Telephone 766-2260

2. Lessee's name and address Telephone

3. Contractor's name and address owner Telephone

Proposed use of building single fam. dwelling No. of sheets

Last use same No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 1,000.00

FIELD INSPECTOR—Mr. Adda TO Appeal Fees \$

@ 775-5451 Base Fee

To move single family, 16' x 20', from Lot 90-N-8 to Lot 90-4, 5 (N). Within the next two weeks. Pleasant Ave., Peaks Island, as per plot plan. Lat. Fee

TOTAL \$ 15.00

Stamp of Special Conditions

ISSUE PERMIT TO #1

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining Kind of heat fuel

Framing Lumber—Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet

Joists and rafters 1st floor 2nd 3rd roof

On centers 1st floor 2nd 3rd roof

Maximum span 1st floor 2nd 3rd roof

For one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY DATE MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? If

ZONING: OK 1760 6/16/84

BUILDING CODE: Will there be in charge of the above work a person competent

Fire Dept. to see that the State and City requirements pertaining thereto

Health Dept. are observed? YES

Others:

Signature of Applicant Laurie Jean Wildes Phone # 766-2260

Type Name of above Laurie Jean Wildes [] [] [] []

Other and address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

[Handwritten signature]

NOTES

6-6-84 SENT LETTER A King
to receive info. on the settle
system #

10-11-84 - House minimal
not set on found. yet. CA

11-27-84 - House set on
piers. Chimney work near
complete. W/P/OK. CA

1-11-85 - Exterior work in
progress OK. CA

3-9-85 - Checked
W/P/OK CA

5-24-85 - Checked, All


4-19-85 - W/P/OK CA

2-25-86 - Checked
OK. CA

6-3-86 - Complete
OK. CA

Permit No. 81/1073
 Location 9515 Pleasant Cir
 Owner Jennie Lane Strickland
 Date of permit 6-8-84
 Approved 9-1-84
 Dwelling Mrs. dwelling
 Garage
 Alteration

Chas. D.



PERMIT # 04 CITY OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Address: Laurie & Covey Johnson - 766-2108
Pleasant Avenue, Peaks Island, Maine 04108
 LOCATION OF CONSTRUCTION 90-N-4 & 6 Pleasant Ave., P. I.
 CONTRACTOR: OWNER SUBCONTRACTORS: _____

ADDRESS: _____
 Est. Construction Cost: 800.00 Type of Use: Single Family
 Past Use: SAME
 Building Dimensions: L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____
 Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____
 Conversion: Explain Construct open deck rear of dwelling.
COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE as per plan. 15'x18'
 # Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs: Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 b. Other: _____

Floor:
 1. Sills Size _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lolly Column Spacing: _____ Size: _____
 4. Joist Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather Exposure _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

For Official Use Only	
Date: <u>May 26, 1988</u>	Subdivision: Yes / No _____
Ins'ds Fire Limits _____	Name _____
Bldg Code _____	Lot _____
Time Limit _____	Block _____
Estimated Cost: <u>\$800.00</u>	Permit Expiration: _____
Val. of Structure _____	Ownership: _____ Public _____ Private _____
Fee: <u>\$25.00</u>	

Ceiling:
 1. Ceiling Joists Size: _____ **PERMIT ISSUED**
 2. Ceiling Strapping Size _____ Spacing _____
 3. Type Ceiling: _____
 4. Insulation Type _____ Size MAY 31 1988
 5. Ceiling Height: _____

Roof:
 1. Truss or Rafter Size _____ Spar _____ **City Of Portland**
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 4. Other _____

Chimneys:
 Type _____ Number of Fire Places _____

Heating:
 Type of Heat: _____

Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Zoning:
 District _____ Street Frontage Req. _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt. _____ Special Exception _____
 Other (Explain) _____
 Date Approved _____

Permit Received By Joseph M Rinaldi
 Signature of Applicant Laurie Johnson Date 5-26-88
 Signature of CEO _____ Date _____
 Inspection Dates WITH LIMITED



CITY OF PORTLAND, MAINE

139 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

90-N-4 & 6
Pleasant Avenue
Peaks Island

May 26, 1988

Laurie & Covey Johnson
Pleasant Avenue
Peaks Island, Maine 04108

Dear Mr. and Mrs. Johnson:

This is in reference to your application for a building permit for an open deck on the rear of your dwelling on Pleasant Avenue, Peaks Island, in the Island Residential 2 Zone. We can not ascertain from your sketch whether or not the proposed deck is in accordance with the setback requirements for the IR-2 Zone, which are as follows:

Front yard: 25 feet
Rear yard: 25 feet
Side yard: 20 feet
Side yard on Side Street: 20 feet

Please review your sketch and determine what setbacks are being provided from the outer edge of the deck to the front, side and/or rear of the building after the deck has been attached. We would appreciate having a revised plot plan to show that the proposed deck meets the above setback requirements. Please submit a revised plot plan to show that the proposed deck will meet these setbacks subject to review by the Code Enforcement Officer assigned to your district of the City.

Sincerely,

Warren J. Turner

Warren J. Turner
Zoning Enforcement Inspector


Enclosure: IR-2 Island Residential Zone

cc: P. Samuel Hoffses, Chief, Inspection Services
Arthur Addato, Code Enforcement Officer

*Miss Johnson came
in and furnished
setback data
WJ Turner 5/31/88*

Laurel & Covey JOHNSON Pleasant Avenue Peaks Island

NO. 90-N-446




RECEIVED

MAY 26 1988

DEPT. OF PLANNING & ZONING
CITY OF PORTLAND


Laurie & Covey JOHNSON Pleasant Avenue Peaks Island Me
 90-N-4+6

(A)



(B)

- Decking 1x6
- Nailed to Building
- 2x6 stringers



(b) 6x6 tubes 12" cement filled 4ft Down Below the grade

150
 750
 1.3
 225
 250
 675

Location of Building } Lots 90N4
 90N6

RECEIVED

MAY 26 1988

DEPT OF BUILDING INSPECTIONS
 CITY OF PORTLAND

In buildings of Use Groups R-1 and R-2 which have basements, an additional smoke detector shall be installed in the basement. In buildings of Use Group R-3, smoke detectors shall be required on every story of the dwelling unit, including basements.

In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level provided the lower level is less than one full story below the upper level. If there is an intervening door between the adjacent levels, a smoke detector shall be installed on both levels.


All detectors shall be installed in an approved location. Where more than one detector is required to be installed within an individual dwelling unit, the detectors shall be wired in such a manner that the actuation of one alarm will actuate all the alarms in the individual unit.

- 6.) Private garages located beneath rooms in buildings of Use Groups R-1, R-2, R-3 or I-1 shall have walls, partitions, floors and ceilings separating the garage space from the adjacent interior spaces constructed of not less than 1-hour fireresistance rating. Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by means of 1/2-inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and adjacent interior spaces shall be raised not less than 4 inches (102 mm) above the garage floor. The door opening protectives shall be 1 3/4-inch solid core wood doors or approved equivalent.

- *7.) A guardrail system located near the open side of deck or elevated walking surfaces shall be constructed. Guards in buildings of Use Group R-3 shall be not less than 36 inches in height. Open guards shall have intermediate rails, balusters or other construction such that a sphere with a diameter of 6 inches cannot pass through any opening.

- 8.) Section 25-135 of the Municipal Code for the City of Portland states: "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year."

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services

/ksc
11/9/87

BUILDING PERMIT REPORT

DATE: 31 May 1988

ADDRESS: 90-11-4 E 6 Pleasant Ave, Peaks Island

REASON FOR PERMIT: 15' x 10' deck

BUILDING OWNER: Laurie & Covey Johnson

CONTRACTOR: "

PERMIT APPLICANT: "

APPROVED: *7 DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All vertical openings shall be enclosed with construction having a fire rating of at least one(1) hour, including fire doors with self-closers.
- 2.) Each apartment shall have access to two(2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 3.) The boiler shall be protected by enclosing with one(1) hour fire rated construction including fire doors and ceiling, or by placing over the boiler, two(2) residential sprinkler heads supplied from the domestic water.
- 4.) Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118 mm) above the floor. All egress or rescue windows from sleeping rooms must have minimum net clear openings of 5.7 square feet (0.53m²). The minimum net clear opening height dimension shall be 24 inches (610 mm). The minimum net clear opening width dimension shall be 20 inches (508 mm).
- 5.) In addition to any automatic fire alarm system required by Sections 1018.3.5, a minimum of one single station smoke detector shall be installed in each guest room, suite or sleeping area in buildings of Use Groups R-1 and I-1 and in dwelling units in the immediate vicinity of the bedrooms in buildings of Use Group R-2 or R-3. When actuated, the detector shall provide an alarm suitable to warn the occupants within the individual unit (see Section 1717.1.1).



CITY OF PORTLAND, MAINE

389 CONGRESS STREET

PORTLAND, MAINE 04101

(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

May 31, 1988

Laurie and Corey Johnson
Pleasant Ave.
Peaks Island, ME 04108

Dear Mr. and Mrs. Johnson:

Your application to construct an open deck 15'x18' has been reviewed and a permit is herewith issued subject to the following requirements:

- 1) Please read and implement item #7 of the attached building permit report.
- 2) Your plan shows 2"x 6" floor joists with a span of 15'. The building code would require a minimum of 2"x10", 16" O.C., for a 15' span. If the span is divided by a second carrying beam at 7 1/2', the 2"x 6" joists, 16" O.C. will work.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

P. Samuel Hoffses
Chief, Inspection Services

PERMIT # 00521 CITY OF Portland BUILDING PERMIT APPLICATION MAP # LOT#

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Laurie & Conway Johnson - 766-2108

Address: Pleasant Avenue, Peaks Island, Maine 04108

LOCATION OF CONSTRUCTION: 90-N-4 & 6 Pleasant Ave., P. I.

CONTRACTOR: owner SUBCONTRACTORS: _____

ADDRESS: _____

Est. Construction Cost: 800.00 Type of Use: Single family

Part of: SAME

Building Dimensions: L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: Seasonal Condominium _____ Apartment _____

Conversion - Explain: Construct open deck rear of dwelling,

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE as per plan. 15'x18'

Residential Buildings Only: _____

Of Dwelling Units: _____ # Of New Dwelling Units _____

Foundation: _____

1. Type of Soil: _____
2. Set: Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other: _____

Floors: _____

1. Sill Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls: _____

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls: _____

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

For Official Use Only

Date: May 26, 1988 Subdivision: Yes / No _____

Inside Fire Limits _____ Name _____

Bldg Code _____ Lot _____

Time Limit _____ Block _____

Estimated Cost: 800.00 Permit Expiration: _____

Value/Structure _____ Ownership: _____ Public _____ Private _____

Fee: \$25.00

Ceiling: _____ **PERMIT ISSUED**

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceilings: _____ MAY 31 1988
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof: _____ City of Portland

1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____
4. Other _____

Chimneys: _____

Type: _____ Number of Fire Places _____

Heating: _____

Type of Heat: _____

Electrical: _____

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing: _____

1. Approval of soil test if required _____ Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Fixtures _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools: _____

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning: _____

District: DR2 Street Frontage Req: _____ Provided _____

Required Setbacks: Front _____ Back _____ Side _____

Revisions Required: _____

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt. _____ Special Exception _____

Other (Explain): _____

Date Approved: May 26, 1988

Permit Received By: _____

Signature of Applicant: _____ Date: _____

Signature of CEO: _____ Date: _____

Inspection Dates: _____





CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

90-N-4 & 6
Pleasant Avenue
Peaks Island

May 26, 1988

Laurie & Covey Johnson
Pleasant Avenue
Peaks Island, Maine 04108

Dear Mr. and Mrs. Johnson:

This is in reference to your application for a building permit for an open deck on the rear of your dwelling on Pleasant Avenue, Peaks Island, in the Island Residential 2 Zone. We can not ascertain from your sketch whether or not the proposed deck is in accordance with the setback requirements for the IR-2 Zone, which are as follows:

Front yard: 25 feet
Rear yard: 25 feet
Side yard: 20 feet
Side yard on Side Street: 20 feet

Please review your sketch and determine what setbacks are being provided from the outer edge of the deck to the front, side and/or rear of the building after the deck has been attached. We would appreciate having a revised plot plan to show that the proposed deck meets the above setback requirements. Please submit a revised plot plan to show that the proposed deck will meet these setbacks subject to review by the Code Enforcement Officer assigned to your district of the City.

Sincerely,

Warren J. Turner

Warren J. Turner
Zoning Enforcement Inspector

Enclosure: IR-2 Island Residential Zone

cc. P. Samuel Hoffses, Chief, Inspection Services
Arthur Addato, Code Enforcement Officer

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering
(207) 281-3018

PROPERTY ADDRESS		PORTLAND 4473 TOWN COPY Date: <u>105, 88, 92</u> \$ <u>16.00</u> <input type="checkbox"/> Double Fee Charge Chief Plumbing Inspector Date Approved: <u>6-6-94</u>
Town Or Plantation	PORTLAND PEAKS ISLAND	
Street	PLEASANT AVENUE	
Subdivision/Lot #	TAX MAP 90 BLOCK N LOTS 6 & 7	
PROPERTY OWNERS NAME		
CREILSON LINDA		
Last: First:		
Applicant Name:	LINDA K CREILSON	
Mailing Address of Owner/Applicant (if Different)	21 COTTAGE STREET EVERETT MASS. 02149	
Owner/Applicant Statement		Caution: Inspection Required
I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.		I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules.
Signature of Owner/Applicant: <u>Linda K Creilson</u> Date: <u>5/14/94</u>		Local Plumbing Inspector Signature: <u>A Rowe</u> Date Approved: <u>6-6-94</u>

PERMIT INFORMATION		
THIS APPLICATION IS FOR: 1. <input type="checkbox"/> NEW SYSTEM 2. <input checked="" type="checkbox"/> REPLACEMENT SYSTEM 3. <input type="checkbox"/> EXPANDED SYSTEM 4. <input type="checkbox"/> SEASONAL CONVERSION 5. <input type="checkbox"/> EXPERIMENTAL SYSTEM	THIS APPLICATION REQUIRES: 1. <input checked="" type="checkbox"/> NO RULE VARIANCE REQUIRED 2. <input type="checkbox"/> NEW SYSTEM VARIANCE Attach New System Variance Form 3. <input type="checkbox"/> REPLACEMENT SYSTEM VARIANCE Attach Replacement System Variance Form 4. <input type="checkbox"/> Requires only Local Plumbing Inspector Approval 5. <input type="checkbox"/> Requires both State and Local Plumbing Inspector Approval	INSTALLATION IS COMPLETE SYSTEM 1. <input checked="" type="checkbox"/> NON-ENGINEERED SYSTEM 2. <input type="checkbox"/> PRIMITIVE SYSTEM (Includes Alternative Toilet) 3. <input type="checkbox"/> ENGINEERED (+2000 gpd) INDIVIDUALLY INSTALLED COMPONENTS: 4. <input type="checkbox"/> TREATMENT TANK (ONLY) 5. <input type="checkbox"/> HOLDING TANK 6. <input type="checkbox"/> ALTERNATIVE TOILET 7. <input type="checkbox"/> NON-ENGINEERED LAUNDRY AREA (ONLY) 8. <input type="checkbox"/> ENGINEERED DISPOSAL AREA (ONLY) 9. <input type="checkbox"/> SEPARATED LAUNDRY SYSTEM
IF REPLACEMENT SYSTEM: YEAR FAILING SYSTEM INSTALLED: <u>1900E</u> THE FAILING SYSTEM IS: 1. <input type="checkbox"/> BED 3. <input type="checkbox"/> TRENCH 2. <input type="checkbox"/> CHAMBER 4. <input checked="" type="checkbox"/> OTHER: <u>CESSPOOL</u>	DISPOSAL SYSTEM TO SERVE: 1. <input checked="" type="checkbox"/> SINGLE FAMILY DWELLING 2. <input type="checkbox"/> MODULAR OR MOBILE HOME 3. <input type="checkbox"/> MULTIPLE FAMILY DWELLING 4. <input type="checkbox"/> OTHER _____ SPECIFY _____	TYPE OF WATER SUPPLY PUBLIC WATER
SIZE OF PROPERTY: <u>6995 SF</u> ZONING: <u>IR2</u>		

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)			
TREATMENT TANK 1. <input checked="" type="checkbox"/> SEPTIC: <input type="checkbox"/> Regular <input checked="" type="checkbox"/> Low Profile 2. <input type="checkbox"/> AEROBIC SIZE: <u>1000</u> GALS.	WATER CONSERVATION 1. <input type="checkbox"/> NONE 2. <input checked="" type="checkbox"/> LOW VOLUME TOILET 3. <input type="checkbox"/> SEPARATED LAUNDRY SYSTEM 4. <input type="checkbox"/> ALTERNATIVE TOILET SPECIFY: _____	PUMPING 1. <input checked="" type="checkbox"/> NOT REQUIRED 2. <input type="checkbox"/> MAY BE REQUIRED (DEPENDS ON TREATMENT TANK LOCATION AND ELEVATION) 3. <input type="checkbox"/> REQUIRED DOSE: _____ GALS	CRITERIA USED FOR DESIGN FLOW (BEDROOMS, SEATING, EMPLOYEES, WATCH RECORDS, ETC.) 2 BEDROOM CONSERVATIVE 300 LOW VOLUME TOILET -30 DESIGN FLOW: <u>270</u> (GALLONS/DAY)
SOIL CONDITIONS USED FOR DESIGN PURPOSES PROFILE: <u>4</u> CONDITION: <u>C</u> DEPTH TO LIMITING FACTOR: <u>22</u>	SIZE RATINGS USED FOR DESIGN PURPOSES 1. <input type="checkbox"/> SMALL 2. <input checked="" type="checkbox"/> MEDIUM 3. <input type="checkbox"/> MEDIUM-LARGE 4. <input type="checkbox"/> LARGE 5. <input type="checkbox"/> EXTRA-LARGE	DISPOSAL AREA TYPE/SIZE 1. <input type="checkbox"/> BED _____ Sq. Ft. 2. <input checked="" type="checkbox"/> CHAMBER <u>350*</u> Sq. Ft. <input checked="" type="checkbox"/> REGULAR <input type="checkbox"/> H-20 3. <input type="checkbox"/> TRENCH _____ Linear Ft. 4. <input type="checkbox"/> OTHER: _____	

SITE EVALUATOR STATEMENT * USED 14 INFILTRATOR POLYETHYLENE CHAMBER IN TRENCH CONFIGURATION.

On JUNE 16 1991 (date) I conducted a site evaluation for this project and certify that the data reported is accurate. The system I propose is in accordance with the Subsurface Wastewater Disposal Rules.

Signature: Thomas A. Adams 277/4798 7/2/91
 Site Evaluator of Professional Engineer's Signature PE # 1 PE (Date)

Page 1 of 3
HHE-20J Rev. 4/83



SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering

Town, City, Plantation: **PORTLAND PEAKS ISLAND** Street, Road, Subdivision: **PLEASANT AVENUE 90-N-6,7** Owners Name: **LINDA K CREILSON**

SITE PLAN

Scale 1" = 50 Ft.



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole 2 Test Pit Boring

Depth of Organic Horizon Above Mineral Soil: 2

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0-3	LOAM	FRIABLE	BROWN	
3-10	LOAMY SAND	LOOSE	RED BROWN	NONE
10-12	MANY ROOTS			
12-30	GRAVELLY SAND	FIRM	OLIVE	COMMON DISTINCT
30-50	SAND	FRIABLE	OLIVE	

Soil Profile: <u>4</u>	Classification: <u>C</u>	Slope: <u>1/2%</u>	Limbing Factor: <u>22</u>	<input checked="" type="checkbox"/> On a Water
				<input type="checkbox"/> Reseptive Layer
				<input type="checkbox"/> Bedrock

Observation Hole 2 Test Pit Boring

Depth of Organic Horizon Above Mineral Soil: 2

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0-6	MIXED-LOAM	FRIABLE	BROWN	NONE
6-10	SILT LOAM	FRIABLE	TAN	COMMON DISTINCT
10-20	SILT LOAM	FIRM	BROWN	MANY PROMINENT
20-30	SANDY LOAM	FIRM	OLIVE	
30-50	BEDROCK			


Soil Profile: <u>4</u>	Classification: <u>D/III</u>	Slope: <u>1/2%</u>	Limbing Factor: <u>7</u>	<input checked="" type="checkbox"/> On a Water
				<input type="checkbox"/> Reseptive Layer
				<input type="checkbox"/> Bedrock

Thomas R. Adams 277/4798 7/2/76
Site Evaluator or Professional Engineer's Signature SE # / PE # Date


SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering

Town, City, Plantation	Street, Road, Subdivision	Owner's Name
PORTLAND PEAKS ISLAND	PLEASANT AVE 90-N-6,7	LINDA K CREILSON
SUBSURFACE WASTEWATER DISPOSAL PLAN		Scale 1" = 20' FT.



FILL REQUIREMENTS	CONSTRUCTION ELEVATIONS	ELEVATION REFERENCE POINT LOCATION & DESCRIPTION
Depth of Fill (Upslope) 14'	Reference Elevation is 100.0	PK NAIL IN 24" BIRCH
Depth of Fill (Downslope) 14'	Bottom of Disposal Area 94.6	
	Top of Distribution Lines or Chambers 95.8	
DISPOSAL AREA CROSS SECTION		Scale:
		Vertical: 1 inch = 5' FT.
		Horizontal: 1 inch = 10' FT.



Signature: Thomas R. Glams SR #/PE # 277/4798 Date 7/2/91
 Site Evaluator or Professional Engineer's Signature Date