

SOM NSTRABL RD. - LITTLE DIAMOND  
105-A-16  
ISL.

AP- Sonnenstrah Road(105-A-16-Little Diamond Island)

March 20, 1963

Mr. Theodore T. Rand  
Little Diamond Island  
Maine

cc to: Mr. Allen H. Barker  
Draper Road  
Wayland, Mass.

Dear Mr. Rand:

Permit for installation of a metalbestos  
pre-fabricated chimney in cottage at the above named location  
is issued herewith. Since fuel used in appliance which is to  
be connected to this chimney is to be other than oil or gas,  
the Building Code requires that the chimney be equipped with  
a cleanout fitting. Permit is issued on the basis that such  
a fitting will be provided.

Very truly yours,

Albert J. Soule  
Building Inspection Director

AJS:ra



R2 RESIDENCE ZONE

PERMIT ISSUED

00219  
M/R 20 1963

# APPLICATION FOR PERMIT

Third Class

Class of Building or Type of Structure

Portland, Maine

March 20, 1963

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Law of the State of Maine the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Scannenstrahl Road (Assess.) Plan 105-A-16 Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Allen N Barker, Little Diamond Island Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address Theodore T Rand, Draper Road Wayland Mass. Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans no No. of sheets \_\_\_\_\_  
 Proposed use of building Cottage No. families 1  
 Last use \_\_\_\_\_ " \_\_\_\_\_ No. families \_\_\_\_\_  
 Material Frame 1 1/2 No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_ Fee \$ 2.00  
 Estimated cost \$ 100.00

## General Description of New Work

To erect "Prefac chimney"

Type of heat and fuel Franklin Stove-wood  
 Make Metalbestos-7" type M  
 Supported on frame of building  
 No cleanout fitting? See letter.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

## Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing Lumber-Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Corner posts \_\_\_\_\_ Sills \_\_\_\_\_  
 Size Girder \_\_\_\_\_ Column under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st fl. \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

APPROVED:

*O.R. - 3/20/63 - agj*

Allen N Barker  
Theodore T Rand

CS-111

INSPECTION COPY

Signature of owner


by:

*Theodore T Rand*

*TM*

NOTES

3/6/64 Assume this  
would be seen in  
off



Permit No. 69/219

Location *W. 1st St. to 1st St. E. to 1st St. W. to 1st St. E.*

Owner *Oliver H. Burdick*

Date of permit *3/21/64*

Notif. casing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

Staking: Out Notice

Form Check Notice

TO BE FILLED IN BY THE PERMITTEE