



(A) APARTMENT HOUSE ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

01571
JUN 2 1948

Class of Building or Type of Structure Third Class
Portland, Maine, August 30, 1948

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair ~~and~~ install all the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications: 109C-A-12-16

Location Sunset Road, Cliff Island Within Fire Limits? no Dist. No. _____
Owner's name and address Teresa Rice, Cliff Island Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address Howard Clark, Cliff Island Telephone _____
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building Cottage No. families _____
Last use _____ No. families _____
Material frame _____ No. stories 1 1/2 Heat _____ Style of roof pitch Roofing _____
Other buildings on same lot _____ Fee \$ 2.00
Estimated cost \$ 200

INSPECTION NOT COMPLETED

General Description of New Work

To construct 6'x9' addition on rear of cottage -
To cut in new opening 2'6" between existing kitchen and new addition.
24' to street line - 10' to side lot lines

NOTIFICATION BEFORE RATHING
OR CLOSING-IN IS WAIVED

Handwritten calculations:
9 x 1.33 x 45 = 540
2 x 4 on 9' span = 290
6 x 1.33 x 45 = 360
2 x 4 on 6' span = 430

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Teresa Rice CERTIFICATE OF GUARANTEE REQUIREMENT IS WAIVED

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Height average grade to top of plate 9' Height average grade to highest point of roof 12'
Size, front _____ depth _____ No. stories 1 1/2 solid or filled land? solid earth or rock? rock
Material of foundation concrete at least 4' below grade or to ledge Thickness, top _____ bottom low cellar _____
Material of underpinning _____ to sill _____ Height _____ Thickness _____
Kind of roof shed-pitch Rise per foot 5/12 Roof covering asphalt roofing Class C Und. Lab. _____
No. of chimneys none Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber Kind hemlock Dressed or full size? dressed
Corner posts 4x4 Sills 4x6 Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x6, 2nd none, 3rd _____, roof 2x6
On centers: 1st floor 16", 2nd _____, 3rd _____, roof 16"
Maximum span: 1st floor 9', 2nd _____, 3rd _____, roof 9'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Signature of owner

Teresa Rice

INSPECTION COPY

Permit No. 4811571

Location Sunset Rd. Cliff

Owner Teresa Rice

Date of permit 9/2/48

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

INSPECTION NOT COMPLETED

NOTES

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...

THRESHOLD MORT...



109-C-A-12616
APPLICATION FOR AMENDMENT TO PERMIT

PERMIT ISSUED
 SEP 29 1948
 CITY of PORTLAND

Amendment No. 2
 Portland, Maine, September 28, 1948

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 48/1571 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Sunset Rd., Cliff Island Within Fire Limits? no Dist. No. _____
 Owner's name and address Teresa Rice, Sunset Rd., Cliff Island Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Howard Clarke, Cliff Island Telephone _____
 Architect _____ Plans filed nc No. of sheets _____
 Proposed use of building Cottage No. families _____
 Last use _____ No. families _____
 Increased cost of work _____ Additional fee 25

Description of Proposed Work

To provide concrete foundation 8" at top and 10" at bottom instead of stone in mortar foundation. Foundation to be at least 4' below grade or to ledge and in this case ledge was encountered 12" below grade.

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

Approved: _____

Signature of Owner By: Howard Clarke

Approved: 9/28/48 _____

Inspector of Buildings

INSPECTION COPY

Memorandum from Department of Building Inspection, Portland, Maine

Sunset Road, Cliff Island (Teresa Rice)—Amendment to building permit to cover second addition to kitchen for Mrs. Teresa Rice by Howard Clarke, builder

9/8/48

The application for amendment shows that the stone wall laid in mortar would be 16" thick at the top and only 12" thick at the bottom. No doubt this is an error, the wall being required to be no less than 16" thick at any point.

The approved amendment subject to this change is issued to Mrs. Rice and a copy of this memorandum to Mr. Clark.

McD/S

CC: Mr. Howard Clark
Cliff Island, Maine

(Signed) Warren McDonald
Inspector of Buildings



APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1

Portland, Maine, Sept. 7, 1948

PERMIT ISSUED

SEP 8 1948

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 48/1571 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Sunset Rd., Cliff Island Within Fire Limits: no Dist. No. _____
 Owner's name and address Teresa Rice, Sunset Rd., Cliff Island Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Howard Clarke, Cliff Island Telephone _____
 Architect _____ Plans filed, No. _____ No. of sheets _____
 Proposed use of building Cottage No. families _____
 Increased cost of work 150. Additional fee .25

Description of Proposed Work

TO BE DONE

To construct 7'x9' addition to existing kitchen (opposite side from other addition) in same location as existing platform.

Permit Issued with Memo

Details of New Work

Is any plumbing work involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate 9' Height average grade to highest point of roof 12'
 Size front _____ depth _____ at least 4' below grade or to ledge? _____ No. stories 1 solid or filled land? no earth or rock? rock
 Material of foundation stone in mortar Thickness, top 16" bottom 16" cellar no
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof shed-roof Rise per foot 5" Roof covering asphalt roofing Glass Wind Lab.
 No. of chimneys none Material of chimneys _____ of lining _____
 Framing lumber—Kind hex. oak Dressed or full size dressed
 Corner posts 4x4 Sills 4x6 Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) "x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x6, 2nd _____, 3rd _____, roof 2x6
 On centers: 1st floor 16", 2nd _____, 3rd _____, roof 16"
 Maximum span: 1st floor 9', 2nd _____, 3rd _____, roof 9'

Approved: _____

Signature of Owner Teresa Rice

Approved: [Signature]

Inspector of Buildings

INSPECTION COPY

AP Sunset Road, Cliff Island
(Mrs. Teresa Rice)-I

September 2, 1948

Mrs. Teresa Rice
Sunset Road
Cliff Island, Maine
Mr. Howard Clarke
Cliff Island, Maine

Subject: Building permit for alterations of
and construction of an addition at the
rear of the cottage of Mrs. Teresa Rice
on Sunset Road, Cliff Island

Dear Madam & Sir:

Following receipt of Mrs. Rice's letter, saying that 2x6 roof joists are to be used in the roof of the addition and that the stone in mortar foundation wall which has been built without first securing a permit is no less than 16" thick, the building permit is issued to her, herewith, subject to the following:

1. The entrance of this cottage faces the shore and the rear of the cottage is toward Sunset Road. The permit is issued upon the understanding that the nearest wall of the addition to Sunset Road is more than 10' from the line between Sunset Road and Mrs. Rice's land; that the lot on either side of this lot, on which the cottage is located, has no buildings at all on it; and that no part of the exterior walls of the addition will be closer than 10' to either side property line.

2. I understand from the owner that certain posts or piers beneath the existing kitchen or other parts of the cottage have already been replaced, although no permit was secured therefor, by a masonry wall consisting of stone laid in mortar, and from the owner's letter that this wall under the existing cottage is no less than 16" thick, which is the minimum permitted by the Building Code for such a foundation wall. If this work already done complies with this specification, it is included in the permit now issued. If it does not so comply, it is not so included in this permit now issued, and arrangement should be made to make the wall comply with Building Code requirements.

3. The owner also said that the greater part or all of the foundation wall under the proposed addition had been built, although no permit therefor had been issued; that this wall consists of stone laid in mortar, and I understand from her letter that upon returning to the Island she found that this wall was at least 16" in width or thickness which is the minimum allowed by the Building Code for this type of wall, and I take it that the statement in her letter of August 31 that "the underpinning in correct" means that the wall is no less than 16" thick and that the stones are laid in mortar. If that is not the case, no further work should be done under this permit, and the wall should either be made to comply with the Building Code before proceeding with the superstructure, or else the permit should be returned immediately for whatever adjustment seems possible.

4. The 1x6 sill is to be solid lumber in cross-section, not built of more than one piece, the 2x6 floor joists are to have no less than 1x3 cross-bridging in about the center of each span. From the owner's letter I understand that 2x6 roof joists are to be used instead of the 2x4, which she indicated in the application. If these roof joists are to have a pitch of less than 5" to the foot, they should have no less than 1x3 cross-bridging in about the center between each pair.

Very truly yours,

WMC/S

Inspector of Buildings

(see next page)

Rice, Clarke — 2

September 2, 1948

Dear Mr. Clarke:

Mrs. Rice tried to file this application August 30, and was quite insistent that we issue the permit at once. She was unable to give much of the information that we needed, both under the Zoning Ordinance and under the Building Code, and it was only after a considerable period of explaining and questioning that I could get any comprehension of what it was about.

She gave you as the contractor, and said that the new foundation wall under the cottage and practically all of it under the addition had already been built. From her description I gather that these walls were stone laid in mortar, but she was unable to say how thick they had been built. She did not say that you had been in charge of constructing the walls, and I have difficulty believing that you would do this work without a permit.

We had quite a time getting cleared up about the roof and I am not at all sure that we have the right information now. She insisted that you were to use 2x4 roof joists, 16" from center to center, running the 9-foot way of the addition and that the addition was to have only one pitch on the roof and that about 4" to the foot. She later concluded that the total rise of the roof would be 4' which made about 5½" per foot pitch. Her letter says that you intended to use 2x6 anyway. As a matter of fact if the pitch is more than 5", you could use 2x4's, 16" from center to center, if no ceiling was to be hung on them. If you are to use the 2x6's, whether the pitch is to be more or less than 5" to the foot, they could be spaced 24" from center to center.

I am afraid it is not going to be possible for us to get an inspector down to Cliff Island again this fall unless some other important job comes up. For that reason we are stamping off the requirement for notice of readiness for closing-in inspection, relying on you to get everything spaced right and the firestops in, if any are needed before covering up the work.

Warren McDonald.


Tuesday - Aug. 31/48

Department of Bldg. Inspection,
Portland, Maine

Dear Sirs - When I made application
for a permit ~~for~~ ^{for an} addition to my kitchen I
made a mistake in saying the rafters to
be used were 2x4 but Mr. Clark is using
2x6 according to law. And also Mr. Clark
says that the underpinning is correct,
and that he has been building for years,
and knows what is the right and proper
to do, and expects it to pass inspection.
Will you kindly send me the permit by
return mail, so they can proceed with
their work.

Sincerely
(Mrs) Terese R. Rice

Cliff Island
Maine





(A) APARTMENT HOUSE ZONING PERMIT ISSUED
APPLICATION FOR PERMIT

1258

Class of Building or Type of Structure Third Class

SEP 5 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME:

Portland, Maine, September 5, 1933

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Sunset Road, Cliff Island Ward 1.1 Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address Teresas E. Rice Cliff Island Telephone _____

Contractor's name and address Owner Telephone _____

Architect's name and address _____ Telephone _____

Proposed use of building Cottage No. families _____

Other buildings on same lot _____

Plans filed as part of this application? no No. of sheets _____

Estimated cost \$ 25.00 Fee \$ 25

Description of Present Building to be Altered

Material wood No. stories 2 Heat _____ Style of roof _____ Roofing _____

Last use Cottage No. families _____

General Description of New Work

To cut in two new windows (ordinary size) on 1st floor and cut in new door opening on 1st floor to open out on plaza

To build 4' addition on side of existing one story open platform on side of cottage

NOTIFICATION BEFORE LATENT OR CLOSING-IN IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by the heating contractor.

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____

To be erected on solid or filled land? _____ Height average grade to highest point of roof _____
_____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per 100 _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Teresas E. Rice

Signature of owner

Teresas E. Rice

INSPECTION COPY

5511

Ward 24 / Permit No. 33 / 1253

Location Sunset Road Cliff Dr

Owner Teressa H. P. He

Date of permit 9/5/83

Notif. closing-in

Ins. pn. closing-in


Final Notif.

Final Inspn.

Cert. of Occupancy issued

NOTES

8/20/86. Although the
cottage was opened
was unable to rain
anyone, etc. looks as
though this work
had been done, etc.



Repairs on summer
cottage at Cliff Island,
Me., belonging to Tressa
W. Rice, as follows:—

Two windows set in 1st
floor, and a door leading
outs a piazza.

Rebuilding and widening
4', the piazza (uncovered)
on one side of the cottage.

Also, if we decide to shun-
gle sides of cottage, what
would the extra fee amount

b-9.

yours truly
E. Rice

9/4/33

August 31, 1935

Mr. Dastace B. Rice
Cliff Island
Portland, Maine

Dear Sir:

I have your letter of August 29th concerning certain changes in your summer cottage at Cliff Island. A number of 5-cent postage stamps were enclosed with your letter which I am returning herewith.

I am sorry that we cannot issue your permit in any but the regular way. Some person who knows what is to be done and can explain it must come to this office and give the information, sign the application in your name, and pay the fee.

It would be quite a long story to explain to you why we cannot receive applications by mail, but I can assure you that it is not possible to handle the matter in that way.

In the same mail as your letter, I have a request from Mr. Joseph A. Davis of Cliff Island who asks that we send him a permit to cover repairs to the roof of his house at Cliff Island. I am writing him also that the application must be made by some individual. Possibly you and Mr. Davis could get together, and only one of you need come to the city, as whichever one came could file both applications and sign the application of the other owner as his agent.

Very truly yours,

Inspector of Buildings.

WV/HC
Enc.

Cliff Is., Me. 7-9/33

Warren McDonald,
Inspector of Bldgs.,
Portland, Me.

Dear Sir:

I have your letter of the 23rd inst. at hand, regarding repairs on my Cliff Is. summer cottage. I expect to be in Portland before many days, to make formal application for the permit. In the mean time, I want to have you know that I received your letter and am giving the matter proper consideration. The piazza on one side of the house needed pulling down. We like it about 4' wide. It has no roof. Then there are the 2 windows and an extra door. We also contemplate shingling the sides of the cottage. Would it not be possible, in this case, to send me a permit? I will send my check for the amount of

the fee

Yours, with thanks
for your good letter.

Eustace P. Rice

Gr/

RECEIVED
AUG 23 1953
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

Cliff Island, Me.

City of Portland, Me.
Dept. of Buildings
Gentlemen:

8/22/53

I wish a permit for
repairing my piazza, setting two new
windows and a door.

Kindly mail me the requisite
card and let me know if there
is a fee. The cottage stands in the name
of Teressa H. Rice.

Yours very truly

E. H. Rice

August 23, 1933

Mr. E. B. Rice
Cliff Island
Portland, Maine

Dear Sir:

I have your letter of August 22, 1933 requesting a building permit. It is necessary for some person to come to this office and make formal application for such a permit on blank forms furnished by this Department and written here. From your letter I should judge that the setting of the two new windows and a door requires a permit, but I am not so sure about the repairing of the piazza. If repairs to the piazza are merely replacing woodwork that has rotted and the like, then no permit is required to include the piazza work, but if the piazza is to be altered in any way, either by increasing or decreasing the size of the piazza, or if the roof covering of the piazza is to be repaired, then the work should be included in the permit.

There is a small fee required to cover issuing the permit, and the size of this is based upon the complete estimated cost of the work to be done. The fee for the work which you have outlined probably would not exceed fifty cents (50¢).

The carpenter who is to do the work can very nicely make application for the permit in the name of the owner.

Very truly yours,

Inspector of Buildings.

RE/HO



(1) APARTMENT HOUSE ZONE PERMIT ISSUED
APPLICATION FOR PERMIT 1253

SEP 5 1939

Class of Building or Type of Structure Third Class

Portland, Maine, September 5, 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect, alter, install the following building structure, equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Sumner Road, Cliff Island Ward 13.1 Within Fire Limits? NO Dist. No. _____

Owner's or Lessee's name and address T. Rosa H. Rice Cliff Island Telephone _____

Contractor's name and address Order Telephone _____

Architect's name and address _____ Telephone _____

Proposed use of building Cottage No. families _____

Other buildings on same lot _____

Plans filed as part of this application? no No. of sheets _____

Estimated cost \$ 25.00 Fee \$ 25

Description of Present Building to be Altered

Material wood No. stories 2 Heat _____ Style of roof _____ Roofing _____

Last use Cottage No. families _____

General Description of New Work

To cut in two new windows (ordinary size) on 1st floor and cut in new door opening on 1st floor to open out on to piazza
To build 4' addition on side of existing one story open platform on side of cottage

NOTIFICATION BY _____
OR CLOSING IN IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out, separately, by and under the supervision of the heating contractor.

Details of New Work

Size: front _____ depth _____ No. stories _____ Height average grade to top of plate _____
Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ ft. or in _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Foists and rafters: 1st floor _____ 2nd _____ 3rd _____ roof _____

On centers: 1st floor _____ 2nd _____ 3rd _____ roof _____

Maximum span: 1st floor _____ 2nd _____ 3rd _____ roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner _____ By Toreusa H. Rice

ORIGINAL

5508

Ward Isl. 1 Permit No. 33/1255

Location Sunset Road, Cliff Island

Owner Teressa H. Rice

Date of permit 9/5/33

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

NOTES:

99-A-12-16



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Nov. 15, 1983
 Receipt and Permit number B19598

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 109-C-B-12 Sunset Avenue, Cliff Island
 OWNER'S NAME: James Colt ADDRESS: same

OUTLETS:	FEE:
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead <input checked="" type="checkbox"/> Underground _____ Temporary _____ TOTAL amperes <u>200</u>	3.00
METERS: (number of) <u>1</u>50
MOTORS: (number of)	
fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
	INSTALLATION FEE DUE:
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	DOUBLE FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	
	TOTAL AMOUNT DUE:
	<u>5.00</u>

INSPECTION:

Will be ready on _____, 19__; or Will Call

CONTRACTOR'S NAME: Thomas Wright

ADDRESS: Cliff Island, Portland

TEL.: 766-2625

MASTER LICENSE NO.: _____ SIGNATURE OF CONTRACTOR:

LIMITED LICENSE NO.: 634 Thomas Wright P.A. GOMEZ

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS —

Permit Number 19598

Location 109-C-A-12 Sunset Ave Cliff Island

Owner J. Colt

Date of Permit 11-15-83

Final Inspector 7-19-84

By Inspector Libby

Permit Application Register Page No 15

Cliff Island

INSPECTIONS: Service ✓ by Libby
Service called in 17-13-84
Closing-in 7-19-84 by _____

PROGRESS INSPECTIONS: _____

CODE
COMPLIANCE
COMPLETED
DATE 7-19-84

REMARKS:
DATE: _____

Vertical lines for remarks and additional information.