

84-36 BELMEADE ROAD

SHAW-WALKER

File cut # 9208 Mail cut # 9209 Tear tabs # 9203R 3 File cut # 9205R

PERMIT TO INSTALL PLUMBING

11957

Date Issued: 9-10-62
 Address: 34 Belmonte Street
 Installation For: Charles Tremble
 Owner of Bldg.: Charles Tremble
 Owner's Address: 34 Belmonte Street
 Plumber: Pallotta Oil Company Date: 9-10-62

By: J. P. Welch
 PORTLAND PLUMBING INSPECTOR

APPROVED FIRST INSPECTION		PROPOSED INSTALLATIONS		NUMBRS	FEE
NEW	REPL				
			SINKS		
			LAVATORIES		
			TOILETS		
			BATH TUBS		
			SHOWERS		
			DRAINS		
		1	HOT WATER TANKS	1	\$ 2.00
			TANKLESS WATER HEATERS		
			GARBAGE GRINDERS		
			SEPTIC TANKS		
			HOUSE SEWERS		
			ROOF LEADERS (Conn. to house drain)		

Date: 9-17-62
 By: [Signature]
 APPROVED FINAL INSPECTION

By: JOSEPH E. WELCH

- TYPE OF BUILDING
 COMMERCIAL
 RESIDENTIAL
 SINGLE
 MULTI FAMILY
 NEW CONSTRUCTION
 REMODELING

PORTLAND HEALTH DEPT. PLUMBING INSPECTION TOTAL ▶ \$ 2.00



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Sept. 10, 1962

PERMIT ISSUED
01106
SEP 10 1962
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating-cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 34 Belmeade Road Use of Building Dwelling No. Stories 2 New Building Existing
Name and address of owner of appliance Charles Tremble, 34 Belmeade Road
Installer's name and address Pallotta Oil Co. 112 Exchange St. Telephone _____

General Description of Work

To install hot Oil-fired domestic water heater in place of gas-fired water heater.

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? None
If so, how protected? _____ Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 2'
From top of smoke pipe 15" From front of appliance _____ From sides or back of appliance _____
Size of chimney flue with asbestos shield Other connections to same flue boiler
If gas fired, how vented? _____ Rated maximum demand per hour _____
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner Delco-gun type Labeled by underwriters' laboratories? Yes
Will operator be always in attendance? _____ Does oil supply line feed from top or bottom of tank? Bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement-existing Number and capacity of tanks 275 existing
Low water shut off _____ Make _____ No. _____
Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? _____
Total capacity of any existing storage tanks for furnace burners _____

IF COOKING APPLIANCE

Location of appliance _____ Any burnable material in floor surface or beneath? _____
If so, how protected? _____ Height of Legs, if any _____
Skirting at bottom of appliance? _____ Distance to combustible material from top of appliance? _____
From front of appliance _____ From sides and back _____ From top of smoke pipe _____
Size of chimney flue _____ Other connections to same flue _____
Is hood to be provided? _____ If so, how vented? _____ Forced or gravity? _____
If gas fired, how vented? _____ Rated maximum demand per hour _____

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature]
9/10/62

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Pallotta Oil Company

Signature of Installer by: [Signature]

INSPECTION COPY

CS 200

7M



(R) RESIDENCE ZONE - C
APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, April 26, 1954

PERMIT ISSUED
00508
APR 27 1954
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 34 Belmeade Road Within Fire Limits? Yes Dist. No. _____
Owner's name and address Charles Tremble, 34 Belmeade Road Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address J. E. Boone, 71 Lincoln St. Telephone 3-1367
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building dwelling house No. families 1
Last use _____ " " _____ No. families 1
Material WOOD No. stories 2 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 40. Fee \$ 50.

General Description of New Work

To change two windows in kitchen to one window 40" x 40", 2x4 header.

Permit Issued with Memo

CERTIFICATE OF OCCUPANCE
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO contractor

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber--Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? _____
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Charles Tremble

Signature of owner by:

Memorandum from Department of Building Inspection, Portland, Maine

34 Belmeade Road--To change size of window for Charles Tremble by
J. F. Doone--April 27, 1954

Application does not indicate framing strong enough to satisfy Building Code. So, permit is issued subject to condition that doubled 2x4 headers will be used over opening with short or "jack" stud under each end of the header.

WMC0/B

CC: Mr. Charles Tremble
34 Belmeade Road

(Signed) Warren McDonald
Inspector of Buildings

P. 33/1937-I

1-4-43-H

December 21, 1933

Eastern Oil, Inc.
133 Marginal Way,
Portland, Maine

Dear Sir:

With relation to the oil burning equipment which you have installed for Miss Gertrude Manish at 34 Bolmeado Road, please provide an instruction card relating to the operation of the oil burner near the oil burner assembly and permanently in place without delay.

Our inspector in making examination found that there is in the oil feed line between the tank and the new burner merely a manually operated valve instead of the automatic closing, quick-action valve considered necessary for safety.

I realize that this tank and valve are parts of a former installation and that perhaps you have nothing to do with the nature of valve installed there. Nevertheless to satisfy the ordinarily accepted standards of safety, which the owner, who is receiving a copy of this letter, no doubt desires, the proper valve ought to be provided for the protection of the property and the occupants of the building.

For the owners benefit, let me explain that the difference between the valve in the oil pipe now and that recommended is that the present valve must be closed by hand. In case of fire in the cellar from any source the oil would continue to run from the tank to the burner unless some person was able to reach the valve and shut it. The automatic valve which ought to be provided has an element within the valve which will quickly melt at high temperatures, and the valve is so designed that when the element melts the valve quickly closes of itself. Thus with this automatic valve in the pipe, if a fire occurs in the cellar, even in the dead of night, the excessive heat of the fire would close the valve and thus stop the flow of oil from the tank without any person being present.

Very truly yours,

RMCD/H

CC: Gertrude Manish
34 Bolmeado Road

Inspector of Buildings



FILL IN COMPLETELY AND SIGN WITH INK
STEAM

PERMIT ISSUED

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

NOV 4 1939

Portland, Maine, Nov. 4, 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 34 Belmeade Rd. Use of Building Residence

Name and address of owner Miss Gertrude Menish, 34 Belmeade Rd. Ward _____

Contractor's name and address Easternoil, Inc. 133 Marginal Way Telephone 3-6495

General Description of Work

To install Oil Burner

NOTIFICATION FROM
OR CLOSING IN IS
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? Yes If not, which story _____ Kind of Fuel Oil

Material of supports of heater or equipment (concrete floor or what kind) Concrete

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____

from top of smoke pipe _____, from front of heater _____ from sides or back of heater _____

Size of chimney flue _____ Other connections to same flue _____

IF OIL BURNER

Name and type of burner Easternoil Model A Labeled and approved by Underwriters' Laboratories? Yes

Will operator be always in attendance? No Type of oil feed (gravity or pressure) Pressure

Location oil storage Basement No. and capacity of tanks 1-275 already installed

Will all tanks be more than seven feet from any flame? Yes How many tanks fireproofed? _____

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor By M. Michaels

EASTERNOIL, INC

PH
5/11/39

H.

Ward 8 Permit No. 39/1989

Location 34 Belmeade Rd

Owner Fertunde, Marisa

Date of permit 11/7/89

Post Card sent

Notif. for insp. None

Approval Tag issued 12/20/89, CDO

Oil Burner Check List (date) 11/20/89

1. Kind of heat Steam

2. Label 36/898

3. Anti-siphon Existing

4. Oil storage "

5. Tank distance "

6. Vent pipe "

7. Fill pipe "

8. Gauge "

9. Rigidity "

10. Feed safety "

11. Pipe sizes and material "

12. Control valve "

13. Ash pit vent

14. Temp. or pressure safety

15. Instruction card No

16. No. of off-on start

NOTES

#15 - no instruction card.

Manually operated

valve instead of fusible valve at tank, existing condition. CDO

12/21/89 - A.T.H. P.S. note that I did not absolutely order them to change valve. I'm such a base if you just on a try I think you ought to write on the tag in plain English that a snubber valve is a burner device is most approved - and 1/5/90. Nothing done. Miss Marisa said Mr. Loring, Eastern Oil said fusible valve not needed. Said she would have one put on just the same. CDO.

1/12/90. Fusible valve at tank. CDO.



YOU!
are responsible for complying
with the requirements or not.

APPLICATION FOR PERMIT TO BUILD

CLASS BUILDING

This Application and
Get All Questions Settled
Portland, Maine, June 8, 1925 19

To the INSPECTOR OF BUILDINGS, BEFORE COMMENCING WORK.

The undersigned hereby applies for a permit to build, according to the following specifications, the Laws of the State of Maine, and the Building Ordinance of the City of Portland:

EXPENSIVE

Location 34-36 Belmeade Rd Ward 8 Within Fire Limits? no
 Owner's name and address? W C French, 130 Highland Street
 Contractor's name and address? over
 Architect's name and address? _____
 Proposed occupancy of building (purpose)? dwelling & private garage 1 car
 No. families? 1 apartments? _____ lodgers? _____
 Size, front? 26, depth? 39 No. stories? 1 1/2, height, average grade to highest point of roof? 24
 To be erected on solid or filled land? solid earth or rock? _____
 Material of foundation? stone Thickness, top? 18 bottom? yes
 Material of underpinning? stone over 4 ft. high? 2ft thickness? 16in
 Kind of roof (pitch, hip, etc.)? pitch Kind of roofing? asphalt
 Kind of heat? steam Material of chimney? brick, of lining? tile

SIZE OF FRAMING MEMBERS

Corner posts? 4x6 Sills? 4x4 Rafters or roof beams? 2x6 on center? 24
 Material and size of columns under girders? 4 in iron pipe on center? _____
 Ledger board used? yes Size? 2x6 Studs (outside walls and carrying partitions) 2 x 4 16" O.C.
 Girders 6" x 8" or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts will be all one piece in cross section.
 Floor timbers: 1st floor 2x8, 2nd 2x8 finished rooms, 3rd _____, 4th _____
 On centers: 1st floor 16, 2nd 16, 3rd _____, 4th _____
 Span: 1st floor 14ft, 2nd 14ft, 3rd _____, 4th _____

IF 1ST OR 2ND CLASS BUILDING

External walls } thickness { 1st story _____, 2nd story _____
 Party walls } { 1st story _____, 2nd story _____
 Material of cornice? _____ How fastened? _____

IF APARTMENT, TENEMENT OR LODGING HOUSE

Dimensions of lot? _____
 Dimensions of other buildings on lot? _____
 Clear _____ to rear lot line? _____, to one side lot line? _____, to other side lot line? _____

IF A PRIVATE GARAGE

No. cars to be accommodated? 1
 Other buildings on same lot? vacant lot
 Distance from nearest present building to proposed garage? 30
All parts of garage, including eaves, will be at least 2 ft. from all lot lines.
 Garage will be at least 50 feet from nearest windows of adjoining property.
 Will there be a heating plant within building? yes
 If so, how protected? radiator

MISCELLANEOUS

Will the above construction require the removal or disturbing of any shade tree on the public street? yes no
 Plans filed as part of this application? no No. sheets? _____
 Estimated total cost \$ 9,000. Fee? 1.75

Signature of owner or authorized representative? W. C. French
APPROVED
Miss P. Leachman
 CHIEF OF FIRE DEPT.