

Ap 55-59 Baxter Boulevard

ATH  
LESS  
RMT  
PH  
AJS  
XBS  
HL

May 14, 1946

Centennial Broadcasting Company  
21 Preble Street  
Portland 3, Maine

Subject: Building permit for construction of broadcasting studio, office and transmitter house at 55-59 Baxter Boulevard

Gentlemen,

The last time I passed by the site of this proposed building, no work had been done upon it.

Your attention is respectfully called to the fact that if the work is not started before three months have elapsed from the date of issuance of the permit (March 14, 1946), the building permit will have lapsed and it would be necessary to apply again and secure the permit in the same manner as before the work could be lawfully started.

This feature is of particular importance under the circumstances because since a building permit was issued, the Building Code has been changed so that the site of the proposed building is in Fire District No. 1A where the class of construction (wooden frame or Third Class) proposed for this building is not allowable, and therefore no building permit could be issued to cover that type of construction.

Very truly yours,

Inspector of Buildings

W McD/L