

INQUIRY BLANK

Verbal  
By Telephone

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

ZONE I  
FIRE DIST. 1A

LOCATION 237 Baxter Blvd. OWNER Herbert W. Hayes Date 8/8/50  
MADE BY Ernest C. Soule ADDRESS 75 Edwards Street TEL. 2-7301  
PRESENT USE OF BUILDING Storage  
CLASS OF CONSTRUCTION Metal frame NO. OF STORIES 1

REMARKS:

INQUIRY: 1- Can a wood frame addition 25' x 100' with wood floor be built on the west side of 40' x 100' metal frame building (2 stories high) for use as an enclosed loading platform?  
2- Can an addition with metal frame roof and walls and heavy timber floor be built of same size?

ANSWER: 1- Only if constructed as specified in section 403-d of the Building Code governing construction in Fire District 1-A and the existing building and addition is equipped with an automatic sprinkler system.  
2- Such an addition would have to be classed as Metal Frame Construction, in which the wood floor is not permissible.

DATE OF REPLY 8/8/50 REPLY BY A.J.S.

INQUIRY BLANK

ZONE 6  
FIRE DIST. 1A

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

Date 11/7/46

Verbal  
By Telephone

LOCATION 29-37 Baxter Blvd. OWNER C. E. Noyes Company  
MADE BY Lithen H. Henderson TEL. 2-9543

ADDRESS 181 State Street

PRESENT USE OF BUILDING Tire storage building now under construction

CLASS OF CONSTRUCTION Metal frame NO. OF STORIES 1

REMARKS:

INQUIRY: 1 - Would it be permissible to make end wall of building toward Baxter Boulevard of stucco construction, leaving off metal covering sheets and providing metal lath and plaster on both sides of wall, framing after providing additional metal studing or furring to support plaster in proper manner.

ANSWER: 1 - Would check and let him know 11/8/46 - Such construction would be permissible in Fire District, but we should have to have full information as regards framing in end to be stuccoed based this should be obtained from designer of building to make sure that it will work out for strength.

DATE OF REPLY 11/7/46 REPLY BY A. J. Sears

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

CERTIFICATE OF OCCUPANCY

This is to certify that the building at 29-37  
Baxter Blvd., built ~~under~~ under Building Permit No.  
40,153<sup>4</sup> has been finally inspected and may now be oc-  
cupied for the purpose of warehouse (tire storage).

Date 1/21/47

Inspector of Buildings

Issued to G. B. Noyes Co.

(~~Signature~~)

Temporary Certificate only  
Final to be issued later

INQUIRY BLANK

16x72  
18x72

ZONE I

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

FIRE DIST. 1B

Verbal  
By Telephone

DATE 10/15/46

LOCATION 29-37 Baxter Blvd OWNER C. C. Noyes Co

MADE BY Herbert Noyes TEL. 2-4647

ADDRESS 195 Forest Avenue

PRESENT USE OF BUILDING Major Garage

CLASS OF CONSTRUCTION Metal Frame NO. OF STORIES 1

REMARKS: Plumb some one else has found that

finishes but there is also a  
for a timber system to canal at metal

INQUIRY: 1- Can the two metal garages, one 16'x72' and the  
other 18'x72', now located at 292 Forest Avenue on  
property of E. Hansen Co., be located on above lot  
where Annex is being built and be used for  
storage purposes?

2- Can these be placed back to back on lot?

ANSWER: 1- In order to be located on lot to comply with  
Building Code regulations they must be considered  
as two separate buildings, be located at least 5' from  
each other and from the other building on the lot  
as well as 10' from any lot line. This would take  
a width of 10' + 16' + 15' + 15' + 5' = 55' where only 50' is available.  
If either of buildings is located so that doors would  
be closer than 30' to any openings in new building  
(over)

DATE OF REPLY

REPLY BY

Handwritten initials and date: HN  
10/17/46



(1) INDUSTRIAL ZONE  
APPLICATION FOR PERMIT

Permit No. **01587**  
**PERMIT ISSUED**

Class of Building or Type of Structure Metal Frame  
Portland, Maine, August 21, 1946 **AUG 28 1946**

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~and~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 29-37 Baxter Blvd. Ward \_\_\_\_\_ Within Fire Limits? yes Dist. No. 1A  
Owner's or lessee's name and address C. E. Noyes Co., 195 Forest Avenue Telephone \_\_\_\_\_  
Contractor's name and address Northeast Bldg. Corp., 142 High Street Telephone \_\_\_\_\_  
Architect Stran-Steel Standard Plan 40 Plans filed yes No. of sheets \_\_\_\_\_  
Proposed use of building Warehouse (tire storage) No. families \_\_\_\_\_  
Other buildings on same lot \_\_\_\_\_ Fee \$ 1.00  
Estimated cost \$ 8000.

Memorandum from Department of Building Inspection, Portland, Maine

29-37 Baxter Boulevard—Construction of one-story building, 40' by 100' for C. E. Noyes Company by Northeast Building Corp., builders—8/19/46

To Owner & Builders:

A permit is issued for the building to be used for storage only, without interior partitions, without insulation and without provision for heat.

WNCB/D

CC: Northeast Building Corporation  
142 High Street

(Signed) Warren McDonald  
Inspector of Buildings

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. Framing Lumber

Details of New Work

Kind? \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_  
Dressed or Full Size? \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories 1 Height average grade to highest point of roof \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of Roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ of lining \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_  
Kind of heat none Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_


If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Original



X

Ward Permit No. 46/1581

Location 29-31 Baxter Blvd

Owner C. P. Rogers Co

Date of permit 8/29/46

Notif. closing-in

Insph. closing-in

Final Notif.

Final I. opn. 5/16/47 - OK

Cent. of Occupancy issued 1/23/47

NOTES

2/2/46 - 1st inspection OK

4/17/46 - 2nd inspection OK

6/14/46 - 3rd inspection OK

8/14/46 - 4th inspection OK

10/21/46 - 5th inspection OK

12/18/46 - 6th inspection OK

2/15/47 - 7th inspection OK

4/12/47 - 8th inspection OK

6/9/47 - 9th inspection OK

8/6/47 - 10th inspection OK

10/3/47 - 11th inspection OK

12/1/47 - 12th inspection OK

1/29/48 - 13th inspection OK

4/16/48 - 14th inspection OK

7/13/48 - 15th inspection OK

10/10/48 - 16th inspection OK

1/7/49 - 17th inspection OK

4/4/49 - 18th inspection OK

7/1/49 - 19th inspection OK

one office easement party

to be used as a parking area

near 15th St. and Lexington

we are commencing with

sale of used cars about

on the lot and that

there is no connection

from office to rest of

ground. The parties

are both to be shown on

the attached sketch. Best

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

is provided by means

of a concrete curb and

No.	Inspection	Date	Remarks
1	Inspection	2/2/46	1st inspection OK
2	Inspection	4/17/46	2nd inspection OK
3	Inspection	6/14/46	3rd inspection OK
4	Inspection	8/14/46	4th inspection OK
5	Inspection	10/21/46	5th inspection OK
6	Inspection	12/18/46	6th inspection OK
7	Inspection	2/15/47	7th inspection OK
8	Inspection	4/12/47	8th inspection OK
9	Inspection	6/9/47	9th inspection OK
10	Inspection	8/6/47	10th inspection OK
11	Inspection	10/3/47	11th inspection OK
12	Inspection	12/1/47	12th inspection OK
13	Inspection	1/29/48	13th inspection OK
14	Inspection	4/16/48	14th inspection OK
15	Inspection	7/13/48	15th inspection OK
16	Inspection	10/10/48	16th inspection OK
17	Inspection	1/7/49	17th inspection OK
18	Inspection	4/4/49	18th inspection OK
19	Inspection	7/1/49	19th inspection OK

INQUIRY BLANK

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

ZONE I  
FIRE DIST. Nones

DATE 12/13/45

Verbal  
By Telephone

15-57

LOCATION 235-45 Baxter Blvd. OWNER \_\_\_\_\_

MADE BY Mel Libby + Herbert W. Noyes of C.E. Noyes Co. 2-4647

ADDRESS 195 Noyes Street

PRESENT USE OF BUILDING \_\_\_\_\_ NO. OF STORIES \_\_\_\_\_

CLASS OF CONSTRUCTION \_\_\_\_\_

REMARKS: \_\_\_\_\_

INQUIRY: Can a one story building of about 10,000 sq ft area for use for tire storage be built at this location of wood frame construction? Tire re-treading shop may possibly be moved to this new building. Building will front on Marginal way and a proposed street to be built for development of property.

ANSWER: If building is sprinklered, otherwise it would be limited to 8,170 sq ft. for building front on two streets. If drive-in service for changing tires were contemplated, it might change the fire drive-in service or keeping of auto. mobile in building.

2- No, but hazardous rooms, such as building-room in case of tire re-treading plant, would be

DATE OF REPLY 12/13/45 REPLY BY A.J. Sears

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for Warehouse at 29-37 Baxter Blvd. Date 8/21/46

1. In whose name is the title of the property now recorded? C.E. Woyses Co.
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Yes, by stake
3. Is the outline of the proposed work now staked out upon the ground? yes no.  
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? yes.
4. What is to be maximum projection or overhang of eaves or drip? none
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes.
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes.
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes.

C.E. Woyses Co.  
Herbert W. Woyses



PERMIT CARD WILL BE IN GARAGE BLDG.

PERMIT ISSUED

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

APR 17 1987

City of Portland

Portland, Maine, April 14, 1987

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

WORK IS FOR BLDGS. 1, 2, 3, 4 and garage & 5 New Building
Location 290 Baxter Blvd Use of Building Condominiums No. Stories 3 Existing " X
Name and address of owner of appliance Ricker Park Associates - same - 773-1470
Installer's name and address Union Oil Co. - P.O. Box 2528 SO. Portland Telephone 789-1521
04106

General Description of Work

To install 4 boilers, 1 in each of bldg. 1, 2, 3, 4, 3 warm air furnaces in garage and work area. each location will have 2 330 gal. oil storage tanks

IF HEATER, OR POWER BOILER

Location of appliance garage - floor Any burnable material in floor surface or beneath? no
If so, how protected? level Kind of fuel? # 2 fuel oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3' all around to 8'
From top of smoke pipe 18 x 18 min From front of appliance From sides or back of appliance
Size of chimney flue 12 x 12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Carlin - gun - Beckett 7 Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner Size of vent pipe garage - storage supply system
Location of oil storage base, ent. Number and capacity of tanks each bldg. 660
Low water shut off yes Make McDonald Miller No. 150 x 51-2
Will tanks be more than five feet from any flame? yes How many tanks enclosed? semi enclosed
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 100,598.00 525.00

APPROVED: [Signature line]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

INSPECTION FILE APPLICANT'S COPY ASSESSOR'S COPY
Signature of Installer Edward F. Cornelia Lic # 00998

[Handwritten signature]

NOTES

Blank lined area for notes.

Permit No. 87/324  
Location 210 East  
Owner V-14-87  
Date of permit 1-12-87  
Approved

Left column of lined area with faint text: 1. IM TILL PINE, 2. IM WHITE PINE, 3. Kind of Pine, 4. Number of Pines & Support, 5. Location of Pines, 6. IM TILL PINE, 7. IM WHITE PINE, 8. Kind of Pine, 9. Number of Pines & Support, 10. Location of Pines, 11. IM TILL PINE, 12. IM WHITE PINE, 13. Kind of Pine, 14. Number of Pines & Support, 15. Location of Pines, 16. IM TILL PINE, 17. IM WHITE PINE, 18. Kind of Pine, 19. Number of Pines & Support, 20. Location of Pines.

Right column of lined area.

**PLUMBING APPLICATION**

Department of Human Services  
Division of Health Engineering  
(207) 289-3826

**PROPERTY ADDRESS**

Town Or Plantation: Bayside East & Bayside Terrace

Street: [Blank]

Subdivision Lot # [Blank]

**PROPERTY OWNERS NAME**

Last: Portland Housing Authority

First: [Blank]

Applicant Name: Joseph P. Clancy

Mailing Address of Owner/Applicant (If Different): P.O. Box 717, Brunswick, Me 04011

PORTLAND PERMIT # 2,436 TOWN COPY

Date Permit Issued: 7/20/87

FEE: \$ 1.30

Local Plumbing Inspector Signature: [Blank]

I.P.I. #: 123

**Owner/Applicant Statement**

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: [Blank]

Date: [Blank]

**Caution: Inspection Required**

I have inspected the installation as described above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature: [Blank]

Date Approved: SEP 30 1987

**PERMIT INFORMATION**

This Application is for:

1.  NEW PLUMBING

2.  RELOCATED PLUMBING

Type Of Structure To Be Served:

1.  SINGLE FAMILY DWELLING

2.  MODULAR OR MOBILE HOME

3.  MULTIPLE FAMILY DWELLING

4.  OTHER - SPECIFY: [Blank]

Plumbing To Be Installed By:

1.  MASTER PLUMBER

2.  OIL BURNERMAN

3.  MFG'D. HOUSING DEALER/MECHANIC

4.  PUBLIC UTILITY EMPLOYEE

5.  PROPERTY OWNER

LICENSE # 022440

Hook-Up & Piping Relocation Maximum of 1 Hook-Up	Column 2	Column 1
	Number	Type Of Fixture
<p><b>HOOK-UP:</b> to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.</p> <p><b>OR</b></p> <p><b>HOOK-UP:</b> to an existing subsurface wastewater disposal system.</p>		Hosebibb / Sillcock
		Floor Drain
		Urinal
		Drinking Fountain
<p><b>PIPING RELOCATION:</b> of sanitary lines, drains, and piping without new fixtures.</p>		Indirect Waste
		Water Treatment Softener, Filler, etc.
		Grease/Oil Separator
		Dental Cuspidor
Number of Hook Ups & Relocations		Bidet
	Other:	
\$ Hook-Up & Relocation Fee		Water Heater
	<b>Fixtures (Subtotal) Column 2</b>	<b>Fixtures (Subtotal) Column 1</b>
		<b>Fixtures (Subtotal) Column 2</b>
		<b>Total Fixtures</b>
		<b>Fixtures Fee</b>
		<b>Hook-Up &amp; Relocation Fee</b>
		<b>Permit Fee</b>

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE

\$ 1.30


\$ 1.30<sup>00</sup>

9-15-85

NOTES

2 offices - conference room  
 windows okay.  
 Hallway & doors, etc  
 as per plan  
 9-30- Loading area  
 requirement OK

Completed according to plan



Permit No. 85/876  
 Location 33 Baxter Blvd.  
 Owner Donburg Inc.  
 Date of permit 8/13/85  
 Approved:  
 Dwelling  
 Garage  
 Alteration

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP B 0 876

B.O.C.A. TYPE OF CONSTRUCTION

AUG 18 1985

ZONING LOCATION PORTLAND, MAINE 8/12/85

City Of Portland

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 33 Baxter Boulevard Fire District #1 [ ] #2 [ ]

1. Owner's name and address Donbury Inc. same Telephone 774-6254

2. Lessee's name and address Telephone

3. Contractor's name and address owner Telephone

No. of sheets

Proposed use of building No. families

Last use No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$2,000 Appeal Fees \$

FIELD INSPECTOR—Mr. @ 775-5451 Base Fee 30.00

Late Fee

TOTAL \$ 30.00

to make interior alterations as shown

Stamp of Special Conditions

issued with letter

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING:
BUILDING CODE: MS-d 8/12/85 Will there be in charge of the above work a person competent
Fire Dept.: to see that the State and City requirements pertaining thereto
Health Dept.: are observed?
Others:

Signature of Applicant Arthur Hatt Phone #
Type Name of above Arthur Hatt for 1 2 3 4
Donbury Other
and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY
Mr. McIssac East



## CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

August 13, 1985

Dcnbury, Inc.  
P. O. Box 792  
Portland, Maine 04104

RE: Interior Renovations - 33 Baxter Blvd.

Gentlemen:

A permit to make alterations, as per plan, is issued, subject to the following Building Code requirements:

Exit signs and Emergency lighting are required, as per attached BOCA requirements.

If there is still a mechanical area for vehicles in the abutting warehouse, a 6" threshold or step down is required between areas.

All labeled doors shall have self-closing devices.

Very truly yours

MARGE SCHMUCKAL,  
ACTING BUILDING CODE EXAMINER

MS/mlb

ENC.



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP ..... 0-876 PERMITTED
B.O.C.A. TYPE OF CONSTRUCTION .....
ZONING LOCATION ..... PORTLAND, MAINE 9/12/85 AUG 18 1985

City of Portland

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE
The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 33 Baxter Boulevard
1. Owner's name and address Donbury Inc., same Fire District #1 [ ] #2 [ ]
2. Lessee's name and address Telephone 774-6254
3. Contractor's name and address owner Telephone
Proposed use of building No. of sheets
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 2,000
FIELD INSPECTOR - Mr @ 775-5451
Appeal Fees \$
Base Fee 30.00
Late Fee
TOTAL \$ 30.00
to make interior alterations as shown

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber--Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION - PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING:
BUILDING CODE: Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant Arthur Hatt for Phone #
Type Name of above Donbury 1 [ ] 2 [ ] 3 [ ] 4 [ ]
Other and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date August 30, 19 85  
 Receipt and Permit number D 04272

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:  
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of  
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:  
 LOCATION OF WORK: 33 Baxter Blvd.  
 OWNER'S NAME: Donbury Inc. ADDRESS: \_\_\_\_\_

	FEES
OUTLETS: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL <u>13-60</u> .....	<u>5.00</u>
FIXTURES: (number of) Incandescent _____ Flourescent <u>x</u> (not strip) TOTAL <u>1-10</u> .....	<u>3.00</u>
Strip Flourescent _____ ft. ....	
SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____ ..	
METERS: (number of) _____ .....	
MOTORS: (number of) Fractional _____ .....	
1 HP or over _____ .....	
RESIDENTIAL HEATING: Oil or Gas (number of units) _____ .....	
Electric (number of rooms) _____ .....	
COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____ .....	
Oil or Gas (by separate units) _____ .....	
Electric Under 20 kws _____ Over 20 kws _____ .....	
APPLIANCES: (number of) Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of) Branch Panels <u>1</u> .....	<u>1.00</u>
Transformers _____ .....	
Air Conditioners Central Unit _____ .....	
Separate Units (windows) _____ .....	
Signs 20 sq. ft. and under _____ .....	
Over 20 sq. ft. _____ .....	
Swimming Pools Above Ground _____ .....	
In Ground _____ .....	
Fire/Burglar Alarms Residential _____ .....	
Commercial _____ .....	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ .....	
over 30 amps _____ .....	
Circus, Fairs, etc. _____ .....	
Alterations to wires _____ .....	
Repairs after fire _____ .....	
Emergency Lights, battery _____ .....	
Emergency Generators _____ .....	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) ..... .....	
TOTAL AMOUNT DUE: _____	<u>9.00</u>

INSPECTION:  
 Will be ready on \_\_\_\_\_, 19\_\_; or Will Call \_\_\_\_\_  
 CONTRACTOR'S NAME: Mancini Elec  
 ADDRESS: 179 Sheridan St.  
 TEL.: \_\_\_\_\_  
 MASTER LICENSE NO.: on file SIGNATURE OF CONTRACTOR: \_\_\_\_\_  
 LIMITED LICENSE NO.: \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN



