

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

April 14, 1993

Rocco & Janet Corsetti
Highland Cliff Rd
Windham, ME 04062

Re: 268 Woodford St
CBL: 123-F-022
DU:


Dear Mr. & Mrs. Corsetti,


We recently received a complaint and an inspection was made at the above referred address. As a result of the inspection, you are hereby notified to correct the following substandard housing conditions:

	2nd Floor/Rear Unit	
1. Illegal "zip" wire		113
2. Hanging/loose electrical wire		113
3. Inoperative heater		114-2
4. Secure gas heater to floor		114-2
5. Discontinue flexible gas tubing		114-2

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected within 30 days. Failure to comply with this order may result in a complaint being filed for prosecution in District court.

Sincerely,


Arthur Rowe
Code Enforcement officer


P. Samuel Hoffses
Chief of Inspection Services