

105-107 REVERE STREET



Fifth cut • 920R - Half cut • 9202R - Third cut • 9203R - Fifth cut • 9205R

**CITY OF PORTLAND, MAINE**  
**Application for Permit to Install Wires 55581**

Permit No. 2408  
 Issued Dec. 16, 1941  
 Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address THOMAS MARTIAN 105 Beech  
 Contractor's Name and Address Ralph Eger 105 Woodlands Tel. 774 2125

Location  
 Use of Building  
 Number of Families 1 Apartments  
 Stores  
 Number of Stories 1  
 Description of Wiring: New Work  
 Additions  
 Alterations

Pipe  Cable  Metal Molding  
 BX Cable  
 Plug Molding (No. of feet) .....

No. Light Outlets  
 Plugs  
 Light Circuits  
 Plug Circuits

FIXTURES: No. ....  
 Floor. or Strip Lighting (No. feet) .....

SERVICE: Pipe  Cable  Underground  
 No. of Wires  
 Size 2-2-1

METERS: Relocated  Added   
 Total No. Meters .....

MOTORS: Number Phase H. P. Amps Volts Starter .....

HEATING UNITS: Domestic (Oil) No. Motors Phase H.P. ....  
 Commercial (Oil) No. Motors Phase H.P. ....

Electric Heat (No. of Rooms) .....

APPLIANCES: No. Ranges Watts .. Brand Feeds (Size and No.) .....

Elec. Heaters Watts ..

Miscellaneous Watts .. Extra Cabinets or Panels .....

Transformers .. Air Conditioners (No. Units) Signs (No. Units) .....

Will commence 19 20 Ready to cover in 19 .. Inspection .. 19 .....

Amount of Fee \$ 2.00

Signed Ralph Eger

DO NOT WRITE BELOW THIS LINE

SERVICE  METER .. GROUND   
 VISITS: 1 .. 2 .. 3 .. 4 .. 5 .. 6 ..  
 .. 7 .. 8 .. 9 .. 10 .. 11 .. 12 ..

REMARKS:

INSPECTED BY J. W. Hester (OVER)

LOCATION *Revere ST 105*  
 INSPECTION DATE *12/21/71*  
 WORK COMPLETED *12/21/71*  
 TOTAL NO. INSPECTIONS *1*

REMARKS:

FEE S FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING

1 to 30 Outlets \$ 2.00  
 31 to 60 Outlets 3.00  
 Over 60 Outlets, each Outlet .05  
 (Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).

SERVICES

Single Phase 2.00  
 Three Phase 4.00

MOTORS

Not exceeding 50 H.P. 3.00  
 Over 50 H.P. 4.00

HEATING UNITS

Domestic (Oil) 2.00  
 Commercial (Oil) 4.00  
 Electric Heat (Each Room) .75

APPLIANCES

Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and all permanent built-in appliance — each unit 1.50

MISCELLANEOUS

Temporary Service, Single Phase 1.00

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for One Family Dwelling house  
at 107 Revere Street

Date 3/2/22

1. In whose name is the title of the property now recorded? *Ellsworth W. Salie*
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? *Measuring from street lot*
3. Is the outline of the proposed work now staked out upon the ground? *No*. If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? *Yes*
4. What is to be maximum projection or overhang of eaves or drip? House 18" Garage 2"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? *Yes*
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? *Yes*
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? *Yes*

*E. W. Salie*



GENERAL BUILDING PERMIT

Permit No. U. 117

### APPLICATION FOR PERMIT

JUN 7 1935

Class of Building or Type of Structure Third Class

Portland, Maine, March 5, 1935

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 107 Maynard Street Ward B Within Fire Limits? no Dist. No. \_\_\_\_\_

Owner's or Lessee's name and address Ellsworth H. Salie 52 Froble St. Telephone \_\_\_\_\_

Contractor's name and address E. F. Gunn 97 Pitt St. Telephone F 7289

Architect's name and address \_\_\_\_\_

Proposed use of building 1-car garage No. families \_\_\_\_\_

Other buildings on same lot One family dwelling house proposed

Plans filed as part of this application? yes No. of sheets 1

Estimated cost \$ 700 Fee \$ .75

#### Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Last use \_\_\_\_\_ No. families \_\_\_\_\_

#### General Description of New Work

To erect cedar frame garage 12' x 10'

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

#### Details of New Work

Size, front 12' depth 10' No. stories 1 Height average grade to top of plate 8'

Height average grade to highest point of roof 15'

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation concrete slab or cedar posts Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of Roof pitch Rise per foot 8" Roof covering asphalt shingles Class C Und Leb

No. of chimneys no Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_

Kind of heat no Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_

Corner posts 4x4 Sills 4x6 or 4x8 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_

Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joints and rafters: 1st floor concrete or wood 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x4

On centers: 1st floor 18", 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 24"

Maximum span: 1st floor 12', 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

#### If a Garage

No. cars now accommodated on same lot none, to be accommodated 1

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

#### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

by Ellsworth H. Salie

Signature of owner \_\_\_\_\_

INSPECTION COPY Oliver T. Sanborn

\_\_\_\_\_

Ward 8 Permit No. 32/779

Location 107 Revere St.

Owner Ellsworth M. Salie

Date of permit 6/7/32.

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 6/13/32


Cert. of Occupancy issued

NOTES

3/8/32 - Garage not  
staked out - A.J.L.

6/7/32 - Excavation OK

6/13/32 - Work almost  
completed A.J.L.



917



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Sept. 8, 1952

PERMIT ISSUED 01450 SEP-9 1952 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 105 Revere Street Use of Building Dwelling No. Stories New Building Existing Name and address of owner of appliance Mildred S. Smith, 105 Revere St. Installer's name and address A. E. Moody, 479 Auburn Street Telephone 2-0072

General Description of Work

To install oil burner in existing steam heat (replacement)

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Kind of fuel? Minimum distance to burnable material, from top of appliance or casing top of furnace From top of smoke pipe From front of appliance From sides or back of appliance Size of chimney flue Other connections to same flue If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Petro Labelled by underwriter's laboratories? yes Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Type of floor beneath burner concrete Location of oil storage basement Number and capacity of tanks existing If two 275-gallon tanks, will three-way valve be provided? Will all tanks be more than five feet from any flame? yes How many tanks fire proofed? Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Kind of fuel? Minimum distance to wood or combustible material from top of appliance From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Blank lines for miscellaneous information

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: OK 9-9-52 [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

[Signature]

Signature of Installer

INSPECTION COPY

- 1 Fill Pipe.....
- 2 Vent Pipe.....
- 3 Kind of Heat.....
- 4 Burner Rigidity & Supports.....
- 5 Name & Label.....
- 6 Stack Control.....
- 7 High-Limit Control.....
- 8 Remote Control.....
- 9 Piping Support & Protection.....
- 10 Valves in Supply Line.....
- 11 Capacity of Tanks.....
- 12 Tank Rigidity & Supports.....
- 13 Tank Distance.....
- 14 Oil Gauge.....
- 15 Instruction Card.....
- 16.....

NOTES

9-19-52  
Permit No. 521450  
Location 105 Geneva St.  
Owner: McLeod & Smith  
Date of permit 9/9/52  
Approved [Signature]

[Empty space for notes]	[Empty space for notes]
-------------------------	-------------------------





(RC) GENERAL RESIDENCE ZONE - C PERMIT ISSUED  
APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class Permit No. 0050  
JAN 11 1943  
Portland, Maine, January 11, 1943

105-197

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 105 Revere Street Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's or Lessee's name and address Ellsworth Salie, 105 Revere Street Telephone \_\_\_\_\_  
Contractor's name and address F. F. Ginn, 97 Pitt Street Telephone 2-0301  
Architect \_\_\_\_\_ Plans filed no No. of sheets \_\_\_\_\_  
Proposed use of building Dwelling No. families 1  
Other buildings on same lot \_\_\_\_\_  
Estimated cost \$ 20. Fee \$ .25

Description of Present Building to be Altered

Material frame No. stories 1 1/2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use Dwelling No. families 1

General Description of New Work

To cut in new door between bedroom and kitchen, first floor.

VERIFICATION BEFORE LATEN-  
OR CLOSING IN IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. OK-agg 3-11/1/43

Details of New Work

CERTIFICATE OF OCCUPANCY  
EQUIPMENT IS WAIVED

Is any plumbing work involved in this work? no  
Is any electrical work involved in this work? no Height average grade to top of plate \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls; thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot \_\_\_\_\_ to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes  
Signature of owner By: Ellsworth Salie

INSPECTION COPY

Signature of owner By: Jesse Hamlin

27-22

Permit No. 43/57  
Location 105 Rensselaer St.  
Owner Claworth, Julie  
Date of permit 1/12/43  
Notif. closing-in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. \_\_\_\_\_  
Cert. of Occupancy issued None

NOTES

~~FOR PERMIT~~

City of New York  
Department of Building

District of New York  
No. \_\_\_\_\_

No.	Name	Address	City	State	Occupation	Occupancy	Remarks
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

0989

Permit No. Jul 18 1932

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 17, 1932

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 107 Revere Street Use of Building Dwelling House  
Name and address of owner Milworth M. Sallie 30 Preble St. Ward 6  
Contractor's name and address A. E. Moody 471 Auburn St. Telephone P 1156

General Description of Work

To install Steam heating system including Oil Burner

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel \_\_\_\_\_  
Material of supports of heater or equipment (concrete floor or what kind) Concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, over 15"  
from top of smoke pipe over 15", from front of heater over 4' from sides or back of heater over 3'

IF OIL BURNER

Name and type of burner Branford Model A Labeled and approved by Underwriters' Laboratories? Yes  
Will operator be always in attendance? no Type of oil feed (gravity or pressure) Pressure  
In the basement Location oil storage \_\_\_\_\_ No. and capacity of tanks 1-275 gallon  
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? None

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor A. E. Moody 7/18/32

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED


P.C. and  
7/13/32

Ward 8 Permit No. 32/989  
 Location 107 Rennie St.  
 Owner Edsworth Salie  
 Date of permit 7/13/32.  
 Notif. closing in \_\_\_\_\_  
 Inspn. closing-in \_\_\_\_\_  
 Final Notif. \_\_\_\_\_  
 Final Inspn. 7/29/32. O.T.  
 Cert. of Occupancy issued None

7/20/32 - Water set up but  
 ordinance not yet in-  
 stalled & job

- By 37/20 W. NGPES
1. Kind of boiler Steam
  2. Label \_\_\_\_\_
  3. Anti-siphon \_\_\_\_\_
  4. Oil storage \_\_\_\_\_
  5. Tack distaste \_\_\_\_\_
  6. Vent pipe \_\_\_\_\_
  7. Fill pipe \_\_\_\_\_
  8. Gauge \_\_\_\_\_
  9. Rigidity \_\_\_\_\_
  10. Feed safety \_\_\_\_\_
  11. Pipe sizes & material \_\_\_\_\_
  12. Control valve \_\_\_\_\_
  13. Ash pit vent \_\_\_\_\_
  14. Temp. or pressure safety \_\_\_\_\_
  15. Instruction card \_\_\_\_\_
  16. \_\_\_\_\_

INSPECTOR OF BOILER PLANTS  
 A. W. [unclear]





(2) GENERAL PERFORMANCE ZONE

Permit No. 0209

# APPLICATION FOR PERMIT

MAK 3 1932

Class of Building or Type of Structure Third Class

Portland, Maine, March 3, 1932

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 107 Revere Street Ward 8 Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's or Lessee's name and address Ellsworth M. Salie, 30 Preble St. Telephone \_\_\_\_\_  
 Contractor's name and address E. F. Ginn, 97 Pitt St. Telephone F 7289  
 Architect's name and address \_\_\_\_\_  
 Proposed use of building dwelling house No. families 1  
 Other buildings on same lot 1 car garage  
 Plans filed as part of this application? yes see garage No. of sheets \_\_\_\_\_  
 Estimated cost \$ 4500. Gas .25 Fee \$ 1.25 **\$1.50**

### Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_

### General Description of New Work

To erect one family frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

### Details of New Work

Height average grade to top of plate \_\_\_\_\_  
 Size, front 26' depth 55' No. stories 1 Height average grade to highest point of roof 22'  
 To be erected on solid or solid earth or rock? earth  
 Material of foundation concrete Thickness, top 10" bottom 12"  
 Material of underpinning brick Height 2'6" Thickness 8"  
 Kind of Roof pitch Rise per foot 8" Roof covering asphalt roofing Class C Und. Lab.  
 No. of chimneys 2 (1 outside) Material of chimneys brick of lining flue  
 Kind of heat steam Type of fuel coal Is gas fitting involved? yes  
 Corner posts 4x6 Sills 4x8 Girt or ledger board? ledger board Size 1x6 not more than 1" below top of plate  
 Material columns under girders iron columns Size 4" Max. on centers 8'  
 Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
 Joists and rafters: 1st floor 2x8, 2nd 2x6 unfr, 3rd \_\_\_\_\_, roof 2x6  
 On centers: 1st floor 16", 2nd 16", 3rd \_\_\_\_\_, roof 24"  
 Maximum span: 1st floor 13', 2nd 13', 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
 Total number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Ellsworth M. Salie  
E. F. Ginn  
 By \_\_\_\_\_

INSPECTION COPY

h 950 A

Ward 8 Permit No. 32/209  
 Location 107 Revere St.  
 Owner Ellsworth M. Salie  
 Date of permit 3/8/32  
 Notif. closing-in 5/27/32 - 7.15 AM  
 Inspn. closing-in 5/27/32 - P.T.  
 Final Inspector Requirement sent 5/27/32  
 Final Notif. 7/20/32 - OK except for gas  
 Final Inspn. 7/20/32 - 9.20 AM  
 Cert. of Occupancy issued 7/30/32.

NOTES

~~3/8/32 - Location as shown on red O.K. House on lot adjoining has frontage only 13' from street line. Lot on other side is vacant. A.J.S.  
 3/14/32 - Creating frame. A.J.S.  
 3/21/32 - Pouring foundation walls. A.J.S.  
 3/28/32 - Foundation walls poured. A.J.S.  
 4/4/32 - No change. A.J.S.  
 4/12/32 - Same. A.J.S.  
 4/21/32 - Insulating on side. A.J.S.  
 4/28/32 - First story framed. A.J.S.~~

5/4/32 - Not much change. A.J.S.  
 5/11/32 - Roof framed. A.J.S.  
 5/18/32 - Working outside. A.J.S.  
 5/27/32 - snow proof opening. A.J.S.  
 cellar for boiler. Fire stop at attic. Fire stop needed. Fire stop needed around coal pipe or sink at first floor. Q.I. to be in issued. 7/20/32 - Not yet fully ready for final inspection. No gas tag. Hole in first floor under bath to be made tight. Fire stop at plate in attic needed. A.J.S.  
 7/25/32 - O.K. except for gas tag. A.J.S.  
 8/29/32 - Gas connected up but no tag left. A.J.S.