

21 Arlington Street



CITY OF PORTLAND - HEALTH DEPARTMENT
LEAD POISONING and LEAD BASE PAINT DETECTION PROGRAM

Address: 21 Arlington St
 D.U. Location: First Floor
 Occupant: MRS. J. Giargetti
 Children: 2 Ages: 19 mo, 7 days
 Referred By: Nursing
 Building Type: Wood Building Condition: Fair
 Date: 2/20/93
 Owner: MR. Gilbert Faulkner
 Owner's Address: 21 Arlington St
Port. Me 04101
 Project Area:
 Patient's Name: Jeanne
 No. D.U.: 2

DIGITAL ANALYZER (LEAD DETECTOR) READINGS Mg/cm²

INTERIOR ROOMS:	Kitchen	Bath	Living	Dining	Baby's		Other
					Bd#1	Bd#2	
W. Sills	NEG	NEG	25.1		20.5	5.4	
Doors	NEG	NEG	NEG		19.5	6.5	
Walls	NEG	NEG	NEG		6.2	NEG	
M. Board	NEG	NEG	19.9		25.5	5.9	
Cabinets	NEG	NEG	NEG			NEG	
Furniture	-	-	-				
Other							

COMMON AREAS:	Hall	Stair	F. Porch	R. Porch	Entry		Other	
					Other	Other	Other	Other
Steps	NEG		NEG	NEG				
Rails	NEG		NEG	NEG				
Doors	NEG		NEG	NEG				
Walls	NEG		NEG	NEG				
Other								

THE AREAS ABOVE CONTAIN A HIGH CONCENTRATION OF LEAD BASED PAINT (OVER 2.0 mg/cm²). THESE AREAS MUST BE DETOXIFIED.

Comments:

Housing Inspector: D.V. Swasey

Health Dept. - Housing Division - 775-5451
Ext. 448

PORTLAND HEALTH DEPARTMENT - NURSING DIVISION - HOUSING INSPECTIONS DIVISION - LABORATORY

Anne Giorgetti Date 1/9/73

21 Arlington St 1st Floor.

to: Welfare Housing Sanitation Nursing

Telephone
Ref. by: Nursing Orally By: _____

Re: Lead Program

Please test home. Child has elevated 772.9508
blood lead.

Portland Health Department Referral (Please report on reverse)
11-72 SW