

71-75 CODMAN STREET

SHAW-WALKER

1st cut # 920R - 2nd cut # 920R - 3rd cut # 920R - 4th cut # 920R



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 8, 1978
 Receipt and Permit number A 10667

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine,
 the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 73 Codman St.
 OWNER'S NAME: Downe Nelson ADDR: same

OUTLETS: (number of) 1-30
 Lights _____
 Receptacles _____
 Switches _____
 Plugmold _____ (number of feet) _____ FEES
 TOTAL _____

FIXTURES: (number of) _____
 Incandescent _____
 Fluorescent _____ (Do not include strip fluorescent)
 TOTAL _____
 Strip Fluorescent, in feet _____

SERVICES:
 Permanent, total amperes _____
 Temporary _____

METERS: (number of) _____

MOTORS (number of)
 Fractional _____
 1 HP or over _____

RESIDENTIAL HEATING:
 Oil or Gas (number of units) _____
 Electric (number of rooms) 1 _____ FEES
 TOTAL _____

COMMERCIAL OR INDUSTRIAL HEATING:
 Oil or Gas (by a main boiler) _____
 Oil or Gas (by separate units) _____
 Electric (total number of kws) _____

APPLIANCES: (number of)
 Ranges _____
 Cook Tops _____
 Wall Ovens _____
 Dryers _____
 Fans _____
 Water Heaters _____
 Disposals _____
 Dishwashers _____
 Compactors _____
 Others (denote) _____
 TOTAL _____

MISCELLANEOUS. (number of)
 Branch Panels _____
 Transformers _____
 Air Conditioners _____
 Signs _____
 Fire/Burglar Alarms _____
 Circus, Fairs, etc. _____
 Alterations to wires _____
 Repairs after fire _____
 Heavy Duty, 220v outlets _____
 Emergency Lights, battery _____
 Emergency Generators _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE:
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE:
 FOR PERFORMING WORK WITHOUT A PERMIT (304-9)
 TOTAL AMOUNT DUE: 4.00

INSPECTION:
 Will be ready on ready, 19 78; or Will Call _____
 CONTRACTOR'S NAME: Hannan's Electric
 ADDRESS: 51 Lawn Ave. So Portland
 TEL.: 767-2471

MASTER LICENSE NO.: 2885
 LIMITED LICENSE NO.: _____
 SIGNATURE OF CONTRACTOR: Larry Hannan
 INSPECTOR'S COPY



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION PORTLAND, MAINE,

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION Fire District #1 #2

1. Owner's name and address Telephone

2. Lessee's name and address Telephone

3. Contractor's name and address W.A. ADAMS # 22 SANDY ST. Telephone 774-5326

4. Architect Specifications Plans No. of sheets

Proposed use of building No. families

Last use No. families

Material WOOD. No. stories 1. Heat Electric. Style of roof Shed. Roofing Asphalt

Other buildings on same lot

Estimated contractual cost \$ Fees \$

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451

Dwelling Ext. 234

Garage

Masonry Bldg.

Metal Bldg.

Alterations 1070

Demolitions

Change of Use

Other

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 2 3 4

Other:

DETAILS OF NEW WORK SEE OTHER SIDE

Is any plumbing involved in this work? NO Is any electrical work involved in this work? YES

Is connection to be made to public sewer? NO If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof 12'

Size, front 14' depth 9'6" No. stories 1 solid or filled land? Shed earth or ~~stone~~

Material of foundation CONCRETE Thickness, top 10" bottom cellar

Kind of roof Shed Rise per foot 3" Roof covering Shingles

No. of chimneys 2 Material of chimneys of lining Kind of heat Electric fuel

Framing Lumber—Kind SPRUC Dressed or full size? Dimensional Corner posts 2x4 Sills 2x6

Size Girder NONE Columns under girders NONE Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2x10 2nd 11" 3rd roof 2x6

On centers: 1st floor 16" 2nd 11" 3rd roof 16"

Maximum span: 1st floor 9' 2nd 3rd roof 11'

If one story building with masonry walls, thickness of walls? height?

Solid Building A GARAGE

No. cars now accommodated on same lot, to be accommodated ... number commercial cars to be accommodated ...

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING:

BUILDING CODE:

Fire Dept.:

Health Dept.:

Other:

MISCELLANEOUS

Will work require disturbing of any tree on a public street? NO

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Signature of Applicant Phone #

Type Name of above 1 2 3 4

Other

and Address

OFFICE FILE COPY

Deck

10 x 10 located adjacent to
house & new construction

2 x 8 joists 16" oc.

2 x 6 floor boards

foil on two outside dimensions

RECEIVED

MAY - 1 1978

DEPT. OF BLDG. INSP.
CITY OF PORTLAND



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP
 B.O.C.A. TYPE OF CONSTRUCTION 0314
 ZONING LOCATION PORTLAND, MAINE, ...5-1-73.....

PERMIT ISSUED
 MAY 1 1978
 CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION . 73. Codman Street.....
 1. Owner's name and address . Downing. R. Nelson-same..... Fire District #1 , #2
 2. Lessee's name and address Telephone . 772-9594
 3. Contractor's name and address . W. Allen Adams III-42. Savoy. St. Port. Telephone . 774-5326
 4. Architect Specifications Plans No. of sheets
 Proposed use of building . single fam. dwell..... No. families
 Last use same..... No. families
 Material No. stories Heat Style of roof Roofing
 Other buildings on same lot
 Estimated contractual cost \$. 4,000..... Fee \$. 16.00.....

FIELD INSPECTOR—Mr. Hugh

This application is for:

- Dwelling
- Garage
- Masonry Bldg.
- Metal Bldg.
- Alterations
- Demolitions
- Change of Use
- Other

@ 775-5451
 Ext. 234

GENERAL DESCRIPTION

To construct 10 x 14 room, and 10 x 10 sundeck.

8" FOUNDATION FOR PORCH

Stamp of Special Conditions
 1 9" SONOTUBE OUTER EDGE OF DECK, 4x8 SICK (all on pie) NOT BUILDING, 2x8s nailed over railing strips or slats.

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals

PERMIT IS TO BE ISSUED TO 1 2 3 4
 Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? ... no
 Is connection to be made to public sewer? ... no
 Has septic tank notice been sent?
 Height average grade to top of plate
 Size, front ... 14 ... depth ... 9ft. No. stories ... 1 ... solid or filled land? solid ... earth or rock?
 Material of foundation concrete
 Kind of roof . shed . Rise per foot ... 3 ft. Thickness, top ... 19. bottom ... cellar ...
 No. of chimneys . no . Material of chimneys . a' lining . Roof covering ... asphalt shingles
 Framing Lumber—Kind Dressed or full size? Kind of heat fuel
 Size Girder ... none Columns under girders none Corner posts Sills
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor ... 2 x 10 2nd 3rd roof ... 2 x 6
 On centers: 1st floor ... 16 2nd 3rd roof 16
 Maximum span: 1st floor ... 9 2nd 3rd roof 11
 If one story building with masonry walls, thickness of walls? .. solid bridging... .. height? ..
 IF A GARAGE no masonry walls.

No. cars now accommodated on same lot, to be accommodated ... number commercial cars to be accommodated ...
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:
 BUILDING INSPECTION—PLAN EXAMINER DATE
 ZONING: R.H.S. ... E.B. ... 5/1/78
 BUILDING CODE: R.H.S. ... E.B. ... 5/1/78
 Fire Dept.:
 Health Dept.:
 Owner:

MISCELLANEOUS
 Will work require disturbing of any tree on a public street? ..
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? .. yes..

Signature of Applicant *Downing R. Nelson* Phone # ... same
 Type Name of above Downing, R. Nelson

FIELD INSPECTOR'S COPY

1 2 3 4
 Other
 and Address

PERMIT TO INSTALL PLUMBING *Fairday*
 PERMIT NUMBER 128

Date Issued **June 17, 1969**
 Portland Plumbing Inspector
 By **ERNOLD R. GOODWIN**

Address **73 Codman Street**
 Installation For **Dwelling**
 Owner of Bldg **Waleson**
 Owner's Address **73 Codman Street**
 Plumber **A. H. Cousins** Date **June 17, 1969**

App. First Insp.
 Date **6/20/69**
 By **WALTER M. WALLACE**
 App. Final Insp.

Date **6/20/69**
 By **WALTER M. WALLACE**
 Commercial
 Residential
 Single
 Multi Family
 New Construction
 Remodeling

NEW	REPL.		NO.	FEE
1		SINKS	1	2.00
		LAVATORY SIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
1		GARBAGE DISPOSALS	1	2.00
		SEPTIC TANKS		
		HOUSE DRAINERS		
		ROOF LEADERS		
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER		
			TOTAL	4.00

Building and Inspection Services Dept. Plumbing Inspection

PERMIT TO INSTALL PLUMBING

PERMIT NUMBER **9346** Address: **73 Codann Street**

Issued **10-3-60** Installation For: **Walter Lunban**

By **J. P. Welch** Owner of Bldg.: **Walter Lunban**

Plumber: **M. William Cohen** Date: **10-3-60**

APPROVED FIRST INSPECTION

Date **10-14-60**

By **J.P. Welch**

APPROVED FINAL INSPECTION

Date **10-14-60**

By **JOSEPH P. WELCH**

TYPE OF BUILDING

COMMERCIAL

RESIDENTIAL

SINGLE

MULTI FAMILY

NEW CONSTRUCTION

REMODELING

NEW	REP'L	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
1		HOT WATER TANKS	3	\$2.00
		TANKLESS WATER HEATERS		
		GARBAGE GRINDERS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		FOOF LEADERS (conn. to house drain)		
			1	\$2.00
			Total	

SM 12-53 PORTLAND HEALTH DEPT. PLUMBING INSPECTION

PERMIT TO INSTALL PLUMBING

PERMIT NUMBER **821**

Date Issued **10-30-72**
 Portland Plumbing Inspector
 By **ERNOLD R GOODWIN**

App. First Insp.
 Date
 By

App. Final Insp.
 Date **11-21-72**
 By

- Type of Bldg.
- Commercial
 - Residential
 - Single
 - Multi Family
 - New Construction
 - Remodeling

Address 75 Codman St.		Date 10-30-72	
Installation For Single		NO	FEE
Owner of Bldg Mrs. Spurgeon Sullivan			
Owner's Address Same			
Plumber Paul Brennan			
NEW	REPL		
	178 Dartmouth St.		
	SINKS		
	LAVATORIES		
	TOILETS		
	BATH TUBS		
	SHOWERS		
	DRAINS	FLOOR SUR. 'ACE	2.00
1	HOT WATER TANKS		
	TANKLESS WATER HEATERS		
	GARBAGE DISPOSALS		
	SEPTIC TANKS		
	HOUSE SEWERS		
	ROOF LEADERS		
	AUTOMATIC WASHERS		
	DISHWASHERS		
	OTHER		
TOTAL			2.00

Building and Inspection Services Dept.: Plumbing Inspection

40/13-I
n/73

February 28, 1940

Portland Sebago Ice Co.
302 Commercial Street,
Portland, Maine

Gentlemen:

Please furnish without delay an instruction card posted permanently in place near the oil burning equipment which you have installed for Edward Phillips at 71-73 Codman Street, and thus satisfy Building Code regulations thereto.

Very truly yours,

Inspector of Buildings.

McD/W.



FILL IN COMPLETELY AND SIGN WITH INK

Permit No. 00113

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER-EQUIPMENT

Portland, Maine, January JAN 9 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooling or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 71-73 Codman Street Use of Building dwelling No. Stories 2 New Building Existing
Name and address of owner of appliance Edward Phillips
Installer's name and address Portland Sebago Ice Co., 303 Commercial St. Telephone 3-2911

General Description of Work

To install Oil Burning Equipment in connection with steam heat

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes no In not, which story Kind of Fuel Oil
Material of supports of appliance (concrete floor or what kind) concrete
Minimum distance to wood or combustible material from top of appliance or casing top of furnace,
from top of smoke pipe from front of appliance from sides or back of appliance.
Size of chimney flue Other connections to same flue

IF OIL BURNER

Name and type of burner Silent North Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? Type of oil feed (gravity or pressure) pressure
Location oil storage basement No. and capacity of tanks 1 - 275 gal.
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed?

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of Installer [Signature] Portland Sebago Ice Co.

INSPECTION COPY

62570

see 29/2144

Permit No. 40/13

Location 71-73 Cordman St.

Owner Edward Phillips

Date of Permit 1/4-1/40.

Post Card sent

Notif. for insp.

Approval Tag issued 2/27/40

Oil Burner Check List (date) 2/27/40

1. Kind of heat Steam

2. Label ✓

3. Anti-siphon ✓

4. Oil storage ✓

5. Tank distance ✓

6. Vent Pipe ✓

7. Fill Pipe ✓

8. Gauge ✓

9. Rigidity ✓

10. Feed safety ✓

11. Pipe sizes and material ✓

12. Control valve ✓

13. Ash pit vent ✓

14. Temp. or pressure safety ✓

15. Instruction card ?

16.

NOTHS



FILL IN COMPLETELY AND SIGN WITH INK

Permit No. **ISSUED**

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

NOV 23 1939

Portland, Maine, November 22, 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 71-73 67 Godman Street Use of Building dwelling and garage No. Stories 2 1/2 New Building Existing "Existing"
Name and address of owner of appliance Edward Phillips, 27 Hastings St
Installer's name and address Walter Cooper, 346 Broadway, So. Portland Telephone 3-6797

General Description of Work

To install steam heating system

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel oil
Material of supports of appliance (concrete floor or what kind) concrete
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, 2'
from top of smoke pipe 2' from front of appliance over 4' from sides or back of appliance over 4'
Size of chimney flue 8x12 Other connections to same flue none

IF OIL BURNER

Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) _____
Location oil storage _____ No. and capacity of tanks _____
Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of Installer Walter E Cooper

INSPECTION COPY

60760

See 3912144

Permit No. 39/2145

Location 7187 Codman St.

Owner Edward Phillips

Date of Permit 11/23/39

Post Card sent

Notif. for insp'n

Approval Tag issued 2/27/40

Oil Burner Check List (date)

- 1. Kind of heat
- 2. Label
- 3. Anti-siphon
- 4. Oil storage
- 5. Tank distance
- 6. Vent Pipe
- 7. Fill Pipe
- 8. Gauge
- 9. Rigidity
- 10. Feed safety
- 11. Pipe sizes and material
- 12. Control valve
- 13. Ash pit vent
- 14. Temp. or pressure safety
- 15. Instruction card
- 16.

NOTES

100

OS 2144-1

February 28, 1940

Mr. Edward Phillips
27 Hastings Street,
Portland, Maine.

Dear Sir:

This letter may be considered a temporary certificate of occupancy to cover the use of the dwelling house part only of your new home nearing completion at 71-73 Codman Street.

There are a few minor details not completed which your contractor has agreed to fix up at once.

The only important omission is the plaster protection between garage and house. Since the garage is not provided with heat, it is obvious that you do not desire to apply this plaster in freezing weather, but until the protection is completed, it is not possible for us to include in any certificate of occupancy the right to use the garage part.

As soon as the garage protection has been finished and all of these other minor matters taken care of, if you or your contractor will notify this office, we will make another inspection and issue the regular legal certificate of occupancy if everything is found in order.

Very truly yours,

Inspector of Buildings.

HCD/W

Copy for Walter E. Cooper
346 Broadway, So. Portland

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for one family dwelling house with 1-car garage attached
at - 67 Godman Street - (10t73) -

Date 11/22/39

1. In whose name is the title of the property now recorded? Edward Phillips
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Staked out
3. Is the outline of the proposed work now staked out upon the ground? yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip ^{gar} 2 _{ing} 6 ^{inch} _____
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Wm. E. Cape, Jr.



(R) GENERAL RESIDENCE
APPLICATION FOR PERMIT Permit No. 11-73
 Class of Building or Type of Structure _____

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. Portland, Maine, NOV 23 1939

The undersigned hereby applies for a permit to erect and install the following building structure, equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 11-73 67 Codman Street (lot 73) Within City Limits? no Dist. No. _____
 Owner's or Lessee's name and address Edward Phillips, 27 Hastings St. Telephone _____
 Contractor's name and address Walter E. Cooper, 346 Broadway Portland Telephone 3-6797
 Architect _____ Plans used yes No. of sheets 1
 Proposed use of building dwelling house with one car garage attached No. families 1
 Other buildings on same lot _____
 Estimated cost \$ 1500.

Description of Present Building to be Altered
 Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Last use _____ No. families _____

General Description of New Work

To erect one family frame dwelling house with one car garage attached
 The inside of the garage will be covered, where required by law, with perforated gypsum lath covered with one-half inch thickness gypsum plaster.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? yes
 Is any electrical work involved in this work? yes Height average grade to top of plate 1 1/2'
 Size, front 37'6" depth 36' No. stories 2 1/2 Height average grade to highest point of roof 30'
 To be erected on solid or filled land? solid earth or rock? earth
 Material of foundation concrete concrete trenchwall under garage 8" at top and 10" at bottom
 Thickness, top 10" bottom 12" cellar yes
 Material of underpinning brick Height 20" Thickness 8"
 Kind of Roof pitch Rise per foot 7" Roof covering Asphalt roofing Class C Ind. Lab.
 No. of chimneys 1 Outside - fireplace Material of chimneys brick of lining till
 Kind of heat steam Type of fuel oil Is gas fitting involved? no
 Framing Lumber—Kind spruce and hemlock Dressed or Full Size? dressed
 Corner posts 4x6 Sills 4x6 Girt or ledger board? 4x4 Size 2-2x4
 Material columns under girders iron columns Size 1 1/2" Max. on centers 6'
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section. or 2x6 labelled 1st floor column
 Joists and rafters: 1st floor 2x8, 2nd 2x6, 3rd 2x6 stairway - no dormer roof 2x4
 On centers: 1st floor 16", 2nd 16", 3rd 20" roof 2'
 Maximum span: 1st floor 12', 2nd 11', 3rd 12' roof _____
 If one story building with masonry walls, thickness of walls? concrete floor in garage height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 1
 Total number commercial cars to be accommodated none
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSTRUCTION COPY Walter E. Cooper Signature of owner Edward Phillips
 CHIEF OF FIRE DEPT Walter E. Cooper

607

Permit No. 39)2144
 Location: 47 Columbia St.
 Elicand Plaster
 Date of permit: 11/23/39
 Not closing-in: 1/9/40 - 1.05 PM
 Insp. closing-in: 1/9/40 - G.T.
 Final Insp. 3/8/40 - O.K.
 Cert. of Occupancy issued 3/8/40

NOTES
 1/9/40 - Insp. to view work
 1/17/40 - Insp. to view work
 1/21/40 - Insp. to view work
 1/21/40 - Foundation
 wall being finished
 No water penetration
 inspection from above
 Find that an exterior
 pipe in chimney is
 exposed on exterior
 of building although
 on location
 of chimney
 is encased 4'-6"

Large 1 1/2" diam. cold air
 vent located outside in
 chimney cannot be
 closed thanks to old
 O.A.S.
 12 1/2 lbs. - Foundation
 underpinning being
 laid down
 2/12/40 - 2nd day
 underpinning
 2/16/40 - training
 O.A.S.
 2/22/40 - 3rd day
 underpinning
 O.A.S.
 3/5/40 - same O.A.S.
 3/9/40 - finished
 floor level O.T.
 3/27/40 - 1st inspection
 charges not out -
 still in progress
 call on each side. Clean
 inside and outside
 fireplace damper. Tight
 between studs with
 cotton. Plaster garage
 O.A.S.
 2/28/40 - Mr. Cooper will
 take care of above matters.

Plastering of garage
 is done with
 framing of post holes
 supplied. Plaster
 2/29/40 - Final coat of
 plaster
 3/1/40 - Final coat of
 plaster

1/9/40 - Insp. to view work
 1/17/40 - Insp. to view work
 1/21/40 - Insp. to view work
 1/21/40 - Foundation
 wall being finished
 No water penetration
 inspection from above
 Find that an exterior
 pipe in chimney is
 exposed on exterior
 of building although
 on location
 of chimney
 is encased 4'-6"