

62 Concord Street 130-E-16

POSTED
DATE *2/1/71*
DATE RELEASED


SHAW-WALGER
#850517

CERTIFICATE
OF
COMPLIANCE

CITY OF PORTLAND
Health Department - Housing Inspections Division
Telephone: 775-5451 - Extension 448

August 7, 1975

Mr. James Kenney
79 Ninth Street
Portland, Maine

Re: Premises located at 62 Concord Street, Portland, Maine 130-E-16

Dear Mr. Kenney:

A re-inspection of the premises noted above was made on August 6, 1975
by Housing Inspector Bailey.

This is to certify that you have complied with our request to correct the violation of
the Municipal Codes relating to housing conditions as described in our "Notice of
Housing Conditions" dated 7-21-70.

Thank you for your cooperation and your efforts to help us maintain decent, safe and
sanitary housing for all Portland residents.

In order to aid in the preservation of Portland's existing
housing inventory, it shall be the policy of this department
to inspect each residential building at least once every
five years. Although a property is subject to re-inspection
at any time during the said five year period, the next regular
inspection of this property is scheduled for 1980.

Sincerely yours,
David C. Bittenbender
(Acting)
Health Director

By Lyle D. Jones
Chief of Housing Inspections

Inspector

Robert Bailey
R. Bailey

LON:rl

August 7, 1975

Mr. James Kenney
79 Ninth Street
Portland, Maine

Re: 62 Concord Street, Portland, Maine 130-E-16
Second Floor Apt.

Dear Mr. Kenney:

This is to inform you, as owner or agent of the property located at
62 Concord Street, Portland, Maine, that we have released the Second
Floor Apt. from posting.

Therefore, you may rent the apartment to others or occupy it yourself.

If any additional information is desired, visit or call this office.

Sincerely yours,
David C. Bittenbender
Acting Health Director

Lyle D. Noyes
Lyle D. Noyes
Chief of Housing Inspections

Inspector

Robert Bailey
R. Bailey

LDN:rl

August 7, 1975

Mr. James Kenney
79 Ninth Street
Portland, Maine

Re: 62 Concord Street, Portland, Maine 130-E-16
Second Floor Apt.

Dear Mr. Kenney:

This is to inform you, as owner or agent of the property located at 62 Concord Street, Portland, Maine, that we have released the Second Floor Apt. from posting.

Therefore, you may rent the apartment to others or occupy it yourself.

If any additional information is desired, visit or call this office.

Sincerely yours,
David C. Bittenbender
Acting Health Director

Lyle D. Hoyes
Lyle D. Hoyes
Chief of Housing Inspections

Inspector *Robert Bailey*
R. Bailey

LDN:rl

797 6158
Dcl

✓ 9-20-74

POSTED
DATE 9-26-72
1st FLR
DATE RELEASED 2-16-73

OK
DATE 8-6-75

September 26, 1972

Mr. James Kenney 79 NINTH ST
5 Greenway Drive
Falmouth, Maine 04105 Portland, Me.
130-E-16

Dear Mr. Kennays:

Re: 62 Concord Street
First Floor Apartment

This is to inform you, as owner of the property located at 62 Concord Street, Portland, Maine, that we have released the first floor apartment from posting.

Therefore, you may rent the apartment to others or occupy it yourself. If any additional information is desired, visit or call this office.

Sincerely yours,

Lyle D. Hoyas
Chief of Housing Inspections

Inspector [Signature]

LDH:gg

ADMINISTRATIVE HEARING DECISION

City of Portland
Health Department - Housing Division
Tel. 775-5451 Ext. 226

Date August 16, 1972

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

Re: Premises located at 62 Concord Street, Portland, Maine

Dear **Mr. Kenney:**

You are hereby notified that as a result of the discussion between Attorney Robert Cram,
Housing Inspector Bailey and yourself

on August 14, 1972, regarding our "NOTICE OF HOUSING CONDITIONS" at the
above referred premises resulted in the decision noted below.

Expiration time extended to September 16, 1972 - in order to complete the work now
in progress to correct the nineteen (19) Housing Code violations as shown on the attached
list.

Notice modified as follows: _____

Please notify this office if all violations are corrected before the above mentioned date,
so that a "CERTIFICATE OF COMPLIANCE" may be issued.

In Attendance

Attorney R. Cram

Mr. James Kenney

Inspector Bailey

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

By *Lyle D. Royce*
Chief of Housing Inspections

/cc
encl

Re: 62 Concord St.

Remaining Housing Code deficiencies to be corrected within time extension granted on attached "Administrative Hearing Decision" - -

- | | Section(s) |
|--|-----------------|
| 1. Repair or replace the loose siding on the exterior walls of the entire structure. | 3(a) |
| 2. Determine the reason and remedy the condition which causes the gutters to leak. | 3(a) |
| 3. Repair or replace the broken or missing bannister and balusters on the stairway in the front hall, first to second floor. | 3(d) |
| 4. Accomplish a general clean-up of the cellar by properly removing and disposing of all rubbish and debris. | 4(b) |
| 5. Repair or replace the loose and dangerous cellar stairs. | 4(b) |
| 6. Repair or replace the broken and missing bulkhead doors. | 3(c) |
| 7. Install adequate artificial illumination in the front hallway, first floor, properly secure electrical wires in the second floor rear hallway. | 3(c) |

Second Floor Unit

- | | |
|---|-----------------|
| 8. Repair or replace the broken plaster on the ceiling and/or walls in the kitchen, bathroom and living room. | 3(b) |
| 9. Repair or replace the loose and worn floor boards in the kitchen and bathroom. | 3(b) |
| 10. Repair or replace the broken window panes in the living room. | 3(c) |
| 11. Determine the reason and remedy the condition which causes signs of leakage on the ceiling in the front bedroom, near the dormer window. | 3(b) |
| 12. Repair or replace the loose and missing plaster on the walls and ceiling of the third floor hallway. | 3(b) |
| 13. Repair or replace the missing plaster on the wall of the third floor right bedroom. | 3(b) |
| 14. Repair or replace the missing window and sash in the right bedroom of the third floor. | 3(c) |

The following violations, in addition to those listed above, were found on reinspection and are to be corrected within time extension as shown on the attached "Administrative Hearing Decision" -

- | | |
|---|-----------------|
| 15. Repair or replace the loose and missing stones and bricks at the front of structure. | 3(a) |
| 16. Repair or replace the loose railing of the front porch. | 3(d) |
| 17. Repair or replace the loose and broken tread of the front porch stairs. | 3(d) |
| 18. Remove the water from the cellar floor. | 3(a) |
| 19. Repair or replace the loose bricks of bulkhead entrance (foundation). | 3(a) |

I hereby certify that a copy of the attached notice(s) regarding the premises located at

62 Concord St Portland, Maine was personally delivered by me

at 1:55 on Aug 4 19 72 into the hands of Mrs James Henney

who identified herself as wife of the owner Mr James Henney at

5 Greenway Drive, Maine.

Anthony J. Olivo Housing Inspector
City of Portland Health Department - Housing Division

August 4, 1972

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine

Re: 62 Concord Street

Dear Mr. Kenney;


As owner or agent of the above referred property located at 62 Concord Street, Portland, Maine, you are hereby notified that as the result of a recent inspection the entire structure is hereby declared unfit for human occupancy.

You must take steps to vacate the First Floor Apartment occupied by Miss Judith Feaney and Mrs. Candy Wright immediately and along with the entire structure it is to be kept vacant so long as the following conditions continued to exist thereon:

- a. The property is damaged, decayed, deteriorated, unsanitary and unsafe (or vermin-infested) in such a manner as to create a serious hazard to the health, safety, and general welfare of the occupants or the public.

Therefore, you will not occupy, permit anyone to occupy or rent the above mentioned without the written consent of the Health Officer or his agent, certifying that the conditions have been corrected.

Sincerely,



Lyle D. Hayes
Chief of Housing Inspections

LDN:gh

Inspector Anthony J. Olivier

August 4, 1972

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine

Re: 62 Concord Street

Dear Mr. Kenney:

As owner or agent of the above referred property located at 62 Concord Street, Portland, Maine, you are hereby notified that as the result of a recent inspection the entire structure is hereby declared unfit for human occupancy.

You must take steps to vacate the First Floor Apartment occupied by Miss Judith Feeney and Mrs. Candy Wright immediately and along with the entire structure it is to be kept vacant so long as the following conditions continued to exist thereon:

- a. The property is damaged, decayed, deteriorated, unsanitary and unsafe (or vermin-infested) in such a manner as to create a serious hazard to the health, safety, and general welfare of the occupants or the public.

Therefore, you will not occupy, permit anyone to occupy or rent the above mentioned without the written consent of the Health Officer or his agent, certifying that the conditions have been corrected.

Sincerely,


Lydia D. Noyes
Chief of Housing Inspections

LDN:gh

Inspector 

August 4, 1972

Miss Judith Feeney & Mrs. Candy Wright
2 Concord Street
Portland, Maine


Re: First Floor Apartment

Dear Miss Feeney & Mrs. Wright:

A recent inspection by Housing Inspector Oliver of the First Floor Apartment you are now occupying found that it does not meet the requirements of Chapter 307 (Minimum Standards for Housing) of the City of Portland Municipal Code and is hereby declared unfit for human habitation.

The owner, James Kenney, has been notified of the above mentioned conditions and has been directed to take immediate steps to vacate the apartment.

Sincerely,


Lyle D. Hoyer
Chief of Housing Inspections

LON:gh

Inspector Anthony J. Oliver

I hereby certify that a copy of the attached notice(s) regarding the premises located at

62 Concord St Portland, Maine was personally delivered by me

at 3:35 PM on Aug 6 19 72 into the hands of Mrs Wright

who identified herself as tenant of the owner 1st floor unit a.

62 Concord St, Maine.

A. J. Oliver Housing Inspector
City of Portland Health Department - Housing Division

Miss Feeney
Miss Threget
and
Mrs. Henry the landlady
was present at time
notice was delivered

August 4, 1972

Miss Judith Feeney & Mrs. Candy Wright
62 Concord Street
Portland, Maine

Re: First Floor Apartment

Dear Miss Feeney & Mrs. Wright:

A recent inspection by Housing Inspector Oliver of the First Floor Apartment you are now occupying found that it does not meet the requirements of Chapter 307 (Minimum Standards for Housing) of the City of Portland Municipal Code and is hereby declared unfit for human habitation.


The owner, James Kennay, has been notified of the above mentioned conditions and has been directed to take immediate steps to vacate the apartment.

Sincerely,


Lyle D. Noyes
Chief of Housing Inspections

LDN:gh

Inspector



June 12, 1972

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

Re: 62 Concord Street

Dear Mr. Kenney:


As owner of the above referred property, you were notified on July 21, 1970, by hand delivered letter to Mrs. James Kenney wife of the owner Mr. James Kenney, by Housing Inspector Bailey to correct certain substandard conditions in violation of Chapter 307 of the City of Portland Municipal Codes find that you have not complied with our request.

A final reinspection was made on May 22, 1972, by Housing Inspector Bailey and, as a result, you are hereby ordered to correct the violations listed below on or before July 12, 1972.


Sincerely,

Arthur A. Hugheson, CPE MPH
Health Director

Inspector



By


Chief of Housing Inspections

EXISTING VIOLATIONS OF CHAPTER 307 OF THE CITY OF PORTLAND MUNICIPAL CODE -

SECTION(S)

- | | |
|---|-------|
| 1. Repair or replace the loose siding on the exterior walls of the entire structure. | 3(a) |
| 2. Determine the reason and remedy the condition which causes the gutters to leak. | 3(a) |
| 3. Repair or replace the broken or missing handrail and baluster on the stairway in the front hall, first to second floor. | 3(d) |
| 4. Accomplish a general clean up of the cellar by properly removing and disposing of all rubbish and debris. | |
| 5. Repair or replace the loose and dangerous cellar stairs. | 4B 31 |
| 6. Repair or replace the broken and missing bulkhead doors. | 31 |
| 7. Install adequate artificial illumination in the front hallway, first floor, properly secure electrical wires in the second floor rear hallway. | 8 |
| <u>Second Floor Unit</u> <i>Parish - 5-8-72</i> | |
| 8. Repair or replace the broken plaster on the ceiling and/or walls in the kitchen bathroom and living room. | |
| 9. Repair or replace the loose and worn floor boards in the kitchen and bathroom. | |
| 110. Repair or replace the broken window panes in the living room. | |

continued

62 Concord - continued

Second Floor Unit - continued

11. Determine the reason and remedy the condition which causes signs of leakage on the ceiling in the front bedroom, near the dormer window. 3(b)
12. Repair or replace the loose and missing plaster on the walls and ceiling of the third floor hallway. 3(b)
13. Repair or replace the missing plaster on the wall of the third floor right bedroom. 3(b)
14. Repair or replace the missing window and sash in the right bedroom of the third floor. 3(c)

- added violations*
15. R.R. the loose & missing stone & bricks front of structure 3(a)
 16. R.R. the loose railing of the front porch. 3(b)
 17. R.R. the loose & broken treads of the front porch stairs 3(d)
 18. *Remove the water from the cellar floor.* 3(a)
 19. R.R. the loose bricks of the bulkhead entrance (foundation) 3(a)

posting Notice sent out 8/4/72 for 1st floor entire unit posted.
Hank Coleman

11

Rec-124

May 3, 1972

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

Dear Mr. Kenney:

Re: 62 Concord Street
Second Floor Unit


As owner of the property located at 62 Concord Street, Portland, Maine, you are hereby notified that as the result of a recent inspection the vacant second floor apartment is hereby declared unfit for human occupancy.

The above mentioned apartment is to be kept vacant so long as the following conditions continue to exist thereon:

- a. The property is damaged, decayed, deteriorated, unsanitary and unsafe in such a manner as to create a serious hazard to the health, safety and general welfare of the occupants or the public.

Therefore, you will not occupy, permit anyone to occupy or rent the above mentioned without the written consent of the Health Officer or his agent, certifying that the conditions have been corrected.

Sincerely yours,



Lyle D. Noyes
Chief of Housing Inspections

Inspector Robert C. Bradley

LDN:gg

October 12, 1971

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

Dear Mr. Kenney:

Re: 62 Concord Street, Portland, Maine

As owner of the above referred property, you were notified on July 21, 1970, by United States mail, to correct certain substandard conditions in violation of Chapter 307 of the City of Portland Municipal Codes "Minimum Standards for Housing". Several reinspections have been made and we find that you have not complied with our request.

A final reinspection was made on October 5, 1971 by Housing Inspector Bailey and, as a result, you are hereby ordered to correct the violations listed below on or before November 12, 1971.

Sincerely yours,

Arthur A. Hughson, CPH, MPH
Health Director

Inspector _____

By Arthur A. Hughson
Chief of Housing Inspections

EXISTING VIOLATIONS OF CHAPTER 307 OF THE CITY OF PORTLAND MUNICIPAL CODE - Section(s)

- ~~1. Determine the reason and remedy the condition which causes the rear hall stairway, first to second floor, to be separating from main structure. 3(a)~~
- ~~2. Repair or replace the deteriorating wall and floor boards of the second floor front porch. 3(d)~~
- ~~3. Repair or replace the loose siding on the exterior walls of the entire structure. 3(a)~~
- ~~4. Determine the reason and remedy the condition which causes the gutters to leak. 3(a)~~
- ~~5. Repair or replace the broken or missing bannister and balusters on the stairway in the front hall, first to second floor. 3(d)~~
- ~~6. Repair or replace the defective mortar bricks on the chimney above roof line. 3(a)~~
- ~~7. Accomplish a general clean up of the cellar by properly removing and disposing of all rubbish and debris. 4(a)~~
- ~~8. Repair or replace the loose and dangerous cellar stairs. 3(d)~~
- ~~9. Repair or replace the broken and missing bulkhead doors. 3(c)~~
- ~~10. Provide adequate artificial illumination in the front hallway, first floor. Properly secure electrical wires in the second floor rear hallway. Our inspection reveals that the wiring is active throughout the structure and should be thoroughly checked by a competent licensed electrician. 8(c)~~
- 11. First Floor Unit
~~Replaces the broken window panes in the right front bedroom. 3(c)~~
- 12. Second Floor Unit
~~Repair or replace the broken plaster on the ceiling and/or walls in the kitchen, bathroom and living room. 3(b)~~
- ~~13. Repair or replace the loose and worn floor boards in the kitchen and bathroom. 3(b)~~
- ~~14. Repair or replace the chipped and worn sink in the kitchen. 6(a)~~

continued -

62 Concord - continued

Second Floor Unit - continued

- | | |
|--|------------|
| 15. Repair or replace the broken window panes in the living room. | Section(s) |
| 16. Determine the reason and remedy the condition which causes signs of leakage on the ceiling in the front bedroom, near the dormer window. | 3(c) |
| 17. Repair or replace the defective door in the dining room. | 3(b) |
| | 3(c) |

*FIRST PRIORITY IS TO BE GIVEN TO ITEMS NUMBERED 1, 2, 5, 9 and 10 WHEN MAKING YOUR REPAIRS AS THEY CONSTITUTE EXTREME HAZARDS TO THE HEALTH OR SAFETY OF THE OCCUPANTS OF THIS STRUCTURE.

SUPPLEMENT

~~18. Repair or replace the missing plaster on walls and ceiling in the front bedroom. 11/15/71 100 (OK) 3 b/jh 6c~~

~~19. Repair or replace the missing plaster on walls and ceiling in the front bedroom. 11/15/71 100 -3b~~

~~20. Repair or replace the missing plaster on walls and ceiling in the front bedroom. 11/15/71 100 3 b/jh~~

~~22. Repair or replace the missing plaster on walls and ceiling in the front bedroom. 11/15/71 100 3c~~

844.

CITY OF PORTLAND, MAINE
Health Department - Housing Inspector Division

Arthur A. Hughson, CPH MPH
Health Director

NOTICE OF HEARING

July 6 1971

To: Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

In Re: Premises located at 62 Concord Street, Portland, Maine

Dear Mr. Kenney:

Because of your failure to comply with previous NOTICES, you are hereby invited to appear in Room 24, City Hall, 389 Congress Street, Portland, Maine, at 9:30 A.M. on Wednesday, July 14, 1971, to show cause why legal action should not be taken against you for violations of the Municipal Codes relating to housing conditions at the above referred premises, as described more fully in the attached copy of the original NOTICE received by you on or about July 22, 1970. Hearing requested by Inspector Oliver.

FAILURE TO APPEAR MAY RESULT IN PROSECUTION

Please notify this office at once if you have corrected all violations before the above noted hearing date.


Chief of Housing Inspections

Inspector Anthony J. Allen

/aa

NOTICE OF HOUSING CONDITIONS

DU 2

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: 62 Concord Street
Project: Deering Center
issued: 7-21-70
Expires: 10-21-70

Mr. James Kenney
5 Greenway Drive
Falmouth, Maine 04105

Dear Mr. Kenney:

An examination was made of the premises at 62 Concord Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before October 21, 1970. You may contact the Housing Inspection Supervisor at this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,
Arthur A. Hugheson, CPH, MPH

Health Director

By: Hyde D. Hayes
Housing Inspection Supervisor

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)

1. Determine the reason and remedy the condition which causes the rear hall stairway, first to second floor, to be separating from main structure. 3(a)
2. Repair or replace the deteriorating rail and floor boards of the second floor front porch. 3(d)
3. Repair or replace the loose siding on the exterior walls of the entire structure. 3(a)
4. Determine the reason and remedy the condition which causes the gutters to leak. 3(a)
5. Repair or replace the broken or missing bannister and balusters on the stairway in the front hall, first to second floor. 3(d)
6. Repair or replace the defective mortar bricks on the chimney above the roof line. 3(e)
7. ~~Clean the chimney in the cellar by removing and properly disposing of all soot.~~ 3(a)
8. Accomplish a general clean up of the cellar by properly removing and disposing of all rubbish and debris. 4(a)
9. Repair or replace the loose and dangerous cellar stairs. 3(d)
10. Repair or replace the broken and missing bulkhead doors. 3(c)
11. Install adequate artificial illumination in the front hallway, first floor. Properly secure electrical wires in the second floor rear hallway. Our inspection reveals that the wiring is defective throughout the structure and should be thoroughly checked by a competent licensed electrician. 3(c)

continued ~

62 Concord Street - continued

First Floor Unit

12. Replace the broken window panes in the right front bedroom.

Section(s)

3(c)

Second Floor Unit

13. Repair or replace the broken plaster on the ceiling and/or walls in the kitchen, bathroom and living room.
14. Repair or replace the loose and worn floor boards in the kitchen and bathroom.
15. Repair or replace the chipped and worn sink in the kitchen.
16. Repair or replace the broken window panes in the living room.
17. Determine the reason and remedy the condition which causes signs of leakage on the ceiling in the front bedroom, near the dormer window.
18. Repair or replace the defective door in the dining room.

3(b)

3(b)

6(a)

3(c)

3(b)

3(c)

781-3879
REINSPECTION RECOMMENDATIONS

LOCATION 62 Concord St
Project DC
Owner James Kenney

INSPECTOR QJO

NOTICE OF HOUSING CONDITIONS		REINSPECTION NOTICE		HEARING NOTICE	
Issued	Expired	Issued	Expired	Issued	Expired
7/21/70	12/21/70				

A reinspection was made of the above premises and I recommend the following action:

Date		ALL VIOLATIONS HAVE BEEN CORRECTED _____ Send "Certificate of Compliance" _____ "Posting Release" _____
		SATISFACTORY rehabilitation in progress.
4/15/71	BB	UNSATISFACTORY progress. Send "Reinspection Notice" _____. "Notice to Vacate" _____. "Posting Notice" <u>X</u> .
6/30/71	QJO	UNSATISFACTORY progress. Send "Hearing Notice" <u>X</u> at 9:30 - 7-14-71 - Wed.
11/13/71	BB	UNSATISFACTORY progress. Request "Legal Action" be taken <u>X</u> .
6/30/71	QJO	REMARKS: application in 6/23/71 Send Hearing Notice
		10-12-71 Final Notice
		Do not hand to be used by BB
		delivered NOK to his wife at 5 Thompson St Apt
11/15/71	BB	Legal action - CT 1st and 2nd floor
11/15/71	BB	CT - TOWN BANK FOR LOAN CO ON 4/17/72 AM
11/15/71	BB	CT - WASH CALL MO TOW - 11/11/71
11/15/71	BB	FLY UNIT to be posted in QUN 101 6/21/71
		July 14 m.
4/15/71	BB	POST 2nd Floor UNIT (Do not vacate 11.30)
5/11/71	BB	2nd UNIT VACANT
5/22/71	BB	SEND FINAL LETTER
7/12/71	BB	NA-LN

REINSPECTION RECOMMENDATIONS

INSPECTOR QJO

LOCATION 62 Concord St
 PROJECT Wearing City
 OWNER _____

NOTICE OF HOUSING CONDITIONS		HEARING NOTICE		FINAL NOTICE	
Issued	Expired	Issued	Expired	Issued	Expired
7-21-70	10-21-70				

A reinspection was made of the above premises and I recommend the following action:

		ALL VIOLATIONS HAVE BEEN CORRECTED Send "CERTIFICATE OF COMPLIANCE" _____ "POSTING RELEASE" _____
		SATISFACTORY Rehabilitation In Progress Time Extended To _____ Time Extended To _____ Time Extended To _____
		UNSATISFACTORY Progress Send "HEARING NOTICE" _____ "FINAL NOTICE" _____
8/4/72	QJO	"NOTICE TO VACATE" POST Entire <u>1st floor structure</u> POST Dwelling Units <u>(2) 1st floor</u>
		UNSATISFACTORY Progress Request "LEGAL ACTION" Be Taken _____
8/4/72	QJO	INSPECTOR'S REMARKS: <u>Reinspect made post 1st floor - 2nd floor posted 5-3-72 - Entire structure will now be posted. Tenants 1st floor not actually moved in - Not sleeping or eating here no furniture Mrs Judith Feeney & Mrs Candy Wright (Mrs Wright has a 5 yr old girl) - Did not posting notice to Mrs Mervyn at 5 pm</u>
8/6/72	QJO	INSTRUCTIONS TO INSPECTOR: <u>presented in form of claim 8/13/72</u>