

14 Clinton Street 130-I-9

DRG. CTR. I



CERTIFICATE
OF
COMPLIANCE

June 9, 1972

CITY OF PORTLAND
Health Department - Housing Division
Tel. 775-5451 Ext 226

Mr. Donald Ramsey
14 Clinton Street
Portland, Maine 04103

Re: Premises located at 14 Clinton Street

Dear Mr. Ramsey:

A re-inspection of the premises noted above was made on June 6, 1972
by Housing Inspector Galley, of the Health Department.

This is to certify that you have complied with our request to correct the violations
of the Municipal Codes relating to housing conditions described in our "Notice of
Housing Conditions" dated 7/1/70.

Thank you for your cooperation and your efforts to help us maintain decent, safe and
sanitary housing for all Portland residents.

Sincerely yours,

Arthur A. Hughson, CPH, MPH
Health Director

By [Signature]
Chief of Housing Inspections

Inspector [Signature]

Handwritten notes:
2/21/70
P. 10/10/70

DU-1

38
gll

NOTICE OF HOUSING CONDITIONS

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: 14 Clinton Street
Project: Drering Center
Issued: 7-7-70
Expires: 10-7-70

Handwritten initials: AK

Mr. Donald Ramsay
14 Clinton Street
Portland, Maine 04103

Dear Mr. Ramsay:

An examination was made of the premises at 14 Clinton Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before October 7, 1970. You may contact the Housing Inspection Supervisor at this office to arrange satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,
Arthur A. Hughson, CPH, MPH
Health Inspector

By: *Handwritten signature: Kyle D. Sawyer*
Housing Inspection Supervisor

EXISTING VIOLATIONS OF CHAPTER 207 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)

1. ~~Point-up loose joints of the chimney above roof line.~~ 3(e)
2. ~~Repair or replace the loose and broken siding overall on the exterior walls of the structure.~~ 3(b)
3. ~~Repair or replace the loose gutter at the front of structure and the broken downspout, on the right side.~~ 3(b)
4. ~~Determine the reason and remedy the condition which causes the gutters to leak on all sides of structure.~~ 3(a)

