

149 Concord Street 131-G-2

DRG-CTR 1



CERTIFICATE
OF
COMPLIANCE

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 Ext. 226

January 8, 1971

Miss Dorothy M. Fletcher
Mr. Edward G. Fletcher
149 Concord Street
Portland, Maine 04103

Re: Premises located at 149 Concord Street, Portland, Maine

Dear Miss Fletcher and Mr. Fletcher:

A re-inspection of the premises noted above was made on December 28, 1970
by Housing Inspector Oliver, of the Health Department.

This is to certify that you have complied with our request to correct the
violations of the Municipal Codes relating to housing conditions described
in our "Notice of Housing Conditions" dated September 23, 1970.

Thank you for your cooperation and your efforts to help us maintain decent,
safe and sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

By Lynda D. Hughes
Chief of Housing Inspections

Inspector Anthony J. Oliver

/gg

NOTICE OF HOUSING CONDITIONS

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: 149 Concord Street
Project: Deering Center
Issued: 9-23-70
Expires: 12-23-70

DU

gs

Miss Dorothy H. Fletcher
Mr. Edward G. Fletcher
149 Concord Street
Portland, Maine 04103

Dear Miss Fletcher and Mr. Fletcher:

An examination was made of the premises at 149 Concord Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before December 23, 1970. You may contact this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,

Arthur A. Hugheson, CPH MPH
Health Director

Oliver Inspector

B... Lyle D. Hoopes
Chief of Housing Inspections

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" -

- | | |
|---|--------------|
| 1. Determine the reason and remedy the condition which causes the fuses to blow excessively. | Section(s) |
| 2. Repair or replace the broken plaster on the ceilings of the kitchen-pantry, and front living room - first floor; the front bedroom, middle bedroom and hallway of the second floor. | 8(a)
9(b) |

12/25/70
9/26

