

18-24 AMHERST STREET

STANDARD BOOK CO. NEW YORK, N. Y. 10037



STANDARD BOOK CO. NEW YORK, N. Y. 10037



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 9, 1972

PERMIT ISSUED

NOV 15 1972

01894

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 18 Amherst St. Use of Building Dwelling No. Stories 1 New Building Existing " Name and address of owner of appliance Robert Hall Installer's name and address Ballard Oil Company - 135 Marginal Way Telephone 772-1991

General Description of Work

To install Conversion burner and controls

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Kind of fuel? Minimum distance to burnable material, from top of appliance or casing top of furnace From top of smoke pipe From front of appliance From sides or back of appliance Size of chimney flue Other connections to same flue If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Waltham Labelled by underwriters' laboratories? Yes Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? Bottom Type of floor beneath burner Cement Size of vent pipe 1 1/4" Location of oil storage Basement Number and capacity of tanks 275 gals. Low water shut off Make No. Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners 275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 4.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.K. E.B. 11/13/72

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Ballard Oil & Equipment Co.

Signature of Installer Richard J. B...

CS 300

INSPECTION COPY

# 1038

**CITY OF PORTLAND, MAINE**  
**Application for Permit to Install Wires**

Permit No. ... 38  
 Issued .....  
 Portland, Maine November 9, 1972

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

*(This form must be completely filled out — Minimum Fee, \$1.00)*

Owner's Name and Address Isobel Hall Tel. ....  
 Contractor's Name and Address Richard C. P. Portland Tel. 772-1886  
 Location 18 Amherst Use of Building Res.  
 Number of Families 1 Apartments 1 Stores 1 Number of Stories 1  
 Description of Wiring: New Work X Additions ..... Alterations .....

Pipe ..... Cable ..... Metal Molding ..... BX Cable ..... Plug Molding (No. of feet) .....  
 No. Light Outlets ..... Plugs ..... Light Circuits ..... Plug Circuits .....

FIXTURES: No. .... Fluor. or Strip Lighting (No. feet) .....

SERVICE: Pipe ..... Cable ..... Underground ..... No. of Wires ..... Size .....

METERS: Relocated ..... Added ..... Total No. Meters .....

MOTORS: Number ..... Phase ..... H. P. ..... Amps ..... Volts ..... Starter .....

HEATING UNITS: Domestic (Oil) 2 No. Motors 1 Phase 1 H.P. 1  
 Commercial (Oil) ..... No. Motors ..... Phase ..... H.P. ....  
 Electric Heat (No. of Rooms) .....

APPLIANCES: No. Ranges ..... Watts ..... Brand Feeds (Size and No.) .....  
 Elec. Heaters ..... Watts .....  
 Miscellaneous ..... Watts ..... Extra Cabinets or Panels .....

Transformers ..... Air Conditioners (No. Units) ..... Signs (No. Units) .....

Will commence ..... 19 .. Ready to cover in ..... 19. Inspection ..... 19 ..

Amount of Fee \$ .....  
 Signed R. J. B. [Signature]

DO NOT WRITE BELOW THIS LINE

SERVICE .....	METER .....	GROUND .....
VISITS: 1 .....	2 .....	3 .....
4 .....	5 .....	6 .....
7 .....	8 .....	9 .....
10 .....	11 .....	12 .....

REMARKS:

INSPECTED BY [Signature]  
 (OVER)

**CITY OF PORTLAND, MAINE**  
**Application for Permit to Install Wires**

Permit No. 59021  
 Issued 6-28-72  
 Portland, Maine 6-28 1972

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address R.M. HALL Tel. \_\_\_\_\_  
 Contractor's Name and Address GOFF ELECTRIC Tel. 797-3787  
 Location 18 AMHERST ST. Use of Building RESIDENCE  
 Number of Families 1 Apartments \_\_\_\_\_ Stores \_\_\_\_\_ Number of Stories \_\_\_\_\_  
 Description of Wiring: New Work \_\_\_\_\_ Additions \_\_\_\_\_ Alterations   
 Pipe \_\_\_\_\_ Cable \_\_\_\_\_ Metal Molding \_\_\_\_\_ BX Cable \_\_\_\_\_ Plug Molding (No. of feet) \_\_\_\_\_  
 No. Light Outlets \_\_\_\_\_ Plugs \_\_\_\_\_ Light Circuits \_\_\_\_\_ Plug Circuits \_\_\_\_\_  
 FIXTURES: No. \_\_\_\_\_ Fluor. or Strip Lighting (No. feet) \_\_\_\_\_  
 SERVICE: Pipe  Cable \_\_\_\_\_ Underground \_\_\_\_\_ No. of Wires 3 Size 2  
 METERS: Relocated  Added \_\_\_\_\_ Total No. Meters \_\_\_\_\_  
 MOTORS: Number \_\_\_\_\_ Phase \_\_\_\_\_ H. P. \_\_\_\_\_ Amps \_\_\_\_\_ Volts \_\_\_\_\_ Starter \_\_\_\_\_  
 HEATING UNITS: Domestic (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ H.P. \_\_\_\_\_  
 Commercial (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ F.P. \_\_\_\_\_  
 Electric Heat (No. of Rooms) \_\_\_\_\_  
 APPLIANCES: No. Ranges \_\_\_\_\_ Watts \_\_\_\_\_ Brand Feeds (Size and No.) \_\_\_\_\_  
 Elec. Heaters \_\_\_\_\_ Watts \_\_\_\_\_  
 Miscellaneous \_\_\_\_\_ Watts \_\_\_\_\_ Extra Cabinets or Panels \_\_\_\_\_  
 Transformers \_\_\_\_\_ Air Conditioners (No. Units) \_\_\_\_\_ Signs (No. Units) \_\_\_\_\_  
 Will commence \_\_\_\_\_ 19\_\_\_\_ Ready to cover in \_\_\_\_\_ 19\_\_\_\_ Inspection \_\_\_\_\_ 19\_\_\_\_  
 Amount of Fee \$ 2.00 Signed R. Goff

DO NOT WRITE BELOW THIS LINE

SERVICE \_\_\_\_\_ METER \_\_\_\_\_ GROUND \_\_\_\_\_  
 VISITS: 1 \_\_\_\_\_ 2 \_\_\_\_\_ 3 \_\_\_\_\_ 4 \_\_\_\_\_ 5 \_\_\_\_\_ 6 \_\_\_\_\_  
 \_\_\_\_\_ 7 \_\_\_\_\_ 8 \_\_\_\_\_ 9 \_\_\_\_\_ 10 \_\_\_\_\_ 11 \_\_\_\_\_ 12 \_\_\_\_\_

REMARKS:

INSPECTED BY J. W. Huber  
 (OVER)



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

MAY 22 1940

Portland, Maine, May 20, 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 18 Amherst Street Use of Building Dwelling No. Stories New Building Existing

Name and address of owner of appliance Stanley O. Sanborn, 18 Amherst St.

Installer's name and address Ballard Oil & Equip. Co. of Me. Telephone 2-1991

General Description of Work

To install Oil Burning Equipment - Hot Water (forced)

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? Yes If not, which story Kind of fuel Oil

Material of supports of appliance (concrete floor or what kind) Concrete

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace,

from top of smoke pipe 10" WITH ASBESTOS MIN. BOARD PROTECTION from front of appliance from sides or back of appliance.

Size of chimney flue Other connections to same flue

IF OIL BURNER

Name and type of burner GBOO Gilbarco Labeled and approved by Underwriters' Laboratories? Yes

Will operator be always in attendance? Type of oil feed (gravity or pressure) Pressure

Location oil storage Basement No. and capacity of tanks 1 - 275-Gal.

Will all tanks be more than seven feet from any flame? Yes How many tanks fireproofed?

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of Installer By: [Signature] Ballard Oil & Equip. Co. of Me.

INSPECTION COPY

REQUIREMENTS OF LAW ENFORCED BY INSPECTOR OF BUILDINGS

6971c

Permit No. 401201

Location 18 Amherst St.

Owner Stanley P. Sambora

Date of Permit 5/22/40

Post Card sent

Notif for insp. None

Approval Tag issued 5/25/40

Oil Burner Check-list (date) 5/25/40

- 1. Kind of heat H.W. (forced) ✓
- 2. Label ✓
- 3. Anti-siphon ✓
- 4. Oil storage ✓
- 5. Tank distance ✓
- 6. Vent Pipe ✓
- 7. Fill Pipe ✓
- 8. Gauge ✓
- 9. Rigidity ✓
- 10. Feed safety ✓
- 11. Pipe sizes and material ✓
- 12. Control valve ✓
- 13. Ash pit vent ✓
- 14. Temp. or pressure safety ✓
- 15. Instruction card ✓

16a Leak-off station on fill pipe

NOTES

# APPLICATION

RECEIVED

FEB 24 1981

PUBLIC WORKS ENGINEERING



# FOR SUBMETER

## For Sewer User Charge Adjustments

The undersigned hereby requests permission to install additional water meter(s) in accordance with Section 322.6C of the "Municipal Code of the City of Portland, Maine".

It is understood that all expenses related to the purchase, installation and maintenance of the meter(s) is to be borne by the applicant.

### To be Completed by Applicant

Address where sub-meter is requested 18 Amburst St. Portland, Maine

Property owner name Richard M + Beverly M Hall

Tax Map Reference (on Real Estate Tax Bill) 151-1-14 89-1657

Property owner address 18 Amburst St. Portland, Maine

Person to be contacted to schedule inspections Beverly Hall 721-5229 (after 11:30 PM)  
(Name and Telephone Number)

Portland Water District Acct. No. (on bill) D-33-12176

Billing Name & Address (or bill to) Richard Hall  
18 Amburst St. Portland


Location and size existing Portland Water District Service Meter Basement  
front left corner Residential 1/8" Ø

Proposed location and size of sub-meter Left Rear Side  
1/8" Ø Residential


Will a remote reading register be utilized? NO  YES (If yes, state location)  
NEAR PWD. REMOTE READER'S SOON AS DISTRICT CHANGES REGULAR METER TO

REMOTE READER OUTSIDE  
Description of proposed changes  
in plumbing required for submetering:

Install submeter in line  
to outside sillcock



Sketch plan showing proposed changes in plumbing and the location of existing and proposed meters. Show water flow through submeter to non-discharge equipment or location (use additional sheet of paper if necessary)



The volume of water to be submetered can be shown not to enter the sewerage system by virtue of its use for:

- GARDENING, WATERING
- LAWN WASHING CAR
- ETC.

I certify the above information is true and correct:

Richard M Hall  
Signature

2/23/81  
Date

**INSTRUCTIONS.**

First - The applicant is to complete front of this form. The Tax Map Reference can be found on our Real Estate Tax Bill directly following owners name and address. The center of your Property Tax Bill Billing name and address should be copied from your Water & Sewer Bill as well as the Portland Water District Account Number which is in the lower left corner of the Water and Sewer Bill.

Second - Mail completed application form to:

City of Portland  
Dept. of Public Works  
400 City Hall  
Portland, Maine 04103

ATTN: MR. WILLIAM GOODWIN

Third - The Public Works Department will call the person indicated on front side to schedule pre-installation inspection. During this inspection the Public Works section of this form (below) will be completed. Following this inspection Public Works will make copies of the application form. If application is approved 3 copies will be made, one will be sent to the Portland Water District, one will be forwarded to the City Plumbing Inspector and one will be mailed back to the Applicant. If the application is denied, one copy will be made and mailed to the applicant showing reason for denial.

Fourth - Upon receipt of a copy of the approved application, the applicant can purchase and install the sub-meter as approved. Following installation by applicant or his plumber must call the Chief Plumbing Inspector at 775-0111 Ext. 274 for an inspection of the completed installation. Following inspection by the Chief Plumbing Inspector, the Water District will be requested to send the sub-meter and arrange to have an automatic reading system (if applicable - See General Information) instituted where by the volume shown by the sub-meter will be credited on the Sewer User Charges of the bill.

**GENERAL INFORMATION**

Section 222.61 of the "Municipal Code of the City of Portland, Maine" reads as follows:

"Submetering of Water Volume. Any person who feels that recorded water records are not a reliable index of his discharge volume may install an additional water meter of a type approved by the Director to measure the volume of water which can be shown not to enter the sewerage system. The person installing such a meter shall immediately notify the Director of such installation and shall be responsible to the Director for reporting meter readings not less often than every three months. Such person shall be credited with the volume charges for the volume shown by such meter, which meter shall be accessible for reading by the City or its agents at all reasonable times."

The City and the District have arranged to relieve the customer from the reporting responsibility required above if both meters can be read simultaneously by the District meter readers during their regularly scheduled visits to read the pre-existing service meter. This can be accomplished by locating the sub-meter directly adjacent to the pre-existing service meter or by equipping the sub-meter located elsewhere with a remote reading register located at both readings can be made at the same time.

Approved meters are, Kepture and Incowell meters, conforming to the following specifications:

1. shall meet or exceed ANSI accuracy, test requirements and be accompanied by a certificate of test accuracy.
2. the meter shall have straight reading, cubic foot register.
3. the meter shall have the meter number stamped into the meter case.
4. the meter shall be magnetic drive.
5. shall have either a nutated disc or oscillating piston.
6. shall have a bronze case.

Approved meters are available from the Water District, which sells them for the price the District buys them from the manufacturers. If you wish to purchase a sub-meter from the District you must bring your copy of an approved application with you at time of purchase.

**TO BE COMPLETED BY PUBLIC WORKS**

Pre-installation inspection by No van To edel

on March 5, 1980

Automatic reading system requested  YES  NO

A Watts #8A NF Back Flow Preventer or equal shall be installed in hose bulb by outside street.

Application  Approved  Denied

Comments \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**TO BE COMPLETED BY THE PLUMBING INSPECTOR**

An inspection of the completed installation of the submetering system approved on this application was conducted on 5-21-81  
By Ernold R. Goodwin, Chief Plumbing Inspector of the City of Portland.

- The submetering system was installed as approved.
- No cross connections were found.

The installation is  approved  dis-approved

**TO BE COMPLETED BY THE WATER DISTRICT**

Date submeter sold 5-11-81  
Submeter account number D-33-12176  
Submeter make and number 5/8 R 305 33158  
Submeter installation readings 0  
Submeter account entered into computer \_\_\_\_\_  
Submeter account entered into meter book 5-11-81  
Additional Instructions \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_