

125 Concord Street 131-K-3

DRG-CTR I



CERTIFICATE
OF
COMPLIANCE

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 Ext. 226

May 13, 1971

Mr. Robert D. Cody
71 Salem Street
Portland, Maine 04102

Re: Premises located at 125 Concord Street, Portland, Maine

Dear Mr. Cody:

A re-inspection of the premises noted above was made on May 11, 1971
by Housing Inspector R. Bailey, of the Health Department.

This is to certify that you have complied with our request to correct the
violations of the Municipal Codes relating to housing conditions described
in our "Notice of Housing Conditions" dated March 10, 1971.

Thank you for your cooperation and your efforts to help us maintain decent,
safe and sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

By Lyle J. Brown
Chief of Housing Inspections

Inspector R. Bailey

/s/

NOTICE OF HOUSING CONDITIONS

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: 125 Concord Street
Project: Heating Center
Issued: 3-10-71
Expires: 6-10-71

DU 1

Mr. Robert O. Cody
71 Bates Street
Portland, Maine 04102

Dear Mr. Cody:

An examination was made of the premises at 125 Concord Street

Inspector: Bulley Portland, Maine, by Housing
Violations of Municipal Codes relating to hous-
ing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before June 10, 1971. You may contact this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

Inspector

Robert Bulley

By:

Gyle D. Noyes
Chief of Housing Inspections

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" -

- | | |
|--|------------|
| 1. Point up left front of foundation. | Section(s) |
| 2. Determine the reason and remedy the condition which causes the gutter to leak on the left side of structure. | 3(a) |
| 3. Repair or replace the broken plaster on the ceiling of the second floor front hallway. | 3(a) |
| | 3(a) |

