

168 Clinton Street 135-J-7

DNR-6111



CERTIFICATE  
OF  
COMPLIANCE

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 774-8221 Ext. 226

August 10, 1971

Mr. Lloyd W. Butterick  
168 Clinton Street  
Portland, Maine 04103

Re: Premises located at 168 Clinton Street, Portland, Maine

Dear Mr. Butterick:

A re-inspection of the premises noted above was made on August 9, 1971  
by Housing Inspector Bailey, of the Health Department.

This is to certify that you have complied with our request to correct the violations  
of the Municipal Codes relating to housing conditions described in our "Notice of  
Housing Conditions" dated August 20, 1970.

Thank you for your cooperation and your efforts to help us maintain decent, safe and  
sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH, MPH  
Health Director

By Lydia D. Jones  
Chief of Housing Inspections

Inspector Kosier Bailey

/99

NOTICE OF DEFICIENCIES

11

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 774-6321 - Ext. 226

Location: 168 Clinton Street  
Project: Deering Center  
Issued: 8-20-70  
Expires: 11-20-70

Mr. Lloyd W. Butterick  
168 Clinton Street  
Portland, Maine 04103

Dear Mr. Butterick:

An examination was made of the premises at 168 Clinton Street Portland, Maine,  
by Housing Inspector Oliver. Violations of Municipal Codes relating  
to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are  
requested to correct these defects on or before November 10, 1970. You  
may contact the Housing Inspection Supervisor at this office to arrange a satis-  
factory repair schedule if you are unable to make such repairs within the specified  
time. We will assume the repairs to be in progress if we do not hear from you  
within ten days from this date and, on reinspection within the time set forth above,  
will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all  
Portland residents in decent, safe and sanitary housing.

Very truly yours,  
Arthur A. Hughson, CPH MPH  
Health Director

By: Lyle D. Doyes/AK  
Housing Inspection Supervisor

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)

- |   |      |
|---|------|
| 1. Repair or Replace the loose steps on the front porch.  | 3(d) |
| 2. Determine the reason and remedy the condition which causes the floor boards to rot of the front porch. | 3(d) |
| 3. Repair or Replace the broken plaster on the walls of the bathroom.                                     | 3(b) |
| 4. Repair or Replace the worn and chipped lavatory of the bathroom.                                       | 6(a) |
| 5. Replace the bathtub fixture which causes a cross connection.   | 6(a) |

