

Ward 9 Permit No. 37/793

Location 33 Brentwood St.

Owner D. L. Knight

Date of permit 6/3/37

Post Card sent 6/3/37

Notif. for inspu. 6/4/37 2100 am

Approval Tag issued 6/5/37 OK

Oil Burner Check List (date) 6/5/37

1. Kind of heat Hot Water
2. Label 1125964 ✓
3. Anti-siphon ✓
4. Oil storage ✓
5. Tank distance ✓
6. Vent pipe ✓
7. Fill pipe ✓
8. Gauge ✓
9. Rigidity ✓
10. Feed safety ✓
11. Pipe sizes and material ✓
12. Control valve ✓
13. Ash pit/vent ✓
14. Temp. or pressure safety ✓
15. Instruction card ✓
16. Draft - Start in smoke pipe

*over smoke pipe where
less than 15" below
wood above. OK*

NOTES

*Cimney has a cleanout
D.L. Knight said OK
would provide shield*