

97-99 CLINTON STREET

SHAW-WALKER

Full cut # 92017 Half cut # 92021 Third cut # 92039 Full cut # 92051

PERMIT TO INSTALL PLUMBING

Date Issued **1-10-72**  
 Portland Plumbing Inspector  
 By **ERNOLD R GOODWIN**

App. First Insp.  
 Date  
 By

App. Final Insp.  
 Date  
 By

- Type of Bldg.
- Commercial
  - Residential
  - Single
  - Multi Family
  - New Construction
  - Remodeling

Address **97 Clinton St.** PERMIT NUMBER **153**

Installation For  
 Owner of Bldg. **Ruth Bishop**  
 Owner's Address: **Same**  
 Plumber: **Maynard Waits** Date: **1-10-72**

NEW	REPL	NO.	FEE
	1	SINKS	2.00
	1	LAVATORIES	2.00
		TOILETS	
	1	BATH TUBS	2.00
		SHOWERS	
		DRAINS FLOOR SURFACE	
		HOT WATER TANKS	
		TANKLESS WATER HEATERS	
		GARBAGE DISPOSALS	
		SEPTIC TANKS	
		HOUSE SEWERS	
		ROOF LEADERS	
		AUTOMATIC WASHERS	
		DISHWASHERS	
		OTHER	
TOTAL			6.00

Building and Inspection Services Dept. Plumbing Inspection



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 15, 1961

PERMIT ISSUED

AUG 15 1961 01014

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 97 Clinton St. Use of Building Dwellings No. Stories 2 New Building Existing " Harris Oil Company 202 Commercial St. Telephone 5728304

General Description of Work To install Oil burner (replacement) in connection with existing steam heat.

IF HEATER, OR POWER BOILER

Location of appliance If so, how protected? Minimum clearance to burnable material, from top of appliance or casing top of furnace Kind of fuel? From front of appliance From sides or back of appliance Size of chimney pipe Other connections to same flue If gas fired, how vented? Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Volcano-gunttype Labeled by underwriters' laboratories? yes Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/2" Location of oil storage basement Number and capacity of tanks 275 existing Low water shut off yes Make McDonnell-Killier How many tanks enclosed? No. 67 Will all tanks be more than five feet from any flame? yes Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance If so, how protected? Skirting at bottom of appliance? Height of Legs, if any From front of appliance Distance to combustible material from top of appliance? From top of smokepipe Size of chimney flue From sides and back Is hood to be provided? Other connections to same flue If gas fired, how vented? If so, how vented? Forced or gravity? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

7/15/61 - D.K. - [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Harris Oil Company

Signature of Installer by: [Signature]

INSPECTION COPY

F M

Permit No. 611/1014  
 Location 97 Clinton St  
 Owner Harold H. Bishop  
 Date of permit 8/15/61  
 Approved \_\_\_\_\_

NOTES

1	Piping	
2	Valve	
3	Electric	
4	Drain	
5	Other	
6	Other	
7	Other	
8	Other	
9	Piping	
10	Valve	
11	Other	
12	Tank	
13	Tank	
14	Other	
15	Instruction	
16	Low Water	

Large area of horizontal lines for notes or additional information.

ERNEST A. RANDALL, PRESIDENT

HENRY F. MERRILL, TREAS. & GEN. MGR

ESTABLISHED 1881

# RANDALL & McALLISTER

WHOLESALE AND RETAIL DEALERS IN

COAL

ANTHRACITE  
& BITUMINOUS



PORTLAND, ME.

97-99



R.F.K.

June 9, 1937

City of Portland, Maine  
Department of Building Inspection  
Portland, Maine.

Attention: Mr. Warren McDonald.

Dear Sir:

Referring to your letter of June 3 regarding draft regulator installed for Mr. Harold Bishop, 97 Clinker St., Portland, Me., it was installed at chimney wall and at your suggestion this has been removed and installed in the smoke pipe according to your regulations. The opening has been bricked up.


Trusting this meets with your approval.

Truly yours,

Randall & McAllister

*H. A. Beatty*  
Mgr. Oil Dept.

DAB:c



File: P.37/138-I  
R-6/11/37

June 5, 1937

Randall P. McAllister,  
84 Commercial Street,  
Portland, Maine

Gentlemen:

In connection with the installation of an oil burner for Harold Bishop at 97 Clinton Street an inspector from this office advises that you have provided a draft regulator in the wall of the chimney.

This arrangement is not considered satisfactory under Building Code regulations from the standpoint of the safety of the chimney. We have had the question up a number of times with other dealers that have been in the oil burner field longer than you have, and it appears also that the Insurance Underwriters do not look with favor upon an installation of this kind in the chimney wall.

It appears that the installation in the chimney wall in this case is not necessary as the inspector reports that there is plenty of room in the smokepipe to install the draft regulator there. There is no objection to installing the draft regulator in the smokepipe.

Will you be kind enough, then, to remove the draft regulator from the chimney, brick-up the opening thus left and install a draft regulator of the type that may be incorporated in the smokepipe.

May we have this matter attended to on or before June 10, 1937?

Very truly yours,

McE/R  
CC: Harold Bishop

Inspector of Buildings



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

Permit No. 0708

MAY 21 1937

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland Maine, May 21, 1937

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 97 Clinton St. Use of Building Residence No. Stories 2  
Name and address of owner Harold Bishop-97 Clinton St., Portland, Me. Ward 9  
Contractor's name and address Randall & McAllister-Portland, Me. Telephone 3-2941

General Description of Work

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

To install One Power Burner

NOTIFICATION BEFORE LEAVING OR CLOSING-IN IS WAIVED

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not which story \_\_\_\_\_ Kind of Fuel Oil  
Material of supports of heater or equipment (concrete floor or what kind) Concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, no  
from top of smoke pipe 18" from front of heater none from sides or back of heater none  
Size of chimney flue 10 x 12 Other connections to same flue no

IF OIL BURNER

Name and type of burner Timken-Rotary Labeled and approved by Underwriters' Laboratories? yes  
Will operator be always in attendance? \_\_\_\_\_ Type of oil feed (gravity or pressure) gravity  
Location oil storage Inside No. and capacity of tanks 1-275 gal  
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? none

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor Randall & McAllister  
by D. Beatty

INSPECTION COPY



Ward 9 Permit No 371706

Location 97 Clinton St.

Owner Harold Bishop

Date of permit 5/21/37

Post card sent 5/21/37

Not ~~an~~ none

Approval Tag issued 6/1/37

Oil Burner Check List (date) 6/1/37

- 1. Kind of heat Steam
- 2. Label
- 3. Anti-air chon
- 4. Oil storage
- 5. Tank distance
- 6. Vent pipe
- 7. Fill pipe
- 8. Gauge
- 9. Rigidity
- 10. Feed safety
- 11. Pipe sizes and material
- 12. Control valve
- 13. Ash pit vent
- 14. T. mp. or pressure safety
- 15. Instruction card
- 16. Draft or static in chimney

NG. IHS

4/13/37 - Batter about  
draft regulator mod  
6/1/37 - draft regulator

*changed to steam boiler*



STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

For one car frame-garage  
at 97 Clinton Street

Date 8/3/55

1. In whose name is the title of the property now recorded? Harold W & Doris B. Bink
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Yes - stakes
3. Is the outline of the proposed work now staked out upon the ground? Yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? 12"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? Yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? Yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? Yes

H. M. Pallister



(R) GENERAL RESIDENCE ZONE  
 APPLICATION FOR PERMIT **PERMIT ISSUED**

Class of Building or Type of Structure Third Class AUG 8 1935

Portland, Maine, August 7, 1935

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 97 Clinton Street Ward 9 Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's or Lessee's name and address Harold E. Bishop, et al 97 Clinton St. Telephone \_\_\_\_\_  
 Contractor's name and address R. A. Peterson, 64 Parkworth St. Telephone 2-7087  
 Architect's name and address \_\_\_\_\_  
 Proposed use of building 1 car garage No. families \_\_\_\_\_  
 Other buildings on same lot 1 family dwelling house  
 Plans filed as part of this application? yes No. of sheets 1  
 Estimated cost \$ 150. Fee \$ .75

Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_

General Description of New Work

To erect one car frame garage 12' x 20'

NOTIFICATION BEFORE LATHING  
 OR CLOSING-IN IS WAIVED  
 CERTIFICATE OF OCCUPANCY  
 REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work:

Size, front 12' depth 20' No. stories 1 Height average grade to top of plate 0'  
 Height average grade to highest point of roof 12'  
 To be erected on solid or filled land? solid earth or rock? earth  
 Material of foundation concrete slab Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof pitch Rise per foot 9" Roof covering Asph. roofing glass C. Mem.  
 No. of chimneys no Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
 Kind of heat no Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
 Corner posts no Sills yes Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x9 or larger. Bridging in every floor and flat roof span over \_\_\_\_\_ feet. Sills and corner posts all one piece in cross section.  
 Joints and rafters: 1st floor concrete, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot no to be accommodated 1  
 Total number commercial cars to be accommodated none  
 Will automobile repairing be done other than \_\_\_\_\_ repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Harold E. Bishop, et al  
 by R. A. Peterson  
 INSPECTION CITY

49230

Ward 9 Permit No. 35/1209

Location 97 Clinton St.

Owner Harold W. Bishop et al.

Date mit 8/8/35

Notif. closing-in \_\_\_\_\_

Inspn. closing-in \_\_\_\_\_

Fine \_\_\_\_\_

Final Inspn. 9/6/35

Cert. of Occupancy issued none

NOTES

8/1/35 Location as  
sketch of K. etc.  
8/14/35 - some hole  
nailed in  
8/23/35 - wall framed  
etc.  
9/6/35 - work done etc.





FILL IN COMPLETELY AND SIGN WITH INK

Permit No. \_\_\_\_\_

### APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 21, 1929

To the INSPECTOR OF BUILDINGS, Portland, Me.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 97 Clinton Street

Use of Building dwelling house

Name and address of owner Harry Bishop

Contractor's name and address E. R. Miller, 98 Forest Avenue

Telephone F 3722 W

#### General Description of Work

To install steam heating system

IF HEATER, POWER BOILER OR COOKING DEVICE:

Is heater or source of heat to be in cellar?  yes  If not, which story \_\_\_\_\_ Kind of Fuel coal

Material of supports of heater or equipment (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 16" 2'  
from top of smoke pipe 15", from front of heater over 4' from sides or back of heater over 4'

IF OIL BURNER

Name and type of burner \_\_\_\_\_

Approved by Underwriters' Laboratories? \_\_\_\_\_

*PC sent  
10/22/29*



# APPLICATION FOR PERMIT

PERMIT ISSUED  
Permit No. 22223

Class of Building or Type of Structure \_\_\_\_\_

Portland, Maine, October 21, 1929

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ install the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 97 Clinton Street Ward 9 Within Fire Limits? No Dist. No. \_\_\_\_\_

Owner's or Lessee's name and address Harry Bishop Telephone \_\_\_\_\_

Contractor's name and address E. R. Mallen, 98 Forest Ave. Telephone \_\_\_\_\_

Architect's name and address \_\_\_\_\_ Telephone F 3732 W

Proposed use of building dwelling house No. families \_\_\_\_\_

Other buildings on same lot \_\_\_\_\_

### Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_

### General Description of New Work

To install steam heating system

### Details of New Work

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Roof covering \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Kind of heat steam Type of fuel coal Distance, heater to chimney \_\_\_\_\_  
If oil burner, name and model \_\_\_\_\_  
Capacity and location of oil tanks \_\_\_\_\_  
Is gas fitting involved? \_\_\_\_\_ Size of service \_\_\_\_\_  
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? No  
Plans filed as part of this application? yes No. sheets 1  
Estimated cost \$ \_\_\_\_\_ Fee \$1.00  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

INSPECTION COPY

Signature of owner \_\_\_\_\_

476A



STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

For one family dwelling house  
at Lot 43 Clinton Street

Date 7/29/29

100

1. In whose name is the title of the property now recorded? David Bishop
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Stakes
3. Is the outline of the proposed work now staked out upon the ground? Yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? Yes
4. What is to be maximum projection or overhang of eaves or drip? None
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? Yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? Yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? Yes

H. W. Patterson

HP1423



PERMIT ISSUED  
Permit No. 1454  
AUG 1 1929



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, July 29, 1929

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~also install~~ the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 63 Clinton Street (See 97-99 C. Clinton Street) Within Fire Limits? NO Plat. No. \_\_\_\_\_  
Owner's or Lessee's name and address HAROLD STAPTON, 14 HANCOCK ST. Telephone \_\_\_\_\_  
Contractor's name and address H. M. Patterson 827 Stevens Ave. Telephone 7 0154 R  
Architect's name and address \_\_\_\_\_  
Proposed use of building Dwelling house No. families 1  
Other buildings on same lot \_\_\_\_\_

### Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Fast use \_\_\_\_\_ No. families \_\_\_\_\_

### General Description of New Work

To erect one family-frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

### Details of New Work

Size, front 24' over all depth 42' No. stories 2 Height average grade to highest point of roof 28'  
To be erected on solid or filled land? solid earth of rock? earth  
Material of foundation concrete Thickness, top 10" bottom 12"  
Material of underpinning brick Height 2' Thickness 6"  
Kind of roof pitch 6" to foot Roof covering Asphalt shingles Class C No. 1  
No. of chimneys one Material of chimneys brick of lining 2"  
Kind of heat steam Type of fuel \_\_\_\_\_ Distance, heater to chimney \_\_\_\_\_  
If oil burner, name and model \_\_\_\_\_  
Capacity and location of oil tanks \_\_\_\_\_  
Is gas fitting involved? No Size of service \_\_\_\_\_  
Corner posts Yes Sills Yes Girt or ledger board? Yes Size 2-2x8  
Material columns under girders Iron pipe Size 4" Max. on centers 8'  
Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or large Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd 2x8 attic, roof 2x8  
On centers: 1st floor 16", 2nd 16", 3rd 2', roof 8'  
Maximum span: 1st floor 14', 2nd 14', 3rd 14', roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Plans filed as part of this application? yes No. sheets 1  
Estimated cost \$ 1700. Fee \$ 2.50  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

INSPECTION COPY

Signature of owner

Harold Stapton  
H. M. Patterson

9565

Ward 9 Permit No. 29/1154  
 L Lot 43 Clinton St.  
 Owner Harold Bishop  
 Date of permit 8/1/29  
 Notif. closing-in  
 Ins. closing-in 7/27/29 G.T.  
 Final Notif. 11/25/29 9:45 AM G.T.  
 Cert. of Occupancy issued 11/25/29

NOTES

San harbor not located  
 Called for pattern 7/29/29  
 Location is shifted  
 The front and side  
 holders are further apart  
 ones with roof  
 7/29/29  
 17/29 - opening found  
 in sill, this date  
 lot 43 Clinton St.  
 it was 13 or 14 at  
 bottom, went to  
 requirements of  
 standard, on grade

will with Carpenter  
 8/14/29 G.T.  
 9 ft open in front to  
 have 4x6 header  
 string thereof 8/19/29  
 8/23/29 - Header strength  
 Water fireplace header  
 in cellar, and posts  
 for  
 Attic to be finished one  
 and half stories, floor  
 is 2x6-24" 14" span  
 8/29/29 G.T.  
 Smoke pipe opening in  
 cellar not cut, make on  
 1st floor.  
 Same opening in rear to be  
 stubbed for coal water  
 on final (to top)  
 1 Fire stop in rear of attic  
 Repairs not to be finished  
 (attic) so finish not  
 needed for work at  
 attic floor level  
 R.T. 7/20/29 G.T.  
 No closing in around plumbing

On final  
 Fire stop around water  
 pipe in cellar.  
 Bridge rear end  
 Fire stop around soil  
 stack in attic, Mr  
 Benson will attend  
 to them. 11/29/29 G.T.