

103 Clinton Street 136-B-10

DRG-CTR I



✓

CERTIFICATE  
OF  
COMPLIANCE

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 775-5451 Ext 226

July 20, 1972

Dr. Simon Berenson  
103 Clinton Street  
Portland, Maine 04103

Re: Premises located at 103 Clinton Street, Portland, Maine

Dear Mr. Berenson:

A re-inspection of the premises noted above was made on 7-18-72  
by Housing Inspector Reiley, 103 Clinton Street of the Health Department.

This is to certify that you have complied with our request to correct the violations of the Municipal Codes relating to housing conditions described in our "Notice of Housing Conditions" dated July 30, 1970.

Thank you for your cooperation and your efforts to help us maintain decent, safe and sanitary housing for all Portland residents.

Sincerely yours,

Arthur A. Hughson, CPH, MPH  
Health Director

By [Signature]  
Chief of Housing Inspections

Inspector [Signature]

/99

NOTICE OF EXISTING CONDITIONS

DU 1

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 774-8221 - Ext. 226

Location: 203 Clinton Street  
Project: Bearing Center  
Issued: 7-30-70  
Expires: 10-30-70

Dr. Simon Berenson  
203 Clinton Street  
Portland, Maine 04103

Dear Mr. Berenson:

An examination was made of the premises at 203 Clinton Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned codes, you are requested to correct these defects on or before October 30, 1970. You may contact the Housing Inspection Supervisor at this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,  
Arthur A. Hughson, CPH, PHD  
Health Director

By: Lyle D. [Signature]  
Housing Inspection Supervisor

- EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)
1. Point up the loose and cracked brick front steps - entrance. 3(d)
  2. Point up the loose bricks on chimney above roof line. 3(c)
  3. Repair or replace the broken plaster on the ceiling and walls of the kitchen. 3(b)
  4. Determine the reason and remedy the condition which causes the leakage on the ceiling and walls in the kitchen. 3(b)
  5. Repair or replace the broken plaster on the walls of the second floor rear bedroom. 3(b)
  6. Repair or replace the loose and missing tiles on the bathroom walls. 3(b)
  7. Determine the reason and remedy the condition which causes the bathroom walls to leak. 3(b)
  8. Determine the reason and remedy the condition which causes the bathtub to leak. 3(b)
  9. Repair or replace the caulking between the wall and the bathtub. 3(d)
  10. We suggest that the plumbing in the bathroom be checked by a competent licensed plumber. 3(d)

