

33 Clinton Street 137-F-8-9-10

DRG-CTR 1



CERTIFICATE
OF
COMPLIANCE

December 1, 1970

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 Ext. 226

Mr. Paul V. Guitard
33 Clinton Street
Portland, Maine 04103

Re: Premises located at 33 Clinton Street, Portland, Maine

Dear Mr. Guitard:

A re-inspection of the premises noted above was made on November 19, 1970
by Housing Inspector Oliver, of the Health Department.

This is to certify that you have complied with our request to correct the
violations of the Municipal Codes relating to housing conditions described
in our "Notice of Housing Conditions" dated August 19, 1970.

Thank you for your cooperation and your efforts to help us maintain decent,
safe and sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

By Lyle D. Jones
Chief of Housing Inspections

Inspector Anthony J. Oliver

LDN:gg

NOTICE OF HOUSING CONDITIONS

DU 1

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226
Mr. Paul V. Guitard
33 Clinton Street
Portland, Maine

Location: **33 Clinton Street**
Project: **Deering Center**
Issued: **8/19/70**
Expires: **11/19/70**

Dear **Mr. Guitard**:

An examination was made of the premises at 33 Clinton Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before November 19, 1970. You may contact the Housing Inspection Supervisor at this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,
Arthur A. Hughson, CPN MPH
Health Director

By: [Signature]
Housing Inspection Supervisor

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)

1. ~~Repair or Replace the loose 1st. step on front porch.~~ 3(a)
2. ~~Paint up the chimney above roof line.~~ 3(a)
3. ~~Repair or Replace the missing clapboards on the interior walls.~~ 3(a)
4. ~~Repair or Replace the loose and worn sills on the garage door.~~ 3(a)
5. ~~Replace all broken windows of the garage.~~ 3(c)
6. ~~Repair or Replace the broken plaster on the walls of the front and rear bedrooms and the ceiling of the middle bedroom 2nd floor.~~ 3(b)

