

35 Clinton Street 137-F-10

DRG-CTR

SHAW-WALKER  
7 (85033)

CERTIFICATE  
OF  
COMPLIANCE

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 774-8221 Ext. 226

December 1, 1970

Mrs. Jens Hamilton  
Kennebunk Inn  
Kennebunk, Maine

Re: Premises located at 35 Clinton Street, Portland, Maine

Dear Mrs. Hamilton:

A re-inspection of the premises noted above was made on November 18, 1970  
by Housing Inspector Oliver, of the Health Department.

This is to certify that you have complied with our request to correct the  
violations of the Municipal Codes relating to housing conditions described  
in our "Notice of Housing Conditions" dated August 18, 1970.

Thank you for your cooperation and your efforts to help us maintain decent,  
safe and sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH MPH  
Health Director

By [Signature]  
Chief of Housing Inspections

Inspector Anthony J. Oliver

LDM:gg

NOTICE OF HOUSING CONDITIONS

DU 2 *gls*

CITY OF PORTLAND  
Health Department - Housing Division  
Tel. 774-8221 - Ext. 226

Location: 35 Clinton Street  
Project: Doering Center  
Issued: 8/18/70  
Expires: 11/18/70

Mrs. Jena Hamilton  
Kennebunk Inn  
Kennebunk, Maine 04043

Dear Mrs. Jena Hamilton:

An examination was made of the premises at 35 Clinton Street Portland, Maine, by Housing Inspector Oliver. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you are requested to correct these defects on or before November 18, 1970. You may contact the Housing Inspection Supervisor at this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,  
Arthur A. Hughes, CPH MPH  
Health Director

By: [Signature]  
Housing Inspection Supervisor

- EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - Section(s)
- 1. Repair or replace the loose and worn treads and risers on the front porch steps. *11/5/70* Section(s) *5(d)*
  - 2. First Floor Apartment  
Repair or replace the broken plaster on the ceilings in the front and rear bedrooms. *11/18/70* *11(b)*
  - 3. Repair or replace the worn and chipped lavatory in the bathroom. *11/18/70* *5(d)*
  - 4. Install a duplex convenience outlet in the dining room. *11/18/70* *5(a)*
  - 5. Repair or replace the broken toilet seat in the bathroom. *11/18/70* *5(a)*
  - 6. Second Floor Apartment  
Install a duplex convenience outlet in the dining room. *11/18/70* *5(a)*
  - 7. Repair or replace the worn and chipped lavatory in the bathroom. *11/18/70* *5(d)*

