

53 Clinton Street 137-F-17

DRG 21R



✓

CERTIFICATE
OF
COMPLIANCE

November 24, 1971

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 Ext. 226

Mrs. Yvette Robertson
55 Clinton Street
Portland, Maine 04103

Re: Premises located at 53-55 Clinton Street, Portland, Maine

Dear Mrs. Robertson:

A re-inspection of the premises noted above was made on November 9, 1971
by Housing Inspector Bailey, of the Health Department.

This is to certify that you have complied with our request to correct the violations
of the Municipal Codes relating to housing conditions described in our "Notice of
Housing Conditions" dated July 1, 1970

Thank you for your cooperation and your efforts to help us maintain decent, safe and
sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH, MPH
Health Director

By [Signature]
Chief of Housing Inspections

Inspector [Signature]

/s/

PROCESS

1584
24

NOTICE OF HOUSING CONDITIONS

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: 53-55 Clinton Street
Project: Drinking Center
Issued: 7/1/70
Expires: 8/1/70
10/1/70

Mrs. Ivette Robertson
55 Clinton Street
Portland, Maine 04103

11/9/71
OK

Dear Mrs. Robertson:

An examination was made of the premises at Portland, Maine,
53-55 Clinton Street
by Housing Inspector R. Bailey. Violations of Municipal Codes relating
to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned Codes, you
are requested to correct these defects on or before August 1, 1970. You may
contact the Housing Inspection Supervisor at this office to arrange a satisfactory
repair schedule if you are unable to make such repairs within the specified time.
We will assume the repairs to be in progress if we do not hear from you within ten
days from this date and, on reinspection within the time set forth above, will anti-
cipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain
all Portland residents in decent, safe and sanitary housing.

Very truly yours,
Arthur A. Hinchon, CHM, HMI
Health Director

By: [Signature]
Housing Inspection Supervisor

- | EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" - | Section(s) |
|--|-------------------------|
| 1. Repair or replace the broken and loose plancia and fascia boards on the front porch. | 3(d) 11/9/71 |
| 2. Repair or replace the worn and broken boards on the rear stairs. | 3(a) 11/9/71 |
| 3. Repair or replace the missing and worn shingles on the right side and front corner of the structure. | 2(a) 11/9/71 |

