

84-86 BAYVIEW DRIVE

SHAW-WALKER

First out #020R - Second out #020R - Third out #020R - Fourth out #020R

86 Bayview Drive

Feb. 18, 1972

Donald J. Nelson  
86 Bayview Drive

Dear Mr. Nelson:

Building permit to construct 11'6" x 30' addition on side of existing garage at the above named location is being issued subject to plans received with the application and in compliance with Building Code restrictions as follows:

1. Ties of at least 2x4 inch stock will be required at every third rafter at the plate level and hung in the center by a board.
2. Rafters for the garage roof shall be at least 2x8 inch members, 16 inches on centers.
3. Foundation wall for this section shall be at least 4 feet below grade.

Very truly yours,

A. Allan Soule  
Assistant Director

AAS:m



R3 RESIDENCE ZONE

# APPLICATION FOR PERMIT

PERMIT ISSUED

FEB 18 1972  
0217

Class of Building or Type of Structure  
Portland, Maine, Feb. 16, 1972

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 86 Bayview Drive. Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Donald J. Nelson, 86 Bayview Drive. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address Cimino Constr. ? Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 2  
 Proposed use of building garage (change to two car) No. families \_\_\_\_\_  
 Last use g Style of roof pitch Roofing \_\_\_\_\_  
 Material wood No. stories 1 Heat \_\_\_\_\_  
 Other buildings on same lot house Estimated cost \$ 3000. Fee \$ 9.

### General Description of New Work

To construct  $11'6'' \times 2\frac{1}{2}'$  on side of existing garage as per plans

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

### Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? no  
 Is connection to be made to public sewer? no If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Corner posts \_\_\_\_\_ Sills \_\_\_\_\_  
 Framing Lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Size Cider \_\_\_\_\_ Columns under girders \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, height? \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? \_\_\_\_\_  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:  
OK - 2/18/72 - Allen W. Little

Donald J. Nelson

CS 801  
 INSPECTION COPY Signature of owner

**CITY OF PORTLAND, MAINE**  
**Application for Permit to Install Wires**

Permit No. 55767

Issued Mar 13, 1972  
 Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Donald Nelson Bay View Dr. Tel. 774-1514

Contractor's Name and Address Lloyd A. Moore 41 Brunswick St. Tel. 384-9192

Location 76 Bay View Drive Use of Building Private

Number of Families: 1 Apartments \_\_\_\_\_ Stores \_\_\_\_\_ Number of Stories \_\_\_\_\_

Description of Wiring: New Work \_\_\_\_\_ Additions \_\_\_\_\_ Alterations

Pipe \_\_\_\_\_ Cable \_\_\_\_\_ Metal Molding \_\_\_\_\_ BX Cable \_\_\_\_\_ Plug Molding (No. of feet) \_\_\_\_\_

No. Light Outlets \_\_\_\_\_ Plugs \_\_\_\_\_ Light Circuits \_\_\_\_\_ Plug Circuits \_\_\_\_\_

FIXTURES: No. \_\_\_\_\_ Fluor. or Strip Lighting (No. feet) \_\_\_\_\_

SERVICE: Pipe \_\_\_\_\_ Cable \_\_\_\_\_ Underground \_\_\_\_\_ No. of Wires \_\_\_\_\_ Size \_\_\_\_\_

METERS: Relocated  Added \_\_\_\_\_ Total No. Meters 1

MOTORS: Number \_\_\_\_\_ Phase \_\_\_\_\_ H. P. \_\_\_\_\_ Amps \_\_\_\_\_ Volts \_\_\_\_\_ Starter \_\_\_\_\_

HEATING UNITS: Domestic (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ H.P. \_\_\_\_\_

Commercial (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ H.P. \_\_\_\_\_

Electric Heat (No. of Rooms) \_\_\_\_\_

APPLIANCES: No. Ranges \_\_\_\_\_ Watts \_\_\_\_\_ Brand Feeds (Size and No.) \_\_\_\_\_

Elec. Heaters \_\_\_\_\_ Watts \_\_\_\_\_

Miscellaneous \_\_\_\_\_ Watts \_\_\_\_\_ Extra Cabinets or Panels \_\_\_\_\_

Transformers \_\_\_\_\_ Air Conditioners (No. Units) \_\_\_\_\_ Signs (No. Units) \_\_\_\_\_

Will commence 3:00 1972 Ready to cover in \_\_\_\_\_ 1972 Inspection \_\_\_\_\_ 1972

Amount of Fee \$ 3.00

Signed \_\_\_\_\_

DO NOT WRITE BELOW THIS LINE

SERVICE  METER \_\_\_\_\_ GROUND

VISITS: 1 \_\_\_\_\_ 2 \_\_\_\_\_ 3 \_\_\_\_\_ 4 \_\_\_\_\_ 5 \_\_\_\_\_ 6 \_\_\_\_\_

7 \_\_\_\_\_ 8 \_\_\_\_\_ 9 \_\_\_\_\_ 10 \_\_\_\_\_ 11 \_\_\_\_\_ 12 \_\_\_\_\_

REMARKS:

INSPECTED BY [Signature]  
 (OVER)

CO 888

COPY



CITY OF PORTLAND, MAINE  
Department of Building Inspection

### Certificate of Occupancy

Issued to Paul S. Woodworth

Date of Issue November 22, 1948

This is to certify that the building, premises, or part thereof, indicated below, and built—  
~~at 42-88 Bay View Drive~~ at 42-88 Bay View Drive  
under Building Permit No. 48/1259, has had final inspection, has been found to conform substan-  
tially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved  
for occupancy, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire Building

APPROVED OCCUPANCY

One-family Dwelling House  
One-car Garage

Limiting Conditions:

This certificate supersedes  
certificate issued

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from  
owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

AP 82-83 Bay View Drive-1

July 20, 1948

Mr. Paul S. Woodworth  
25 Catherine Street  
Mr. J. H. Kennedy  
105 Froble Street.

Subject: Permit for one-family dwell-  
ing and attached one-car garage at  
82-83 Bay View Drive

Gentlemen:

The permit for the above work is issued herewith to Mr. Kennedy,  
subject to the following:

1. Mr. Kennedy has left word that the garage is going to be built  
for only one car, as is indicated on the plans, and the application has  
accordingly been changed to that effect.

2. If the maximum span between lally columns is not to exceed seven  
feet, the 4x8 girder as given in application will work out all right. How-  
ever, it is difficult to see how this spacing is to be attained if the wood  
girders are to be located in the same positions as the steel girders are  
shown. If a continuous girder is to be provided in such a position that it  
is not directly beneath the carrying partitions, care must be exercised to  
make sure that the carrying partitions will not be located far enough off  
girder to overload the floor timbers and cause undue deflection.

3. Attention is again called to the required weight of 45 pounds  
per 1000 of the corrugated metal ties for brick veneer. Some difficulty  
has arisen in securing this weight tie, and if not obtainable, the use of  
ties of not less than No. 6 gauge wire may be necessary.

Very truly yours,


Inspector of Buildings

AJS/S

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for 84-86 Bay View Drive  
at Paul S. Woodworth Date July 14, 1948

1. In whose name is the title of the property now recorded? Paul S. Woodworth
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? yes  
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? \_\_\_\_\_
4. What is to be maximum projection or overhang of eaves or drip? \_\_\_\_\_
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

  
\_\_\_\_\_

OFFICE TEL. 3-9872

HOUSE TEL. 4-2751

**J. H. Kennedy**  
Contractor and Builder  
Jobbing of All Kinds      Estimates Furnished  
105 Preble Street, Portland, Maine

July 19, 1948

Mr. Warren McDonald  
Inspector of Buildings  
Room 21, City Hall  
Portland, Maine

Subject: Application for Permit for  
Construction of New Dwelling  
at 82-88 Bay View Drive

Dear Mr. McDonald:

Regarding your letter of July 16.

- ✓ 1. On the 10" straight wall foundation referred to, would say that under all brick masonry walls we will use 12 and 14 battered wall, and under garage and terrace 8 and 10 battered wall, no footing.
- ? 2. We will disregard measurements of 8' 6" span on girders and use a 6x8 girder, 7" span on lally columns.
- ✓ 3. The 4x6 sills will be in one piece instead of in two pieces as shown on the plan.
- ✓ 4. Construction of the chimney will be entirely of brick.
- ✓ 5. We will use 9" channel as shown on plan on the bay window opening.
- ✓ 6. We will make rafters on roof of shed dormer 2x8 instead of 2x6.
- ✓ 7. Framing of flat roof for terrace will be 2x10 - 16" on centers. Provided a two-car garage is built, the terrace will not be continued over the additional garage.
- ✓ 8. If framing of the front wall of the main house is questionable, we will run stud from sill to plate.
- ✓ 9. In construction of the 4' overhang of roof on front of building we will either use brackets or truss ends of rafters.
- ✓ 10. Corrugated metal ties will be used to tie all brick work to the new building of wooden construction.
- ✓ 11. Garage walls will be covered with perforated gypsum lath and plaster, as specified in the application.
- ✓ 12. Taken care of in No. 1.

Yours very truly

*J. H. Kennedy*  
J. H. Kennedy

JHK/P



Woodworth, Kennedy ----- 2

July 16, 1943

short studs extending from second floor to plate seems very questionable. The use of a ledger board to support the second floor joists, with studs running from sill to plate, would provide much more sturdy construction.

OK 9. The construction of the 4-foot overhang of roof on front of building does not appear substantial. If rafters are notched over plate as shown, no cantilever action can be counted upon from the overhanging portion. Therefore brackets or braces would seem to be necessary for supporting these overhanging rafters.

OK 10. No provision is shown on plan for tying the brick and stone veneer to the frame of the building. The Building Code specifies that metal wire ties of at least No. 6 gauge, spaced not less than 16" from center to center of every fifth course of brick or equivalent of such spacing for material other than brick be provided. If desired, corrugated metal ties, galvanized or sherardized, of such length as to provide two nails for fastening to the studs, with a minimum width of 3/4 of an inch and of such minimum thickness that at a width no greater than 7/8 of an inch 1000 ties weigh no less than 1/8 pounds, may be used.

OK 11. The garage side of the wall between garage and dwelling is required to be covered from the foundation to underside of garage roof boarding with plaster on metal or perforated Gypsum lath.

OK 12. It is extremely doubtful that the 10" thickness of foundation walls at the top will accommodate the stone and brick veneer shown and a thickness of wall of at least 12" would seem necessary where the veneer occurs.

Answers to all of the above questions should be worked out and indicated either on revised plans or in writing and filed at this office for checking, so that we may be able to issue the permit as soon as all details have been settled in compliance with Code requirements.

Very truly yours,

Inspector of Buildings

AJS/S

AP 32-23 Bay View Drive-I

July 16, 1943

Mr. Paul S. Woodworth  
25 Catherine Street  
Mr. J. H. Kennedy  
105 Preble Street

Subject: Application for permit for construction of new dwelling at 32-23 Bay View Drive

Gentlemen:

There are so many discrepancies between information given in application and that shown on the plans, as well as some needed information which is not shown at all in either place, that in order to make sure that what is planned meets Building Code requirements, we are unable to issue the permit for the above work until all of the following questions have been settled.

OK 1. The 10" straight foundation wall shown on plans is not allowable, a wall with 10" thickness at the top and 12" thickness at the bottom being the minimum permitted by the Building Code. However, in the case of the trench wall beneath the garage and around the terrace the 8" straight wall as shown on plan is allowable if a footing extending at least 4" beyond the wall on either side and at least 12" deep is provided; otherwise the minimum thickness permitted is 8" at the top and 10" at the bottom as given in application.

? 2. Application indicates that an 8x8 girder is to be used in place of the 7" I-beam shown on plans. In order to figure out on the longest spans of about 9' 6", the 8x8 girder, if of hemlock or spruce, must be full size, not dressed; or a 6x10 dressed hemlock or spruce or 8x8 dressed Douglas Fir may be used if desired.

OK 3. The 4x6 sill indicated in application must be all one piece in cross section, not two pieces of 2x6 as shown on plan. If a box type sill, as seems to be indicated on plans were to be used, the bottom member lying flat on the concrete is required to be bolted to the wall at the corners and at intervals of not over six feet along the sides and ends of the building.

OK 4. The construction of the walls of the chimney with 4" brick walls and 4" stone veneer as shown on plan is permissible, but if stone were to be used throughout the thickness of the walls, a minimum thickness of 12" is required.

OK 5. Is the 9" channel shown on plan for support across bay window opening to be used or is wood to be substituted as in the case with the girders for the building? If steel is to be used, a statement covering the design of the beam is required. If wood is to be employed, the size and material of beam to be used should be furnished.

OK 6. The 2x6 rafters for roof of shed dormer on a span of about 14' do not figure out. No less than 2x8, 16" on centers are required at this location.

OK 7. No framing is shown for flat roof over terrace. As a 2-car garage is to be built instead of one for a single car, is the terrace and roof to extend the full width of the garage or is it to be built the same size as shown on plan? What is framing of garage roof to be?

OK 8. The framing of the front wall of main house above second floor level with

WARNING !!!

THIS BUILDING PERMIT IS ISSUED  
SUBJECT TO SPECIAL CONDITION:

THAT NO CONCRETE SHALL BE POURED IN FOUNDATION FORMS AND NO  
LAYING OF UNIT MASONRY IN FOUNDATION WALLS SHALL BE STARTED UNTIL  
NOTICE HAS BEEN GIVEN AT THE DEPARTMENT OF BUILDING INSPECTION OF  
READINESS TO START ACTUAL MASONRY WORK, AND UNTIL RE-CHECK OF  
LOCATION HAS BEEN MADE BY INSPECTOR.

\* \* \*

Original markings of corners of lot and especially stakes on  
street line set by Dept. of Public Works must be kept intact and  
easily accessible for re-check--not covered by excavated earth  
or building materials. Otherwise the "go-ahead" cannot be given.  
Dept. of Public Works cannot re-set their stakes.

\* \* \*

Obviously the notice for re-check must be given at such a time  
as to allow reasonable opportunity to make re-check.

Warren McDonald  
Inspector of Buildings



(RAA) RESIDENCE ZONE - AA  
**APPLICATION FOR PERMIT**

Class of Building or Type of Structure Third Class  
 Portland, Maine, July 14, 1948

**PERMIT ISSUED**  
 JUL 21 1948  
 CITY OF PORTLAND

The undersigned hereby applies for a permit to erect all ~~structures~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 84-86 Bay View Drive (82-88) Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Paul S. McDermott, 25 Gatherkina St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone 3-5639  
 Contractor's name and address J. H. Kennedy, 105 Preble St. No. of sheets 8  
 Architect \_\_\_\_\_ No. families 1  
 Proposed use of building \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ Dwelling and 1 car garage \_\_\_\_\_ Roofing \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_ Estimated cost \$ 12,000.

**General Description of New Work**

To construct 1 1/2 story frame dwelling and garage 70'x34' as per plans  
 brick veneer front -  
 The inside of the garage will be covered, where required by law, with perforated gypsum  
 lath and plaster - no openings between dwelling and garage.  
 Fee \$ 5.00

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and is the name of the heating contractor. **PERMIT TO BE ISSUED TO** J. H. Kennedy  
 Permit Issued with Letter

**Details of New Work**

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes  
 Height average grade to top of plate 8 ft 9' Height average grade to highest point of roof 17'  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories 1 1/2 solid or filled land? solid earth or rock? earth  
 Material of foundation concrete at least 4' below grade 1 1/2' Thickness, top 16" bottom 14" cellar yes  
 Material of underpinning " to sill Kind of roof pitch-gable Rise per foot 11" dormer 4" Roof covering asphalt roofing Class C Und. Lab. \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys brick of lining tile Kind of heat hot w. fuel oil \_\_\_\_\_  
 Framing lumber—Kind hemlock Dressed or full size? dressed  
 Corner posts 4x6 Sills 4x6 Girt or ledger board? \_\_\_\_\_  
 Girders yes Size 3x8 Columns under girders Lally Size 3 1/2" Six \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet. \_\_\_\_\_  
 Joists and rafters: \_\_\_\_\_  
 On centers: 1st floor 2x8 \_\_\_\_\_, 2nd 2x8 \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x8 \_\_\_\_\_  
 Maximum span: 1st floor 16" \_\_\_\_\_, 2nd 16" \_\_\_\_\_, 3rd \_\_\_\_\_, roof 16" \_\_\_\_\_  
 one story building with masonry walls, thickness of walls? \_\_\_\_\_ concrete floor in garage, \_\_\_\_\_ height? \_\_\_\_\_

**If a Garage**

\_\_\_\_\_ cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

**Miscellaneous**

Will work require disturbing of any tree on a public street? \_\_\_\_\_  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? \_\_\_\_\_

ED:  
with letter logs

Signature of owner Paul S. McDermott



Memorandum from Department of Building Inspection, Portland, Maine

At: 86 Bay View Drive

Nov. 27, 1962

J. H. Kennedy  
105 Preble Street

cc to: Mr. Paul Woodworth  
86 Bay View Drive

Dear Mr. Kennedy:

Permit for repair after fire in dwelling at the above named location is issued herewith on condition that any badly burned floor timbers will either be replaced or have new full length timbers placed beside them.

Very truly yours,

Albert J. Sears  
Building Inspection Director

AJS:is



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, November 26, 1962

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 86 Bay View Drive

Owner's name and address Paul Woodworth, 86 Bay View Drive Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_

Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_

Contractor's name and address J H Kennedy 105 Preble St. Telephone \_\_\_\_\_

Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans no Telephone 3-5639

Proposed use of building \_\_\_\_\_ Dwelling \_\_\_\_\_ No. of sheets \_\_\_\_\_

Last use \_\_\_\_\_ Heat \_\_\_\_\_ No. families 1

Material frame No. stories 1 1/2 Style of roof \_\_\_\_\_ No. families 1

Other buildings on same lot \_\_\_\_\_ Roofing \_\_\_\_\_

Estimated cost \$ 5,000.00

Fee \$ 9.00

## General Description of New Work

To repair after fire to former condition, without alterations and without change of use, but if conditions in the areas of repair are found to be dangerously sub-standard of Building Code requirements, both Building Dept. and owner will be notified immediately.

Cause of fire-- unknown  
Date-- week of 19th-(November)  
Any structural damage -no.

Permit Issued with Memo

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

## Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_

Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_

Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_

Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_

Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_

No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Corner posts \_\_\_\_\_ Sills \_\_\_\_\_

Framing Lumber--Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Paul Woodworth  
J H Kennedy

APPROVED:  
C.N. - 11/27/62 - ags.

CS 301

INSPECTION COPY

Signature of owner by: J H Kennedy

FM

(RAA) RESIDENCE ZONE - AA

APPLICATION FOR PERMIT

Class of Building or Type of Structure Installation
Portland, Maine, Sept. 24, 1948

PERMIT ISSUED

01722
25 1948

CITY of PORTLAND



To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect after repairs to install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 84 Bay View Drive Within Fire Limits? no Dist. No.
Owner's name and address Paul Woodworth, 84 Bay View Drive Telephone
Lessee's name and address Telephone
Contractor's name and address York Electric Co., 220 Middle Street Telephone 2-4757
Architect Specifications Plans No. of sheets
Proposed use of building Dwelling house No. families 1
Last use No. families 1
Material wood No. stories 2 Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ Fee \$ 1.00

General Description of New Work

To install ventilating system for kitchen first floor, with duct work.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO York Electric Co.

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing lumber—Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Girders Size Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Paul Woodworth
York Electric Co.

Signature of owner by: [Signature]

INSPECTION COPY





FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Aug. 25, 1948

PERMIT ISSUED

01520  
AUG 27 1948

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 84-86 Bay View Drive Use of Building Dwelling No. Stories 1 1/2 New Building  
Name and address of owner of appliance Paul Woodworth Catherine St.  
Installer's name and address Augustine K. Reich 515 Stevens St. Telephone 3-5528

General Description of Work

To install Forced hot water heating system oil fired

IF HEATER, OR POWER BOILER

Location of appliance or source of heat cellar Type of floor beneath appliance concrete  
If wood, how protected? Kind of fuel oil  
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace 3'  
From top of smoke pipe 5' From front of appliance 6' From sides or back of appliance 6'  
Size of chimney flue 8x12 Other connections to same flue none  
If gas fired, how vented? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Fitzgibbon-Hart Labeled by underwriter's laboratories? yes  
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom  
Type of floor beneath burner concrete  
Location of oil storage cellar Number and capacity of tanks 1-275  
If two 275-gallon tanks, will three-way valve be provided?  
Will all tanks be more than five feet from any flame? yes How many tanks fire proofed?  
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Kind of fuel Type of floor beneath appliance  
If wood, how protected?  
Minimum distance to wood or combustible material from top of appliance  
From front of appliance From sides and back From top of smokepipe  
Size of chimney flue Other connections to same flue  
Is hood to be provided? If so, how vented?  
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:  
215. E88 8/26/48

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Signature of Installer Augustine K. Reich

INSPECTION COPY



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date 3/27/92, 19  
 Receipt and Permit number 3913

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 86 Bayview Dr  
 OWNER'S NAME: Alan McKee ADDRESS: \_\_\_\_\_

OUTLETS:		FEES
Receptacles <u>10</u> Switches <u>6</u> Plugmold _____ ft. TOTAL <u>16</u> .....		<u>3.20</u>
FIXTURES: (number of)		
Incandescent <u>6</u> Fluorescent <u>2</u> (not strip) TOTAL <u>8</u> .....		<u>1.60</u>
Strip Fluorescent _____ ft. ....		
SERVICES:		
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____ ..		
METERS: (number of) _____ .....		
MOTORS: (number of)		
Fractional _____ .....		
1 HP or over _____ .....		
RESIDENTIAL HEATING:		
Oil or Gas (number of units) _____ .....		
Electric (number of rooms) _____ .....		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler) _____ .....		
Oil or Gas (by separate units) _____ .....		
Electric Under 20 kws _____ Over 20 kws _____ .....		
APPLIANCES: (number of)		
Ranges _____ <u>1</u> _____ Water Heaters _____ .....		
Cool Tops _____ Disposals _____ .....		
Wall Ovens _____ Dishwashers _____ .....		
Dryers _____ Compactors _____ .....		
Fans _____ Others (denote) _____ .....		
TOTAL <u>1</u> .....		<u>2.00</u>
MISCELLANEOUS: (number of)		
Branch Panels _____ .....		
Transformers _____ .....		
Air Conditioners Central Unit _____ .....		
Separate Units (windows) _____ .....		
Signs 20 sq. ft. and under _____ .....		
Over 20 sq. ft. _____ .....		
Swimming Pools Above Ground _____ .....		
In Ground _____ .....		
Fire/Burglar Alarms Residential _____ .....		
Commercial _____ .....		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ .....		
over 30 amps _____ .....		
Circus, Fairs, etc. _____ .....		
Alterations to wires _____ .....		
Repairs after fire _____ .....		
Emergency Lights, battery _____ .....		
Emergency Generators _____ .....		

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... INSTALLATION FEE DUE: \_\_\_\_\_  
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) ..... DOUBLE FEE DUE: \_\_\_\_\_  
 TOTAL AMOUNT DUE: 15.00  
 minimum fee

INSPECTION:  
 Will be ready on \_\_\_\_\_, 19\_\_; or Will Call X  
 CONTRACTOR'S NAME: Carmine Morelli, Jr.  
 ADDRESS: Box 210; Thompson Lk Shrs; Casco; ME  
 TEL.: 627-4967  
 MASTER LICENSE NO.: #03913 SIGNATURE OF CONTRACTOR: \_\_\_\_\_  
 LIMITED LICENSE NO.: \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN



Permit # **923573** City of Portland **BUILDING PERMIT APPLICATION** Fee \$25. Zone \_\_\_\_\_ Map # \_\_\_\_\_ Lot# \_\_\_\_\_  
 Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Alan R. McKee Phone # 879-1494  
 Address: 86 Bayview Dr.; Ptld, ME 04103  
 LOCATION OF CONSTRUCTION 86 Bayview Dr.  
 Contractor: William Simonds Sub.: \_\_\_\_\_  
 Address: \_\_\_\_\_ Phone # \_\_\_\_\_  
 Est. Construction Cost: 1300 Proposed Use: 1-fam w ext renov  
 Past Use: 1-fam  
 # of Existing Res. Units \_\_\_\_\_ # of New Res. Units \_\_\_\_\_  
 Building Dimensions L \_\_\_\_\_ W \_\_\_\_\_ Total Sq. Ft. \_\_\_\_\_  
 # Stories: \_\_\_\_\_ # Bedrooms \_\_\_\_\_ Lot Size: \_\_\_\_\_  
 Is Proposed Use: Seasonal \_\_\_\_\_ Condominium \_\_\_\_\_ Conversion \_\_\_\_\_  
 Explain Conversion exterixor renovations - door

**For Official Use Only**

Date 3/26/92 Subdivision Name APR 16 1992  
 Inside Fire Limits \_\_\_\_\_ Lot \_\_\_\_\_  
 Bldg Code \_\_\_\_\_ Ownership: \_\_\_\_\_  
 Time Limit \_\_\_\_\_  
 Estimated Cost 1300

**PERMIT ISSUED**  
**CITY OF PORTLAND**

**Foundation:**  
 1. Type of Soil: \_\_\_\_\_  
 2. Set Backs - Front \_\_\_\_\_ Rear \_\_\_\_\_ Side(s) \_\_\_\_\_  
 3. Footings Size: \_\_\_\_\_  
 4. Foundation Size: \_\_\_\_\_  
 5. Other \_\_\_\_\_

**Floor:**  
 1. Sills Size: \_\_\_\_\_ Sills must be anchored.  
 2. Girder Size: \_\_\_\_\_  
 3. Lally Column Spacing: \_\_\_\_\_ Size: \_\_\_\_\_  
 4. Joists Size: \_\_\_\_\_ Spacing 16" O.C.  
 5. Bridging Type: \_\_\_\_\_ Size: \_\_\_\_\_  
 6. Floor Sheathing Type: \_\_\_\_\_ Size: \_\_\_\_\_  
 7. Other Material: \_\_\_\_\_

**Exterior Walls:**  
 1. Studding Size \_\_\_\_\_ Spacing \_\_\_\_\_  
 2. No. windows \_\_\_\_\_  
 3. No. Doors \_\_\_\_\_  
 4. Header Sizes \_\_\_\_\_ Span(s) \_\_\_\_\_  
 5. Bracing: Yes \_\_\_\_\_ No \_\_\_\_\_  
 6. Corner Posts Size \_\_\_\_\_  
 7. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_  
 8. Sheathing Type \_\_\_\_\_ Size \_\_\_\_\_  
 9. Siding Type \_\_\_\_\_ Weather Exposure \_\_\_\_\_  
 10. Masonry Materials \_\_\_\_\_  
 11. Metal Materials \_\_\_\_\_

**Interior Walls:**  
 1. Studding Size \_\_\_\_\_ Spacing \_\_\_\_\_  
 2. Header Sizes \_\_\_\_\_ Span(s) \_\_\_\_\_  
 3. Wall Covering Type \_\_\_\_\_  
 4. Fire Wall if required \_\_\_\_\_  
 5. Other Materials \_\_\_\_\_

**Ceiling:**  
 1. Ceiling Joists Size: \_\_\_\_\_  
 2. Ceiling Strapping Size \_\_\_\_\_ Spacing \_\_\_\_\_  
 3. Type Ceilings: \_\_\_\_\_  
 4. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_  
 5. Ceiling Height: \_\_\_\_\_

**Roof:**  
 1. Truss or Rafter Size \_\_\_\_\_ Span \_\_\_\_\_ Action: Approved  
 2. Sheathing Type \_\_\_\_\_ Size \_\_\_\_\_  
 3. Roof Covering Type \_\_\_\_\_

**Chimneys:**  
 Type: \_\_\_\_\_ Number of Fire Places \_\_\_\_\_  
 Date: \_\_\_\_\_ Signature: \_\_\_\_\_

**Heating:**  
 Type of Heat: \_\_\_\_\_

**Electrical:**  
 Service Entrance Size: \_\_\_\_\_ Smoke Detector Required Yes \_\_\_\_\_ No \_\_\_\_\_

**Plumbing:**  
 1. Approval of soil test if required Yes \_\_\_\_\_ No \_\_\_\_\_  
 2. No. of Tubs or Showers \_\_\_\_\_  
 3. No. of Flushes \_\_\_\_\_  
 4. No. of Lavatories \_\_\_\_\_  
 5. No. of Other Fixtures \_\_\_\_\_

**Swimming Pools:**  
 1. Type: \_\_\_\_\_  
 2. Pool Size: \_\_\_\_\_ x \_\_\_\_\_ Square Footage \_\_\_\_\_  
 3. Must conform to National Electrical Code and State Law.

Permit Received By Louise E. Chase  
 Signature of Applicant Alan R. McKee Date 3/26/92  
 CEO's District 6

CONTINUED TO REVERSE SIDE [Signature]  
 Ivory Tag - CEO

White - Tax Assessor

923573

Permit # 923573 City of Portland BUILDING PERMIT APPLICATION Fee \$25. Zone \_\_\_\_\_ Map # \_\_\_\_\_ Lot# \_\_\_\_\_  
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Alan R. McKee Phone # 879-1494  
Address: 86 Bayview Dr.; Ptd, ME 04103  
LOCATION OF CONSTRUCTION 86 Bayview Dr.  
Contractor: William Simonds Sub: \_\_\_\_\_  
Address: \_\_\_\_\_ Phone # \_\_\_\_\_  
Est. Construction Cost: 1300 Proposed Use: 1-fam w ext renov  
# of Existing Res. Units \_\_\_\_\_ # of New Res. Units \_\_\_\_\_  
Building Dimensions L \_\_\_\_\_ W \_\_\_\_\_ Total Sq. Ft. \_\_\_\_\_  
# Stories: \_\_\_\_\_ # Bedrooms \_\_\_\_\_ Lot Size: \_\_\_\_\_  
Is Proposed Use: Seasonal \_\_\_\_\_ Condominium \_\_\_\_\_ Conversion \_\_\_\_\_  
Explain Conversion exterior renovations - door

**PERMIT ISSUED**  
For Official Use Only  
Date 3/26/92 Subdivision \_\_\_\_\_  
Inside Fire Limits \_\_\_\_\_ Name APR 16 1992  
Bldg Code \_\_\_\_\_ Lot \_\_\_\_\_  
Time Limit \_\_\_\_\_ Ownership \_\_\_\_\_  
Estimated Cost: 1300  
**CITY OF PORTLAND**

Zoning: Street Frontage Provided: \_\_\_\_\_  
Provided Setbacks: Front \_\_\_\_\_ Back \_\_\_\_\_ Side \_\_\_\_\_  
Review Required:  
Zoning Board Approval: Yes \_\_\_\_\_ No \_\_\_\_\_ Date: \_\_\_\_\_  
Planning Board Approval: Yes \_\_\_\_\_ No \_\_\_\_\_ Date: \_\_\_\_\_  
Conditional Use: \_\_\_\_\_ Variance \_\_\_\_\_ Site Plan \_\_\_\_\_ Subdivision \_\_\_\_\_  
Shoreland Zoning Yes \_\_\_\_\_ No \_\_\_\_\_ Floodplain Yes \_\_\_\_\_ No \_\_\_\_\_  
Special Exception \_\_\_\_\_  
Other WPA 476-92 (Explain)

Foundation:  
1. Type of Soil: \_\_\_\_\_  
2. Set Backs - Front \_\_\_\_\_ Rear \_\_\_\_\_ Side(s) \_\_\_\_\_  
3. Footings Size: \_\_\_\_\_  
4. Foundation Size: \_\_\_\_\_  
5. Other \_\_\_\_\_

Floor:  
1. Sills Size: \_\_\_\_\_ Sills \_\_\_\_\_ anchored.  
2. Girder Size: \_\_\_\_\_  
3. Lally Column Spacing: \_\_\_\_\_ Size: \_\_\_\_\_  
4. Joists Size: \_\_\_\_\_ Spacing 16" O.C.  
5. Bridging Type: \_\_\_\_\_ Size: \_\_\_\_\_  
6. Floor Sheathing Type: \_\_\_\_\_ Size: \_\_\_\_\_  
7. Other Material: \_\_\_\_\_

Exterior Walls:  
1. Studding Size \_\_\_\_\_ Spacing \_\_\_\_\_  
2. No. windows \_\_\_\_\_  
3. No. Doors \_\_\_\_\_  
4. Header Sizes \_\_\_\_\_ Span(s) \_\_\_\_\_  
5. Bracing: Yes \_\_\_\_\_ No \_\_\_\_\_  
6. Corner Posts Size \_\_\_\_\_  
7. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_  
8. Sheathing Type \_\_\_\_\_ Size \_\_\_\_\_  
9. Siding Type \_\_\_\_\_ Weather Exposure \_\_\_\_\_  
10. Masonry Materials \_\_\_\_\_  
11. Metal Materials \_\_\_\_\_

Interior Walls:  
1. Studding Size 11-1/2" Spacing \_\_\_\_\_  
2. Header Sizes 11-1/2" Span(s) \_\_\_\_\_  
3. Wall Covering Type \_\_\_\_\_  
4. Fire Wall if required \_\_\_\_\_  
5. Other Materials \_\_\_\_\_

Ceiling:  
1. Ceiling Joists Size: \_\_\_\_\_  
2. Ceiling Strapping Size \_\_\_\_\_ Spacing \_\_\_\_\_ Hot in District nor Landmark.  
3. Type Ceilings: \_\_\_\_\_ Does not require review.  
4. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_  
5. Ceiling Height: \_\_\_\_\_ Requires Review.

Roof:  
1. Truss or Rafter Size \_\_\_\_\_ Span \_\_\_\_\_ Action: \_\_\_\_\_  
2. Sheathing Type \_\_\_\_\_ Size \_\_\_\_\_  
3. Roof Covering Type \_\_\_\_\_ Approved with Conditions  
Chimneys: \_\_\_\_\_  
Type: \_\_\_\_\_ Number of Fire Places \_\_\_\_\_ Date: \_\_\_\_\_  
Heating: \_\_\_\_\_  
Type of Heat: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Service Entrance Size: \_\_\_\_\_ Smoke Detector Required Yes \_\_\_\_\_ No \_\_\_\_\_

Plumbing:  
1. Approval of soil test if required Yes \_\_\_\_\_ No \_\_\_\_\_  
2. No. of Tubs or Showers \_\_\_\_\_  
3. No. of Flushes \_\_\_\_\_  
4. No. of Lavatories \_\_\_\_\_  
5. No. of Other Fixtures \_\_\_\_\_

Swimming Pools:  
1. Type: \_\_\_\_\_  
2. Pool Size: \_\_\_\_\_ x \_\_\_\_\_ Square Footage \_\_\_\_\_  
3. Must conform to National Electrical Code and State Law.

Permit Received By Louise E. Chase  
Signature of Applicant Alan R. McKee Date 3/26/92  
CEO's District 6 William Simonds

CONTINUED TO REVERSE SIDE 6 WPA 476-92  
Ivory Tag - CEO

White - Tax Assessor

PLOT PLAN



**FEES (Breakdown From Front)**  
 Base Fee \$ 25  
 Subdivision Fee \$ \_\_\_\_\_  
 Site Plan Review Fee \$ \_\_\_\_\_  
 Other Fees \$ \_\_\_\_\_  
 (Explain) \_\_\_\_\_  
 Late Fee \$ \_\_\_\_\_

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS 8/20/92 OK AC  
AK

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

Alan R. McLu 879-1494  
 SIGNATURE OF APPLICANT ADDRESS PHONE NO.  
 RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE NO.

PAGE  
1.C

PREPARED BY  
DATE

RECEIVED

MAR 26 1992

DEPT. OF BUILDING INSPECTION  
CITY OF PORTLAND

