

27-33 CANCO ROAD

Full cut 0201 • Half cut 0202 • 1/4 cut 0203 • 1/8 cut 0204 • 1/16 cut 0205



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, March 18, 1969

PERM. ISSUED

MAR 18 1969

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 33 Canco Road Use of Building Dwelling No. Stories 1 1/2 New Building Existing
Name and address of owner of appliance Clayton Duplasea, 33 Canco Road
Installer's name and address Randall & McAllister 84 Commercial St. Telephone 774-4554

General Description of Work

To install Oil-fired forced warm air furnace(replacement)

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 4'
From top of smoke pipe 3' From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 12x12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Space-Conditioner-gunttype Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 existing
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

0.15 2.8.8. 3/18/69

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Randall McAllister

CS 300

INSPECTION COPY

Signature of Installer

by: MR Kilgore

Handwritten initials

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. 57635
 Issued 3/18/69

Portland, Maine March 7, 1969, 19...

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Mr. Clayton Duplisea, 33 Canco Rd. Tel.
 Contractor's Name and Address Randall & Mc Allister, 84 Comm. St. Tel.
 Location 33 Canco Road Use of Building Dwelling
 Number of Families 1 Apartments ... Stores Number of Stories 1-1/2
 Description of Wiring: New Work Additions .. Alterations ..
Replace Forced Warm Air Furnace-Install Model OUF-85 Space Conditioning Oil Furnace
 Pipe ... Cable ... Metal Molding ... BX Cable Plug Molding (No. of feet) ..
 No. Light Outlets ... Plugs ... Light Circuits Plug Circuits
 FIXTURES: No. Light Switches ... Fluor. or Strip Lighting (No. feet)
 SERVICE: Pipe Cable Underground No. of Wires Size ..
 METERS: Relocated .. Added Total No. Meters ..
 MOTORS: Number ... Phase H. P. Amps Volts Starter ..
 HEATING UNITS: Domestic (Oil) 1 No. Motors 2 Phase 1 H.P. 1/8 & 1/4
 Commercial (Oil) No. Motors Phase H.P. ...
 Electric Heat (No. of Rooms)
 APPLIANCES: No. Ranges ... Watts Brand Feeds (Size and No.)
 Elec. Heaters ... Watts ..
 Miscellaneous ... Watts Extra Cabinets or Panels
 Transformers ... Air Conditioners (No. Units) ... Sigs (No. Units)
 Will commence Mar. 7 19 69 Ready to cover in 19 ... Inspection Mar. 10 19 69
 Amount of Fee \$ 2.00 Signed Randall & Mc Allister

DO NOT WRITE BELOW THIS LINE

SERVICE METER GROUND
 VISITS: 1 .. 2 .. 3 .. 4 .. 5 .. 6 ..
 .. 7 .. 8 .. 9 .. 10 .. 11 .. 12 ..

REMARKS:

INSPECTED BY J. W. ...
 (OVER)



(RC) RESIDENCE ZONE - C
APPLICATION FOR PERMIT

PERMIT ISSUED
OCT 6 1952
CITY of PORTLAND

Class of Building or Type of Structure Third Class

Portland, Maine, September 29, 1952

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 33 Canco Road Within Fire Limits? no Dist. No. _____
Owner's name and address Clayton Duplissa, 33 Canco Rd. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone _____
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building Dwelling No. families 1
Last use _____ " _____ No. families 1
Material frame No. stories 1 1/2 Heat _____ Style of roof pitch Roofing _____
Other buildings on same lot _____
Estimated cost \$ 200. Fee \$ 2.00

General Description of New Work

To finish off two bedrooms on second floor -
2x4 studs, 16" O.C., sheetrock for ~~partitions~~ and ceiling
2x6 floor joists, 16" O.C. " partitions
existing stairway

Permit Issued with Letter

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Clayton Duplissa

NOTES

10/7/52 -

Ceiling ready for cleaning
ins. of [unclear]

10/9/52 - Suff. G.T. to close

Told Mrs Duplises the
writing was signed when
lunch wall construction was
ready. P.S.B.

10/18/52 - Will come just below fire stops

no required at top of base wall
They plan to start taking the
entire scope of roof down to
in the future put knee wall in
I'd like it would be good to put
fire stops in some of locally
made where they are not so tight.
They will not have to tear wall
out when putting knee wall
in, with gutters [unclear]

11/21/52 - Suff. G.T.
to close in support
to it, following
no wiring to [unclear]
covered [unclear] [unclear]
approval. P.S.B.

Permit No. 521711
Location 33 Camino Real
Owner Clayton D. Blinn
Date of permit 10/21/52
Notif. closing-in 11/21/52
Inspr. closing-in 11/21/52
Final Notif.
Final Inspr.
Cert. of Occupancy issued

12/3

TABLE

No.	Description	Quantity	Unit	Price	Total
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

AP 33 Canco Road

October 6, 1952

Mr. Clayton Duplisea
33 Canco Road
Portland, Maine

Dear Mr. Duplisea:-

Issuance of your permit to cover finishing off two bedrooms on the second floor of your dwelling at 33 Canco Road has been delayed, in the midst of a great many applications for all sorts of jobs, because of a question as to the size and consequently the strength of the floor joists in existing second floor. The permit is now issued subject to the following conditions. If these are not understood, or, if you feel unable to comply with them, it is important that you refrain from starting the work and contact this office for explanation or adjustment.

Your application indicates that the second floor joists are only 2x6, 16 in. from center to center. These would be on a span of at least 12 ft., and would not be strong enough. The application for the original permit when the dwelling was constructed, however, shows these second floor joists to be 2x8, 16 in. from center to center. If the joists are actually 2x8, 16 in. from center to center, it is alright to proceed. If not, you should file an application for amendment to the permit now issued, showing how you will reinforce the floor joists. With the application for amendment should be filed a plan to scale showing a cross section of the attic space, with all the details as to the span between outside wall and central bearing partition (probably this is in the first story beneath the ridge of the roof); the location of the dwarf or "knee" partitions on each side to form the walls of the new rooms; the material of the present first story ceiling and the pitch per foot of the roof and its total height from attic floor to ridge.

Before any part of the new partitions and any part of the new ceiling is covered, you are required to notify this office of readiness for inspection and not to cover up any portion until our inspector has approved the job by leaving his green tag there. When this notice is given, any new plumbing or any new electric wiring should be all in place and should have been inspected and approved by the plumbing and electrical inspectors respectively. Also before notice for inspection is given all required fire stops should be in place. The principal places where these fire stops are required are over the "knee" partitions between the rafters, cut in tightly so that a fire taking place between these partitions and the eaves would not spread quickly up into the shallow attic over the new ceiling. Especially if the present attic where the roof is or is to be insulated, you should get competent advice about ventilating the tight concealed space above the new ceiling and the concealed spaces between "knee" partitions and the eaves. Otherwise you are likely to have extensive water or condensation develop, doing damage to the home and plaguing you generally.

It is assumed that there will be at least one good sized window in each of the two new rooms.

P. S. Also required in new ceiling is a covered hatchway or scuttle, 2 ft. by 3 ft. to give access to blind attic in case of need.

WMCD/G

Very truly yours,

Inspector of Buildings



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, January 5, 1951

PERMIT ISSUED 00357 MAR 13 1951 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

N-~~47~~ 455

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location ... Canco Road ... Use of Building 1-family dwelling No. Stories ... 1 1/2 New Building Existing " Name and address of owner of appliance Maurice Brown, Cumberland Center, contractor. Installer's name and address ... Randall & McAllister, 24 Commercial Street ... Telephone 3-2941

General Description of Work

To install forced warm air heating system and oil burning equipment

IF HEATER, OR POWER BOILER

Location of appliance or source of heat ... basement ... Type of floor beneath appliance concrete If wood, how protected? ... Kind of fuel ... oil ... Minimum distance to wood or combustible material, from top of appliance or casing top of furnace 21 1/2" plenum chamber From top of smoke pipe 2' ... From front of appliance over 4' ... From sides or back of appliance ... over 3' Size of chimney flue 8x12 ... Other connections to same flue ... none If gas fired, how vented? ... Rated maximum demand per hour

IF OIL BURNER

Name and type of burner ... Timken ... Labelled by underwriters' laboratories? ... yes Will operator be always in attendance? ... Does oil supply line feed from top or bottom of tank? ... bottom Type of floor beneath burner ... basement ... concrete ... Location of oil storage ... basement ... Number and capacity of tanks ... 1-275 gal. If two 275-gallon tanks, will three-way valve be provided? ... Will all tanks be more than five feet from any flame? ... yes ... How many tanks fire proofed? ... Total capacity of any existing storage tanks for furnace burners ... none

IF COOKING APPLIANCE

Location of appliance ... Kind of fuel ... Type of floor beneath appliance ... If wood, how protected? ... Minimum distance to wood or combustible material from top of appliance ... From front of appliance ... From sides and back ... From top of smokepipe ... Size of chimney flue ... Other connections to same flue ... Is hood to be provided? ... If so, how vented? ... If gas fired, how vented? ... Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

All installed

Amount of fee enclosed? ... 2.00 (\$2.00 for one heater, etc., 20 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: O.K. E.S.S. 3/14/51

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? ... yes Randall & McAllister

INSPECTION COPY

Signature of Installer by: Arthur P. G.

NOTES

2/26/51 - Cold air return to be connected
+ shield w/te to part and platinum chamber

3/12/51 - W. N. Lane & S. S. P. P.

Permit No. 61/357
Location 2733 Canal Road
Owner Marshall Green
Date of Permit 3/13/51
Approved 3/15/51

- 1. Fill Pipe
- 2. Vent Pipe
- 3. Kind of Heat
- 4. Burner Regulator & Supports
- 5. Name & Label
- 6. Stack Control
- 7. High Limit Control
- 8. Remote Control
- 9. Piping Support & Protection
- 10. Valves in Supply Line
- 11. Capacity of Tanks
- 12. Tank Rigidity & Supports
- 13. Tank Distance
- 14. Oil Gauge
- 15. Instruction Card
- 16.
- 17.
- 18.
- 19.
- 20.
- 21.
- 22.
- 23.
- 24.
- 25.
- 26.
- 27.
- 28.
- 29.
- 30.
- 31.
- 32.
- 33.
- 34.
- 35.
- 36.
- 37.
- 38.
- 39.
- 40.
- 41.
- 42.
- 43.
- 44.
- 45.
- 46.
- 47.
- 48.
- 49.
- 50.



RESIDENCE ZONE - C
APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, August 10, 1950

RECEIVED
AUG 11 1950
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~at the location of~~ the following building ~~specifications~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 27-33 Canco Road Within Fire Limits? no Dist. No. _____
Owner's name and address George E. Meloon, 963 Washington Avenue Telephone _____
Lessee's name and address MELVIN ST. PLANA Telephone _____
Contractor's name and address Haurice Brown, Cumberland Center Telephone _____
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building dwelling house and 1-car garage No. families 1
Last use _____ No. families _____
Material No stories Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 6,500 Fee \$ 7.00

General Description of New Work

To construct 1 1/2-story frame dwelling house 24' x 30' with open breezeway 6' x 6' and attached garage 12' x 20'.

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Haurice Brown

Details of New Work

Is any plumbing involved in this work? yes Gar. _____ Is any electrical work involved in this work? yes Gar. _____
Height average grade to top of plate 10' _____ 8' _____ Height average grade to highest point of roof. 22' _____ 12' _____
Size, front 30' depth 24' No. stories 1 1/2 solid or filled land? ? earth or rock? ?
Material of foundation concrete at least 4' below grade Thickness, top 10" bottom 12" cellar yes
Material of underpinning _____ to sill _____ Height _____ Thickness _____
Kind of roof Pitch-gable Rise per foot 9" Roof covering Asphalt Class C Unq Lab
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat warm air fuel oil
Framing lumber--Kind hemlock _____ Dressed or full size? dressed
Corner posts 4x6 Sills 2x8 _____ Girt or ledger board? _____ Size _____
Girders yes Size 6x8 Columns under girders Lally Size 3 1/2" Max. on centers 8'
Studs (outside walls and carrying partitions) 2x4-16" O. C Bridging in every floor and flat roof span over 8 feet
Joists and rafters: 1st floor 2x3 _____, 2nd 2x8 _____, 3rd _____, roof 2x8 _____ Gar. 2x6 _____
On centers. 1st floor 16" _____, 2nd 16" _____, 3rd _____, roof 16" _____ 24" _____
Maximum span: 1st floor 12' _____, 2nd 12' _____, 3rd _____, roof 12' _____ 6' _____
If one story building with masonry walls, thickness of walls? _____ height? _____
Concrete floor in garage _____
If a Garage _____
No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
George Meloon

INSPECTION COPY Signature of owner by George Meloon

WARNING !!!

THIS BUILDING PERMIT IS ISSUED
SUBJECT TO SPECIAL CONDITION:

THAT NO CONCRETE SHALL BE Poured IN FOUNDATION FORMS AND NO
LAYING OF UNIT MASONRY IN FOUNDATION WALLS SHALL BE STARTED UNTIL
NOTICE HAS BEEN GIVEN AT THE DEPARTMENT OF BUILDING INSPECTION OF
READINESS TO START ACTUAL MASONRY WORK, AND UNTIL RE-CHECK OF
LOCATION HAS BEEN MADE BY INSPECTOR.

* * *

Original markings of corners of lot and especially stakes on
street line set by Dept. of Public Works must be kept intact and
easily accessible for re-check--not covered by excavated earth
or building materials. Otherwise the "go-ahead" cannot be given.
Dept. of Public Works cannot re-set their stakes.

* * *

Obviously the notice for re-check must be given at such a time
as to allow reasonable opportunity to make re-check.

Warren McDonald
Inspector of Buildings

COPY



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

Issued to **George H. Meloon**

Date of Issue **March 12, 1951**

This is to certify that the building, premises, or part thereof, indicated below, and built—
~~located—changed as to use at~~ **27-33 Carco Road**
under Building Permit No. **50/1470**, has had final inspection, has been found to conform substan-
tially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved
for occupancy, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire Building

APPROVED OCCUPANCY

**One-family Dwelling house
One-car Garage**

Limiting Conditions:

This certificate supersedes
certificate issued **1/21/51**

Charles Smith
INSPECTOR **CS**

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from
owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

AP 27-33 Canco Rd.

August 11, 1950

Mr. Maurice S. Brown,
Cumberland Center,
Maine

copy to George H. Peloon,
963 Washington Ave.

Dear Mr. Brown:

In trying to check the staking out of the location of the proposed dwellings with attached garages on the lots at 27-33 Canco Road and at 114-118 Carlyle Road, an inspector from this department reports that the locations of the buildings are not marked clearly enough on the lots to enable him to determine if they are in compliance with Zoning Ordinance requirements. Apparently the garages and breezeways are not staked out at all and in the case of at least one lot the position of the dwelling on the lot is at considerable variance from that shown on the location plan. One of the buildings, indicated for 114-118 Carlyle Road, is actually staked out on the lot at 120-124 Carlyle Road. This is the lot on which you plan to build it instead of as indicated, which changes the address on the application accordingly.

It is necessary that the full outlines of the buildings, including the breezeways and garages, be staked out on the ground so that we may determine whether or not they comply with Zoning Ordinance requirements before permits for construction of the buildings may be issued. We have not yet had opportunity to check the plans filed with the applications against Building Code requirements but will do so as soon as possible.

Very truly yours,

Warren McDonald
Inspector of Buildings

AJS/H

AP 27-33 Canco Road-I
AP 120-124 Carlyle Road-I

August 21, 1950

Mr. Maurice S. Brown
Cumberland Center, Maine
Mr. George H. Meloon
963 Washington Avenue

Gentlemen:

Permits for construction of two dwellings with attached garages, one at 27-33 Canco Road, corner of Carlyle Road and the other on the adjoining lot at 120-124 Carlyle Road, are issued herewith to Mr. Brown who filed the applications for permits. These permits are issued on the basis of the plans filed with the applications but subject to the following:

1. It is possible that these buildings ^{this building} will rest partly on ledge and partly on ledge. It is best if possible where ledge is encountered to construct the entire wall on ledge. However, if this is not feasible, some means of reinforcing the wall where it leaves the ledge and rests on earth should be provided to prevent cracking of the wall.
2. There is no indication on the plans as to the thickness of the foundation wall of garage. The minimum thickness specified by the Building Code is 8" at the top and 10" at the grade and it is required to extend at least 4' below the finished grade or to ledge. The 4x6 sill of garage is required to be bolted to the foundation wall.
3. Nothing is shown on the plans as to the foundation and framing of front platform and steps. Cedar posts, pipe columns or concrete piers may be used for supporting this structure but in any case they are required to extend at least 4' below grade or to ledge. If pipe columns are used, they are required to have a minimum diameter of 3". Concrete piers are required to be 8" square at the top and 10" square at the bottom.
4. The sills of breezeway and front steps are required to be at least 4x6, all one piece in cross section, with the floor joists supported on top of them or notched over nailing strips spiked to the sides of them.
5. Besides the notification for inspection of forms for foundation walls before pouring of concrete into them, notification for inspections by this department are required before any lath or wallboard is applied to walls; partitions or ceilings and again before the buildings are used for living quarters. If everything is found in compliance with law at the time of this latter or "final" inspection, the certificate of occupancy, without which use of the building is unlawful, will be issued.

Very truly yours,

Warren McDonald
Inspector of Buildings

AJS/G

P. S. Since the two buildings are to be constructed according to the same set plans, these plans have been designated as Meloon Standard Plan A and reference may be made to this designation in filing other applications for construction of dwellings in accordance with the same plans, thus avoiding the necessity of filing other plans.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for dwelling and garage Date 8/10/50
at Canco Road

1. In whose name is the title of the property now recorded? George A. Wilson
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? _____
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the size, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Maurice A. Brown

27-33 CANCO ROAD





APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

filmed

Date April 10, 19 84
 Receipt and Permit number B-21964

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 33 Canco Road
 OWNER'S NAME: Mrs. Karatsanos ADDRESS: lives there

3000
 RECEIVED
 DEPT. OF BUILDING INSPECTIONS SERVICES

OUTLETS: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____

FIXTURES: (number of) Incandescent _____ Flourescent _____ (not strip) TOTAL _____
 Str _____ flourescent _____ ft. _____

SERVICE: Underground _____ Temporary _____ TOTAL amperes 100 3.00

METERS: (number of) 1 _____ .50

MOTORS: (number of) Fractional _____ 1 HP or over _____

RESIDENTIAL HEATING: Oil or Gas (number of units) _____ Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____ Oil or Gas (by separate units) _____ Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of) Ranges _____ Water Heaters _____
 Cook Tops _____ Disposals _____
 Wall Ovens _____ Dishwashers _____
 Dryers _____ Compactors _____
 Fans _____ Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of) Branch Panels _____
 Transformers _____
 Air Conditioners Central Unit _____
 Separate Units (windows) _____
 Signs 20 sq. ft. and under _____
 Over 20 sq. ft. _____
 Swimming Pool Above Ground _____
 In Ground _____
 Fire/Burglar Alarms Residential _____
 Commercial _____
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____
 over 30 amps _____
 Circus, Fairs, etc. _____
 Alterations to wires _____
 Repairs after fire _____
 Emergency Lights, battery _____
 Emergency Generators _____

INSTALLATION FEE DUE: _____
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) ... _____
 TOTAL AMOUNT DUE: 3.50
 min 5.00

INSPECTION: Will be ready on _____, 19__; or Will Call
 CONTRACTOR'S NAME: Bradley Electric
 ADDRESS: 55 Gardner Ave. Gorham
 TEL.: _____
 MASTER LICENSE NO.: 03134 SIGNATURE OF CONTRACTOR: Robert Bradley
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

filmed

Date April 10, 19 84
 Receipt and Permit number P 2196

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications.

LOCATION OF WORK: 33 Canco Road
 OWNER'S NAME: Mrs. Karatsanos ADDRESS: Lives there

3100
 3100
 3100
 FEES

OUTLETS: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____

FIXTURES (number of): Incandescent _____ Fluorescent _____ (not strip) TOTAL _____
 Strip Fluorescent _____ ft. _____

SERVICES: Overhead X Underground _____ Temporary _____ TOTAL amount _____ 3.00

METERS: (number of) 1 _____ 50

MOTORS: (number of)
 Fractional _____
 1 HP or over _____

RESIDENTIAL HEATING: Oil or Gas (number of units) _____
 Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____
 Oil or Gas (by separate units) _____
 Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of)
 Ranges _____ Water Heaters _____
 Cook Tops _____ Disposals _____
 Wall Ovens _____ Dishwashers _____
 Dryers _____ Compactors _____
 Fans _____ Others (denote) _____

MISCELLANEOUS: (number of)
 Branch Panels _____
 Transformers _____
 Air Conditioners Central Unit _____
 Separate Units (windows) _____
 Signs 20 sq. ft. and under _____
 Over 20 sq. ft. _____
 Swimming Pools Above Ground _____
 In Ground _____
 Fire/Burglar Alarms Residential _____
 Commercial _____
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____
 Over 30 amps _____
 Circus, Fairs, etc. _____
 Alterations to wires _____
 Repairs after fire _____
 Emergency Lights, battery _____
 Emergency Generators _____

INSTALLATION FEE DUE: _____
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
 FOR REMOVAL OF A "STOP ORDER" (304-16.b)
 TOTAL AMOUNT DUE: 3.50
 min 5.00

INSPECTION: Will be ready on _____, 19 __; or Will Call XX
 CONTRACTOR'S NAME: Bradley Electric
 ADDRESS: 55 Gardner Ave. Gorham
 TEL.: _____
 MASTER LICENSE NO.: 03134 SIGNATURE OF CONTRACTOR: *Robert Bradley*
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

