

117-119 CARLYLE ROAD

PERMIT TO INSTAL. PLUMBING

14358
PERMIT NUMBER

Date Issued: 2/2/65
 Address: 116 To Road
 Installation For: 1st Selburn
 Owner of Bldg.: same
 Owner's Address: Union Road Date: 2/2/65
 Plumber: Alan Miles

By: J.P. Welch
 PORTLAND PLUMBING INSPECTOR

APPROVED FIRST INSPECTION
 Date: 2/5/65
 By: J.P. Welch

APPROVED FINAL INSPECTION
 Date: 5/6/65
 By: J.P. Welch
 CHIEF PLUMBING INSPECTOR

- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

NEW		REPL	PROPOSED INSTALLATIONS	NUMBER	FEE
1			SINKS	1	\$2.00
1			LAVATOPIES	2	1.00
2			TOILETS	1	.60
1			BATH TUBS		
1			SHOWERS	1	.60
			DRAINS		
1			HOT WATER TANKS	1	.60
			TANKLESS WATER HEATERS	1	.60
			GARBAGE GRINDERS		
			SEPTIC TANKS		
			HOUSE SEWERS		
			ROOF LEADERS (Conn. to house drain)	2	.60
			Washing Machine		
				TOTAL	\$13.00

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

Mr. Tolde

PERMIT TO INSTALL PLUMBING

13166

PERMIT NUMBER

Date Issued 8-15-63
PORTLAND PLUMBING
INSPECTOR

By J. P. Welch

APPROVED FIRST INSPECTION

Date Aug. 16, 1963

By JOSEPH E. WELCH

APPROVED FINAL INSPECTION

Date Aug. 16, 1963

By JOSEPH E. WELCH

- By
- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

Address 119 Carlyle Road
Installation For: Carl Solburg
Owner of Bldg. Carl Solburg
Owner's Address: Canon Road
Plumber: William E. Miles Sr. Date: 8-15-63

NEW	REPL	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
		GARBAGE GRINDERS		
		SEPTIC TANKS		
	1	HOUSE SEWERS	1	\$ 2.00
		ROOF LEADERS (Conn. to house drain)		

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

TOTAL ▶ \$ 2.00



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, April 15, 1965

PERMIT ISSUED 00385 APR 16 1965 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 117-119 Carlyle Road Use of Building Dwelling No. Stories 1 1/2 New Building Existing Name and address of owner of appliance Carl Selberg, 47 Canco Road Installer's name and address owner Telephone

General Description of Work

To install Oil-fired forced hot water heating system

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none If so, how protected? Kind of fuel? oil Minimum distance to burnable material, from top of appliance or casing top of furnace 3' From top of smoke pipe 2' From front of appliance over 4' From sides or back of appliance over 3' Size of chimney flue 8x8 Other connections to same flue none If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner American Standard - 5 unit type Labeled by underwriters' laboratories? yes Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/2" Location of oil storage basement Number and capacity of tanks 275 gal. Low water shut off Make No. Will all tanks be more than five feet from any flame? YES How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

[Empty space for miscellaneous information]

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED: O.K. E.S.S. 4/15/65

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Carl Selberg

CS 300

Signature of Installer by: Carl E. Selberg

INSPECTION COPY

Handwritten initials

117-119
127 Carlyle Road

July 1, 1965

Mr. Carl Selberg
47 Canco Road

Dear Mr. Selberg:

You may consider this letter as a temporary certificate of occupancy until such time as fireproofing of garage wall is done and fire door provided. Meanwhile it is unlawful to use the garage as such.

When the above work is completed and this office notified for another inspection, and, if at that time, all is found in order the regular certificate of occupancy required by law will be issued.

If additional information relative to the above is desired, please phone Inspector Earle Smith at 774-8221, extension 234, any week day but Saturday between 8:00 and 9:00 A. M.

Very truly yours,

Earle Smith
Field Inspector

ES:K

Memorandum from Department of Building Inspection, Portland, Maine

AP - 127 Carlyle Road

May 20, 1964

Mr. Carl Selberg,
47 Canco Road

Dear Mr. Selberg:

Permit to construct a 2-story frame dwelling 23'x24' with attached 2-car garage 14'x22' is being issued subject to plans received with application and in compliance with Zoning Ordinance and Building Code restrictions as follows:

1. The ridge board will be made up of 2-2x8's and this ridge will be supported down to the carrying partition and down to solid 8"x12" concrete piers beside the chimney.

Very truly yours,

A. Alan Scille
Field Inspector

AAS/h

CS-27

R5 RESIDENCE ZONE

APPLICATION FOR PERMIT

PERMIT NUMBER
00548
MAY 20 1964

Class of Building or Type of Structure Third Class
Portland, Maine, May 15, 1964

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 117-119 Carlyle Rd. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Carl Selberg, 47 Canco Bld. Telephone 772-4215
Lessee's name and address _____ Telephone _____
Contractor's name and address OWNER Telephone _____
Architect _____ Specifications _____ Plans yes No. of sheets 3
Proposed use of building 1 fam. dwelling No. families 1
Last use _____ No. families _____
Material frame No. stories 2 Heat _____ Style of roof pitch Roofing asphalt
Other buildings on same lot _____ Fee \$ 20.00
Estimated cost \$ 10,000

General Description of New Work

To construct 1-fam., 2-story frame dwelling, and 1-car garage, 38' x 23'

inside of garage will be covered where required by law with 5/8" fire shield to use 1 3/4" solid wood core door

Permit Issued with Letter

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? yes If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate 151 Height average grade to highest point of roof 18'
Size, front 38' depth 23' No. stories 2 Solid or filled land? solid earth or rock? earth
Material of foundation concrete - at least 4" below grade Thickness, top 4" bottom cellar
Kind of roof pitch Rise per foot 9" Roof covering asphalt Class C Und. ab
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat f.h.w. fuel oil
Framing Lumber - Kind hemlock Dressed or full size? dressed Corner posts 4x6 Sills 2x8-box
Size Girder 6x10 Columns under girders wood Size 8x12 Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd _____, roof 2x6
On centers: 1st floor 16", 2nd 16", 3rd _____, roof 24"
Maximum span: 1st floor 11'3", 2nd 14'9", 3rd _____, roof 11' 12"
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated 1 number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Carl Selberg

APPROVED:

CS 301

INSPECTION COPY

Signature of owner By: James C. Selberg

NOTES

5/27/64 - ...
 7/1/64 - Railing
 walls. JH
 7/15/64 - Framing
 done. Boarded
 shingled. both roof
 on sides. JH
 11/9/64 - Progress
 slow - interior
 closing - in E.S.
 1/5/65 - JH G.T. in
 close
 4/15/65 - Fireproofing
 done
 4/15/65 - As soon as fire-
 proofing of garage is done
 fire door provided cut
 away
 5/1/66 - Some wall board
 - has been applied to wall
 between garage & house -
 No fire door. JH
 10/28/65 - No doors
 on fire door
 Shutter door not
 external to wall
 joint not taped.
 End.

4/13/66 -

F.L.E.

2

Location 115-49 Cambridge Rd
 Owner Carl & Cheryl
 Date of permit 5/26/64
 Notif. closing-in 1/5/65
 Inspn. closing-in 1/5/65
 Final Notif. 1/5/65
 Final Inspn. 1/5/65
 Cert. of Occupancy Issued
 Staking Out Notice
 Form Check Notice

115-49 Cambridge Rd
 Carl & Cheryl
 1/5/65
 1/5/65