

Permit # **924203** City of Portland BUILDING PERMIT APPLICATION Fee \$60.00 Zone _____ Map # _____ Lot # _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner Port. Congreg. of Jehovah's Phone # 773-6171
 Address: 355 Canco Rd. 04105
 LOCATION OF CONSTRUCTION 355 Canco Rd.
 Contractor _____ Sub: _____
 Address: _____ Phone # _____
 Est. Construction Cost: \$8,000.00 Proposed Use: storage facility
 Past Use: vacant land
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion to construct storage facility as per plans

For Official Use Only
 Date: September 28, 1992 Subdiv. Name: _____
 Inside Fire Limits _____
 Bldg. Code: _____
 Time Limit: _____
 Estimated Cost: \$8,000.00
 Name: _____
 City of Portland
 Permit Issued **OCT - 7 1992**

Zoning: Street Frontage Provided _____ Back _____ Side _____
 Provided Setbacks: Front _____ Back _____ Side _____
 Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Zoning Yes _____ No _____ Plain Yes _____ No _____
 Special Exception _____
 Other: WDA 10-1-92

Foundations:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____

Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

HISTORIC PRESERVATION
 1. Ceiling Joist Size _____ Spacing _____
 2. Ceiling Strapping Size _____ Spacing _____
 3. Type Ceilings _____
 4. Insulation Type _____ Size _____
 5. Ceiling Height: _____
 Roof:
 1. Truss or Rafter Size _____ Span _____
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 Chimneys:
 Type: _____ Number of Fire Places _____
 Heating:
 Type of Heat: _____
 Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____
 Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____
 Swimming Pools:
 Pool Size: _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

PERMIT ISSUED
 Permit Saved By Latini
 Signature of Applicant Alan Buck
 CEU's District 6 Alan Buck
ISSUED 9/29/92
TER

CONTINUED TO REVERSE SIDE
 Ivory Tag - CEO 161 MA. ROWO

White - Tax Assessor

925 203

\$60.00

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 60.00 Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Port. Congreg. of St. John's Phone # 713-6171
 Address: 355 Canco Rd. 04103
 LOCATION OF CONSTRUCTION 355 Canco Rd.
 Contractor: _____ S. # _____
 Address: _____ Phone # _____
 Est. Construction Cost: \$8,000.00 Proposed Use: storage facility
 Past Use: vacant land
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion to construct storage facility as per plans

PERMIT ISSUED

For Official Use Only

Date: September 28, 1992 Subdivision: _____
 Inside Fire Limits: _____ Name: _____
 Bldg Code: _____ Lot: _____
 Time Limit: _____ Ownership: **CITY OF PORTLAND**
 Estimated Cost: \$8,000.00

Zoning: Street Frontage Provided
 Provided Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
 Special Exception _____
 Other: (explain) 10-1-92

Foundations:

- Type of Soil: _____
- Set Backs - Front _____ Rear _____ Side(s) _____
- Footings Size: _____
- Foundation Size: _____
- Other: _____

Floor:

- Sills Size: _____ Sills must be anchored.
- Girder Size: _____
- Lally Column Spacing: _____ Size: _____
- Joists Size: _____ Spacing 16" O.C.
- Bridging Type: _____ Size: _____
- Floor Sheathing Type: _____ Size: _____
- Other Material: _____

Exterior Walls:

- Studding Size _____ Spacing _____
- No. windows _____
- No. Doors _____
- Header Sizes _____ Spacing _____
- Bracing: Yes _____ No _____
- Corner Posts Size _____
- Insulation Type _____ Size _____
- Sheathing Type _____ Size _____
- Siding Type _____ Weather Exposure _____
- Masonry Materials _____
- Metal Materials _____

Interior Walls:

- Studding Size _____ Spacing _____
- Header Sizes _____ Spacing _____
- Wall Covering Type: _____
- Fire Wall if required _____
- Other Materials _____

Ceiling:

- Ceiling Joists Size: _____
- Ceiling Strapping Size _____ Spacing _____ Not in District per Section 2
- Type Ceilings: _____ Size _____ Does not require review
- Insulation Type _____
- Ceiling Height: _____ 00.00 Requires Review

Roof:

- Truss or Rafter Size _____ Span _____ Area: _____
- Sheathing Type _____ Size _____ Approved with conditions
- Roof Covering Type: _____

Chimneys:

Type: _____ Number of Fire Places _____ Date _____
 Signature: _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

- Approval of soil test if required Yes _____ No _____
- No. of Tubs or Showers _____
- No. of Flushes _____
- No. of Lavatories _____
- No. of Other Fixtures _____

Swimming Pools:

- Pool Size: _____
- Must conform to National Electrical Code and _____

Form Received By: Latini

Signature of Applicant: Alan Buck
 Signature: Alan Buck
 CEO's District: 12 District

PERMIT ISSUED WITH LETTER

PERMIT ISSUED WITH LETTER

White - Tax Assessor

CONTINUED TO REVERSE SIDE
Ivory Tag - CEO

10-1-92
10-1-92
10-1-92

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ 60.00

Subdivision Fee \$ _____

Site Plan Review Fee \$ _____

Other Fees \$ _____

(Explain) _____

Late Fee \$ _____

Inspection Record		Date
Type		
Completed	upset	12/18/92
inspection		

[Signature]

COMMENTS submitted 3 sheets of plans

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

Aian Buck 75 Bridge St. Westbrook, Me. 854-9588

SIGNATURE OF APPLICANT ADDRESS PHONE NO.

Aian Buck ELDER (SAME)

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE NO.

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban
Josep

CITY OF PORTLAND

October 6, 1992

RE: 355 Canco Road

Portland Congregation of Jehovah's Witness
355 Canco Road
Portland, ME 04103

Dear Sir:

Your application to construct storage facility has been reviewed and a permit is herewith issued subject to the following requirements:

No certificate of occupancy can be issued until all requirements of this letter are met.

1. Provide a portable fire extinguisher with at least a 40 BC rating.
2. Provide listed safety storage cabinets for all flammable or combustible liquids in excess of 10 gallons.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

A handwritten signature in dark ink, appearing to read "Samuel P. Hoffses", written over a horizontal line.

P. Samuel Hoffses
Chief of Inspection Services

/el

cc: LT. Wallace Garroway, Fire Prevention Bureau