

7-15 Cummings Street



SHAW-WALKER

#8503-3R

March 6, 1973

Mr. William Prosser
244 Middle Road
Falmouth, Maine

Re: 7-15 Cumming Street,
Portland, Maine

Dear Mr. Prosser:

Your property has been surveyed by the Portland Housing Inspection Division, Health Department, and has met Minimum Code Standards. Congratulations are extended to you for the general condition of your property. Good maintenance is the best way to preserve the useful life of your property and neighborhood.

If we can be of further help, please feel free to call on us.


Sincerely,



Lyle D. Noyes
Chief of Housing Inspections

LDN/cw

Inspector



Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gr...
Director

CITY OF PORTLAND

DECEMBER 26, 1996

CASPARIUS RUDOLF P K
1231 FOREST AVE
PORTLAND ME 04103

Re: 9 CUMMINGS ST
CBL: 167-- D-003-001-01
DU: 6

Dear Mr. Casparius.

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - 3RD FLR - LT - LIVING ROOM 108.20
CEILING IS CRACKED & BUCKLED
2. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Merle Leary
Merle Leary
Code Enforcement Officer

Tammy Munson
Tammy Munson
Code Enfc. Offc./ Field Supv.

