



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

1/12/90

Emily B. Kinney
72 Rosemont Ave.
Portland, ME 04103

DU: 4

re: 36 Leeman St.
181-C-13

Dear Ms. Kinney:


The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referred property.


Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code.

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely yours,
Joseph E. Gray, Jr., Director
Planning & Urban Development


Samuel Hoffes
Chief of Inspection Services


Code Enforcement Officer
Kathleen Lowe #2

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

DECEMBER 26, 1996

KINNEY EMILY B
72 ROSEMONT AVE
PORTLAND ME 04103

Re: 36 LEEMAN ST
CBL: 181 - C-013-001-01
DU: 4

Dear Ms. Kinney:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referenced property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACKUP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Amy Powers
Amy Powers
Code Enforcement Officer

Tammy Munson
Tammy Munson
Code Encl. Offc./ Field Supv.

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

DECEMBER 26, 1996

KINNEY EMILY B
72 ROSEMONT AVE
PORTLAND ME 04103

Re: 36 LEEMAN ST
CBL: 101-- C-013-001-01
DU: 4

Dear Ms. Kinney:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Amy Powers
Code Enforcement Officer

Tammy Munson
Code Enfc.Offc./ Field Supv.