

90 COLUMBI RD.



SHAW-WALKER

#8505-1R



CITY OF PORTLAND

JOSEPH E. GRAY, JR.
DIRECTOR OF PLANNING
AND URBAN DEVELOPMENT

July 19, 1983

Mrs. Charlotte White
90 Columbia Road
Portland, Maine 04103

Re: 90 Columbia Rd. 181-D-24 Gen.

Dear Mrs. White:

We recently received a complaint and an inspection was made by Code Enforcement Officer A. Addato of the property owned by you at 90 Columbia Road Portland, ME. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

Loose brick and missing mortar on exterior chimney is very critical and in danger of falling. 3-e

The above mentioned conditions are in violation of Chapter 307 of the Municipal Code of the City of Portland, Maine, and must be corrected on or before July 29, 1983

Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely yours,
Joseph E. Gray, Jr., Director of
Planning & Urban Development

By Lyle D. Noyes
Lyle D. Noyes
Inspection Services Division

A. Addato
Code Enforcement Officer - A. Addato

jmr

FALMOUTH HEALTH DEPARTMENT

REQUEST FOR SERVICE

DATE RECEIVED	7-19-83	BY	Adelata	DISTRICT	Cassell
REQUEST BY	NAME				
	ADDRESS				
OWNER	NAME	Charlotte White			
	ADDRESS	90 Columbia Rd.			
CONDITIONS	ADDRESS				

Exterior chimney is in very bad condition and ready to collapse.

COMMENTS C-181-BLD-1-24

SPECIAL INSTRUCTIONS C1-C1 - send L.D. - 7-19-83 BR.

DIVISION	SANITATION		HOUSING		NURSING	
	ROUTINE		SPECIAL		BY	
	URGENT		REPORT TO		DATE	
PRIORITY						