

28-30 BOLTON STREET

SHAW

Full cut #920R - Half cut #9202R - Thin #9204R

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. 117

Issued

Portland, Maine, 19....

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Harriet Bum 30 Belmont St.

Contractor's Name and Address Carron Electric 94 Portland Ave. Tel. 772-5424

Location 30 Belmont St. Use of Building home

Number of Families 3 Apartments 3 Stores

Description of Wiring: New Work Additions

Pipe

No. Light Outlets

FIXTURES: No.

SERVICE: Pipe

METERS: Relocated Added

MOTORS: Number

HEATING UNITS: Domestic (Oil)

Commercial (Oil)

Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges

Elec. Heaters

Miscellaneous

Transformers

Will commence

Amount of Fee \$ 6.00

Signed Harriet Bum

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1	2	3
4	5	6
7	8	9
10	11	12

REMARKS:

INSPECTED BY [Signature] (OVER)

PERMIT TO INSTALL PLUMBING

11270

PERMIT NUMBER

Date Issued **3-26-62**

PORTLAND PLUMBING INSPECTOR

By **J. P. Welch**

Address **30 Bolton Street**

Installation For: **Charles Burns**

Owner of Bldg. **Charles Burns**

Owner's Address: **30 Bolton Street**

Plumber: **Portland Gas Light Company**

Date: **3-26-62**

APPROVED FIRST INSPECTION

Date **3-29-62**

By **J. P. Welch**

APPROVED FINAL INSPECTION

Date

By **JOSEPH P. WELCH**

- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

NEW	REPL	PROPOSED INSTALLATIONS	NUMBER		FEE
		SINKS			
		LAVATORIES			
		TOILETS			
		BATH TUBS			
		SHOWERS			
		DRAINS			
1		HOT WATER TANK	1		\$ 2.00
		TANKLESS WATER HEATERS			
		GARBAGE GRINDERS			
		SEPTIC TANKS			
		HOUSE SEWERS			
		ROOF LEADERS (Conn. to house drain)			

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

TOTAL \$ 2.00

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for addition to existing one car garage
at 30 Bolton Street Date 11/13/10

1. In whose name is the title of the property now recorded? Mrs Burns
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Yes
3. Is the outline of the proposed work now staked out upon the ground? If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip?
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? Yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? Yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

A. A. Berry

Memorandum from Department of Building Inspection, Portland, Maine
30 Bolton St. --Addition to garage for Mrs. Hattie Burns--Contractor A.A. Berry--11/14/40

To Owner and Builder:

The application states that an extra 2x4 is to be used across the top of the opening to be cut in the rear wall of the garage. This is not strong enough. If the span of this opening is 12 feet, as is indicated by the location sketch, probably a 6x6 would be the proper size.

CC A.Mrs. Hattie Burns, 30 Bolton St.

(Signed) Warren McDonald
Inspector of Buildings



(A) APARTMENT HOUSE
APPLICATION FOR PERMIT

PERMIT ISSUED

Permit No. 1850
NOV 14 1940

Class of Building or Type of Structure Third Class

Portland, Maine, November 12, 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect, alter, install, the following building structure, equipment, in accordance with the laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location: 30 Bolton Street Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Mrs. Hattie Burns, 30 Bolton St. Telephone _____
Contractor's name and address A. A. Barry, 113 Stevens Avenue Telephone no
Architect _____ Plans filed _____ No. of sheets _____
Proposed use of building a car garage No. families _____
Other buildings on same lot apartment house
Estimated cost \$ 25. Fee \$.25

Description of Present Building to be Altered

Material wood No. stories 1 Heat none Style of roof hip Roofing asph. sh.
Last use 1 car garage No. families _____

General Description of New Work

To build one story frame addition 2' x 12' on rear of existing building
To put in new 2x4 under existing 2x4 plate to support opening

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor

Details of New Work

Is any plumbing work involved in this work? _____
Is any electrical work involved in this work? _____ Height average grade to top of plate 7'
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof 8'
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation concrete posts on flat top _____ bottom _____ cellar _____
Material of underpinning _____ height _____ thickness _____
Kind of roof flat Rise per foot 6" Roof covering Asphalt roofing Class C Und. Let.
No. of chimneys no Material of chimneys _____ of lining _____
Kind of heat no Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind hemlock Dressed or full size? full size
Corner posts 2-2x4 Sills 4x6 Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joist and rafters: 1st floor 4x4, 2nd _____, 3rd _____, roof 2x4
On centers: 1st floor _____, 2nd _____, 3rd _____, roof 2x4
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 2x4
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 1
Total number commercial cars to be accommodated none
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY [Signature] Signature of owner Mrs. Hattie Burns
By [Signature]
CHIEF OF PERMITS

EXAMINATION BEFORE LATHING OR CLOSING IN IS REQUIRED. CERTIFICATE OF COMPLETION REQUIREMENT IS WAIVED

457pc

