

25-21 BRADLEY STREET

SHAW-WALKER

Full cut # 92011 - Half cut # 92022 - Third cut # 92033 - Fifth cut # 92055

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

June 16, 1964

Alexander Vankevich
25 Bradley St.
Portland Maine

Dear Sir;

With relation to permit applied for to demolish a building or
portion of building at 25 Bradley St. (1-story frame building)
it is unlawful to
commence demolition work until a permit has been issued from this
department.

Section 6 of the ordinance for rodent and vermin control pro-
vides: "It shall be unlawful to demolish any building or structure
unless provision is made for rodent and vermin eradication. No permit
for the demolition of a building or structure shall be issued by the
Building Inspector until and unless provisions for rodent and vermin
eradication have been carried out under supervision of a pest control
operator registered with the Health Department.

The building permit for demolition cannot be issued until the
provisions of this section have been satisfied. It is the obligation
of owner or demolition contractor or both to take up with the Health
Department the matter of complying with this section, being prepared to
inform that department what registered pest control operator is to be
employed.

Very truly yours,


Albert J. Sears

Albert J. Sears
Director of Building Inspection

AJS/h

Eradication of this building has been completed.

Reginald J. Butler



6-16-64 JCK



APPLICATION FOR PERMIT

R3 RESIDENCE ZONE

Class of Building or Type of Structure Portland, Maine Third Class
 To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE JUNE 16, 1964

PERMIT ISSUED

JUN 19 1964

CITY OF PORTLAND

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 25 Bradley Street Within Fire Limits? Telephone _____
 Owner's name and address Alexander Wankovich, 25 Bradley St. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address _____ Plans no. _____ No. of sheets _____
 Architect _____ No. families _____
 Proposed use of building _____ No. families _____
 Last use Garage (former barn) Style of roof _____ Roofing _____
 Material _____ Heat _____ Dwelling _____
 Other buildings on same lot _____
 Estimated cost \$ 100. Fee \$ 2.00

General Description of New Work

To demolish existing 1-story frame building

Education letter sent 6-16-64
 It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewer? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ solid or filed land? _____
 Size, front _____ depth _____ bottom _____
 Material of foundation _____ Kind of roof _____
 No. of chimneys _____ Rise per foot _____ Thickness, top _____
 Framing Lumber—Kind _____ Dressed or full size? _____ Roof covering _____
 Size Girder _____ Columns under girders _____ of lining _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet. _____
 Joists and rafters: _____ Size _____ Corner posts _____
 On centers: _____ 1st floor _____ 2nd _____ 3rd _____
 Maximum span: _____ 1st floor _____ 2nd _____ 3rd _____
 If one story building with masonry walls, thickness of walls? _____
 No. cars now accommodated on same lot _____ to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

If a Garage

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Miscellaneous

APPROVED:
O.K. - 6/17/64 - ajs

Signature of owner Alexander Wankovich

INSPECTION COPY



Permit No. 11393

APPLICATION FOR PERMIT

OCT 19

25-31

Class of Building or Type of Structure Third

Portland, Maine, Oct. 19 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ alter ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 25 Bradley St. Ward 8 Within Fire Limits? no Dist. No. _____
 Owner's or Lessee's name and address Mrs H.L. Daggatt 25 Bradley St. Telephone _____
 Contractor's name and address B.H. Riggs 47 Allen Ave. Telephone 2-0088
 Architect's name and address _____ No. families _____
 Proposed use of building Demolish Garage floor
 Other buildings on same lot Dwelling House
 Plans filed as part of this application? no No. of sheets _____
 Estimated cost \$ _____ Fee \$ 50

Description of Present Building to be Altered
 Material Frame No. stories 1 Heat Stove in garage not used Style of roof _____ Roofing _____
 Last use Garage & Poultry house No. families _____

General Description of New Work
Demolish poultry house 12' x 20' attached to rear of garage

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
 To be erected on solid or filled land? _____ Height average grade to highest point of roof _____
 Material of foundation _____ Thickness, top _____ bottom _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of Roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys Brick chimney in garage not used Material of chimneys _____ of lining _____
 Kind of heat none Type of fuel _____ Is gas fitting involved? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Material columns under girders _____ Size _____ Max. on centers _____
 Stairs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x3 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot 1, to be accommodated 1
 Total number commercial cars to be accommodated none
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observe? yes

Signature of owner

Mrs H.L. Daggatt by R.H. Riggs

INSPECTION COPY

35978



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Sept. 20, 1954

PERMIT ISSUED

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 25 Bradley St. Use of Building 1-family dwelling No. Stories 1 Building Existing "
Name and address of owner of appliance Alexander Vankevick, 25 Bradley St.
Installer's name and address Harris Oil Co., 202 Commercial St. Telephone 2-8304

General Description of Work

To install forced hot water heating system and oil burning equipment in place of oil-fired hot water heating system

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 2'
From top of smoke pipe 3' From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 8x10 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner General Electric Labeled by underwriter's laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? top
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 1-275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

[Empty lines for miscellaneous information]

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

[Handwritten signature and date: 9.21.54]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Harris Oil Co.

Signature of Installer by:

[Handwritten signature: L. H. Harris]

INSPECTION COPY

#7
10-22
11-1

Permit No. 54/1483
Location: 25 Bradley St.
Owner Alexander Vanckerick
Date of permit 9/21/54
Approved 11-1-54

Installation & tank

NOTES

- 1 Fill Pipe
- 2 Vent Pipe
- 3 Kind of Heat
- 4 Burner Rigidity & Supports
- 5 Name & Label
- 6 Stack Control
- 7 High Limit Control
- 8 Remote Control
- 9 Piping Support & Protection
- 10 Valves in Suction Line
- 11 Capacity of Tanks
- 12 Tank Rigidity & Supports
- 13 Tank Distance
- 14 Oil Gauge
- 15 Instruction Card
- 16 Low Water Suction

P.P.T. of P.P. in c.
Heat not in
Brng

Place of equipment for
burner, vent, stack, etc.
if so, how located
for record of city

Place of filling for
oil, water, etc.
if so, how located
for record of city

7/10/49



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 10, 1949

PERMIT ISSUED

OCT 10 1949

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 25 Bradley Street Use of Building 1-family Dwelling No. Stories New Building Existing " Name and address of owner of appliance Alexander Vankevich, 25 Bradley Street Installer's name and address Harris Oil Co., 202 Commercial Street Telephone 2-8304

General Description of Work

To install Oil burning equipment in connection with existing hot water heat. (replacement)

IF HEATER, OR POWER BOILER

Location of appliance or source of heat. Type of floor beneath appliance. If wood, how protected? Kind of fuel. Minimum distance to wood or combustible material from top of appliance or casing top of furnace. From top of smoke pipe. From front of appliance. From sides or back of appliance. Size of chimney flue. Other connections to same flue. If gas fired, how vented? Rated maximum demand per hour.

IF OIL BURNER

Name and type of burner Johnson. Labeled by underwriter's laboratories? Yes. Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Bottom. Type of floor beneath burner concrete. Location of oil storage cellar. Number and capacity of tanks existing 1-275-Gal. If two 275-gallon tanks, will three-way valve be provided? Will all tanks be more than five feet from any flame? Yes. How many tanks fire proofed? Total capacity of any existing storage tanks for furnace burners None.

IF COOKING APPLIANCE

Location of appliance. Kind of fuel. Type of floor beneath appliance. If wood, how protected? Minimum distance to wood or combustible material from top of appliance. From front of appliance. From sides and back. From top of smokepipe. Size of chimney flue. Other connections to same flue. Is hood to be provided? If so, how vented? If gas fired, how vented? Rated maximum demand per hour.

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$3.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

OCT. 10. 10. 49. [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes.

Harris Oil Company

Signature of Installer By:

[Signature: Andrew K. Sides]

INSPECTION COPY

Permit No. 49/1694 ¹⁰⁻²⁴⁻⁴⁹
Location 25 Bradley St.
Owner Alexander Plankovich
Date of permit 10/10/49
Approved 122

NOTES

- 1 Fill Pipe
- 2 Vent Pipe
- 3 Kind of Heat Hot Water
- 4 Burner Rigidity & Supports
- 5 Name & Label
- 6 Stack Control
- 7 High Limit Control
- 8 Remote Control
- 9 Proving Switch & Interception
- 10 Valves in Supply Lines
- 11 Contents of Tank
- 12 Tank Location & Supports
- 13 Tank Distance
- 14 Oil Gauge
- 15 Instruction Card
- 16

MICHIGAN DEPARTMENT OF CONSERVATION



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date 8/2/90, 19__
 Receipt and Permit number 01437

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine; the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 25 Bradley St
 OWNER'S NAME: Alex Vahkevich ADDRESS: same

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL <u>1-50</u>	<u>3.00</u>
FIXTURES: (number of)	
incandescent _____ Flourescent _____ (not strip) TOTAL	
Strip Flourescent _____ ft.	
SERVICES:	
Overhead <input checked="" type="checkbox"/> Underground _____ Temporary _____ TOTAL amperes <u>100</u> ..	<u>3.00</u>
METERS: (number of)	
MOTORS: (number of)	
Fractional	
1 HP or over	
RESIDENTIAL HEATING:	
Oil or Gas (number of units)	
Electric (number of rooms)	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler)	
Oil or Gas (by separate units)	
Electric Under 20 kws _____ Over 20 kws	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL	
MISCELLANEOUS: (number of)	
Branch Panels	
Transformers	
Air Conditioners Central Unit	
Separate Units (windows)	
Signs 20 sq. ft. and under	
Over 20 sq. ft.	
Swimming Pools Above Ground	
In Ground	
Fire/Burglar Alarms Residential	
Commercial	
Heavy Duty Outlets 220 Volt (such as welders) 30 amps and under	
over 30 amps	
Circus, Fairs, etc.	
Alterations to wires	
Repairs after fire	
Emergency Lights, battery	
Emergency Generators	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	DOUBLE FEE DUE:
	TOTAL AMOUNT DUE: <u>6.00</u>

INSPECTION:

Will be ready on _____, 19__; or Will Call

CONTRACTOR'S NAME: Scott Robinett

ADDRESS: 123 Ashwmp Rd; Scarborough

TEL: 797-9026

MASTER LICENSE NO.: #09886 SIGNATURE OF CONTRACTOR: _____

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

