

235-239 BANCROFT STREET

SHAW-WALKER

Full cut #920R · Half cut #9202R · Hard cut #9203R · Filth cut #9205R

# CITY OF PORTLAND, MAINE

## Application for Permit to Install Wires

Permit No. 897  
 Issued 28 Sep 73

Portland, Maine ..... 19.....

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address York Home Inc. 235 Bruce St.  
 Contractor's Name and Address RECCO Elec. Comp Tel.

Location ..... Use of Building ..... Number of Stories .....  
 Description of Wiring: New Work ..... Stores ..... Alterations .....

Pipe ..... Cable ..... Metal Molding ..... BX Cable ..... Plug Molding (No. of feet) .....  
 No. Light Outlets ..... Plugs ..... Light Circuits ..... Plug Circuits .....

FIXTURES: No. ..... Undergr. or Strip Lighting (No. feet) .....  
 SERVICE: Pipe ..... Cable ..... Added ..... Total No. Meters .....  
 METERS: Relocated ..... Phase ..... H. P. ..... Amps ..... Volts ..... Starter .....

MOTORS: Number ..... Domestic (Oil) ..... No. Motors ..... Phase ..... H.P. ....  
 HEATING UNITS: Commercial (Oil) ..... No. Motors ..... Phase ..... H.P. ....  
 Electric Heat (No. of Rooms) ..... Brand Feeds (Size and No.) .....

APPLIANCES: No. Ranges ..... Watts ..... Extra Cabinets or Panels .....  
 Elec. Heaters ..... Watts ..... Signs (No. Units) .....  
 Miscellaneous ..... Air Conditioners (No. Units) ..... 19..... Inspection ..... 19.....

Transformers ..... Ready to cover in ..... 19.....  
 Will commence ..... Signed Ralph Egan  
 Amount of Fee \$.....

DO NOT WRITE BELOW THIS LINE

SERVICE	✓	METER	✓	GROUND	✓
VISITS: 1	2	\$	4	6	6
7	8	9	10	12	12

REMARKS: INSPECTED BY [Signature] (OVER)

200 Amp.

LOCATION *Bancro St 57-335*  
 INSPECTION DATE *11/12/73*  
 WORK COMPLETED *11/12/73*  
 TOTAL NO. INSPECTIONS *1*  
 REMARKS:

*REPETITIONS*

**FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1963**

<b>WIRING</b>	
1 to 30 Outlets	2.00
31 to 60 Outlets	3.00
Over 60 Outlets, each Outlet	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
<b>SERVICES</b>	
Single Phase	
Three Phase	
<b>MOTORS</b>	
Not exceeding 50 H.P.	2.00
Over 50 H.P.	4.00
<b>HEATING UNITS</b>	
Domestic (Oil)	3.00
Commercial (Oil)	4.00
Electric Heat (Each Room)	
<b>APPLIANCES</b>	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit	2.00
	4.00
	.75
<b>MISCELLANEOUS</b>	
Temporary Service, Single Phase	1.50
Temporary Service, Three Phase	1.00
Circuses, Carnivals, Fairs, etc.	2.00
Meters, relocate	10.00
Distribution Cabinet or Panel, per unit	1.00
Transformers, per unit	1.00
Air Conditioners, per unit	2.00
Signs, per unit	2.00
<b>ADDITIONS</b>	
5 Outlets, or less	2.00
Over 5 Outlets, Regular Wiring Rates	2.00
	1.00



PERMIT TO INSTALL PLUMBING

PERMIT NUMBER 3199

Date Issued August 1, 1973

By ERNOLD R. GOODWIN  
Portland Plumbing Inspector

Date \_\_\_\_\_  
By \_\_\_\_\_  
App. First Insp.

Date \_\_\_\_\_  
By \_\_\_\_\_  
App. Final Insp.

- Type of Bldg.
- Commercial
  - Residential
  - Single
  - Multi Family
  - New Construction
  - Remodeling

Address 225 Bancroft St  
 Installation for do one family  
 Owner of Bldg. Your Home Inc  
 Owner's Address: Forest Ave  
 Plumber: Pallotta

Date: Aug 4 1973

NEW	REPL.		NO.	FEE
		SINKS	1	
		LAVATORIES	2	
		TOILETS	2	
		BATH TUBS	1	
		SHOWERS	1	
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS	1	
		GARBAGE DISPOSALS	1	
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS		
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER		
TOTAL				12.40

Building and Inspection Services Dept.: Plumbing Inspection



(COPY)

CITY OF PORTLAND, MAINE  
Department of Building Inspection



# Certificate of Occupancy

LOCATION

235-239 Bancroft St

Issued to

Your Home Inc.

Date of Issue

April 28, 1975

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 73/647, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

entire

single family dwelling.

Limiting Conditions:

none

This certificate supersedes  
certificate issued

Approved:

4/28/75  
(Date)

*P. S. Tiffen*  
Inspector

*[Signature]*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

(COPY)  
CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION

235-239 Banoroff St  
Date of Issue April 28, 1975



Issued to **Your Home Inc.**

**This is to certify** that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **7/67**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

**single family dwelling.**

Limiting Conditions:

**entire**

**none**

This certificate supersedes certificate issued

Approved:

**4/28/75**  
(Date)

*[Signature]*

Inspector of Buildings  
Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



235-239 Bancroft Street

June 18, 1973

Your Home, Inc.  
726 Forest Avenue

Gentlemen:

Permit to erect a 23' x 44' split foyer dwelling as per  
Plans is issued herewith subject to the following Building  
Code requirements.

Before a form inspection is called for, please provide  
us with framing details of the outside rear platform.

The concrete foundation wall is required to be at least  
10 inches in thickness instead of the 3 inches as indicated  
on the plans.

Anchor bolts are required in the foundation walls at the  
corners and 8' o. c.'s.

Very truly yours,

Earle S. Smith  
Plan Examiner

ESS:m





R3 RESIDENCE ZONE

### APPLICATION FOR PERMIT

Class of Building or Type of Structure \_\_\_\_\_  
Portland, Maine, June 7, 1973

**PERMIT ISSUED**

JUN 19 1973  
00647  
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 235-239 Bancroft St. Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Your Home, Inc. 726 Forest Ave. Telephone 772-9434  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address same as above Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans \_\_\_\_\_ No. of sheets \_\_\_\_\_  
 Proposed use of building dwelling No. families 1  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ 24,000. Fee \$ 72.

#### General Description of New Work

To erect 23' x 44' split foyer dwelling as per plans

**PERMIT ISSUED  
WITH LETTER**

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

#### Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes  
 Is connection to be made to public sewer? yes If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate 14' Height average grade to highest point of roof 18'  
 Size, front 44' depth 23' No. stories split foyer solid or filled land? solid earth or rock? \_\_\_\_\_  
 Material of foundation concrete-4' below grade Thickness, top 10" bottom \_\_\_\_\_ cellar yes  
 Kind of roof pitch Rise per foot 4/12 Roof covering asphalt shingles  
 No. of chimneys 1 Material of chimneys br. of lining tile Kind of heat L.H.W. fuel oil  
 Framing Lumber—Kind SPRUCE Dressed or full size? dr. Corner posts solid Sills 2x8  
 Size Girder 6 x 8 Columns under girders ally Size 3 1/2 Max. on centers 8'  
 Joists and rafters: 1st floor 2 x 8, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof truss- diamond National  
 On centers: 1st floor 16", 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

#### If a Garage

\_\_\_\_\_ is now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 \_\_\_\_\_ automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

#### Miscellaneous

Will work require disturbing of any tree on a public street? \_\_\_\_\_  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

ZONING OR PAGE  
dy Cook of E.B.S.

Signature of owner Arthur Home, Inc.  
Arthur J. Walker

BY  
TH  
NDMENTS

NOTES

Permit No. 73/647  
 Location 235-239 Baveno St  
 Owner Yves Stone Inc  
 Date of permit 6/19/73  
 Notif. closing-in  
 Inspn. closing-in  
 Final Notif.  
 Final Inspn.  
 Cert. of Occupancy issued  
 Staking Out Notice  
 Form Check Notice

- 8-14-73 Have progress to place foundation per plan. *OK*
- 11-1-73 Same. *OK*
- 12-27-73 Finishing completed. *OK*
- 1-14-74 Have progress to close in. *OK*
- 3-25-74 Same. work going slow. *OK*
- 4-16-74 Same. *OK*
- 5-3-74 Same. *OK*
- 6-20-74 Same. *OK*
- 7-2-74 Same. *OK*
- 7-22-74 Same. *OK*
- 8-12-74 Same. *OK*
- 8-26-74 Same. *OK*
- 9-23-74 Completed work for final inspection. *OK*
- 10-30-74 Same. *OK*
- 12-10-74 Same. *OK*
- 12-16-74 Same. *OK*
- 1-8-75 Same. *OK*
- 1-22-75 Same. *OK*
- 2-19-75 Same. *OK*
- 3-19-75 Same. *OK*
- 4-24-75 Same, couldn't get in. *OK*
- 4-28-75 Had final inspection, spent money on area of pool with missing concrete foundation. guide book not out. quote just beyond working. still remainder of same. *OK*

C/O issued 4/28/75  
 Rivers

CITY OF PORTLAND, MAINE  
Department of Building Inspection

235-239 Bancroft Street

June 18, 1973

Your Home, Inc.  
726 Forest Avenue

C  
Gentlemen:

Permit to erect a 23' x 44' split foyer dwelling as per plans is issued herewith subject to the following Building Code requirements.

O  
Before a form inspection is called for, please provide us with framing details of the outside rear platform.

P  
The concrete foundation wall is required to be at least 10 inches in thickness instead of the 8 inches as indicated on the plans.

Anchor bolts are required in the foundation walls at the corners and 8' o. c.'s.

Very truly yours,

Earle S. Smith  
Plan Examiner

Y  
ESS:M

PERMIT # 1254 **PORTLAND BUILDING PERMIT APPLICATION** DATE 9/29/87 **PERMIT ISSUED**

**I. GENERAL INFORMATION**  
 Location/address of construction 235 Bancroft Street  
 1. Owner's name William Gray Tel. 774-3603  
 Address same 04102  
 2. Lessee's name \_\_\_\_\_ Tel. \_\_\_\_\_  
 Address \_\_\_\_\_  
 3. Contractor's name Dirigo Masonry Tel. \_\_\_\_\_  
 Address Portland, Maine  
 4. Is this a legally recorded lot? yes  no \_\_\_\_\_

**OCT 1 1987**  
**City Of Portland**

**II. DESCRIPTION OF WORK:** To construct slab foundation, 15' x 22', for  
 one-car garage

send permit  
**III. BUILDING DIMENSIONS:** length \_\_\_\_\_ width \_\_\_\_\_ square footage \_\_\_\_\_ height \_\_\_\_\_ #stories \_\_\_\_\_  
**IV. ZONE:** \_\_\_\_\_ Street frontage \_\_\_\_\_ Zoning board approval: no  yes  date \_\_\_\_\_  
 Setbacks: front \_\_\_\_\_ back \_\_\_\_\_ side \_\_\_\_\_ Planning board approval: no  yes  date \_\_\_\_\_  
**V. REVIEW REQUIRED:** variance \_\_\_\_\_ other \_\_\_\_\_ Number of off-street parking spaces: \_\_\_\_\_  
 site plan \_\_\_\_\_ subdivision \_\_\_\_\_ shore \_\_\_\_\_ floodplain m/mf \_\_\_\_\_ enclosed \_\_\_\_\_ outdoors \_\_\_\_\_  
**VI. FEES:** base fee \_\_\_\_\_ other fees \_\_\_\_\_  
 subdivision fee \_\_\_\_\_ late fee \_\_\_\_\_  
 site plan review fee \_\_\_\_\_ TOTAL \$25.00

**VII. DETAILS OF WORK**

1. WATER SUPPLY: <input type="checkbox"/> public <input type="checkbox"/> private	7. ELECTRICAL: service entrance size _____ # smoke detectors _____	8. CHIMNELY: # flues _____ material _____ # fireplaces _____
2. SEWER: <input type="checkbox"/> public <input type="checkbox"/> private, type _____	9. FRAMING: floor joists _____ size _____ max. on center _____ ceiling joists _____ rafters _____ studs _____ wall studs _____	
3. HEAT: type _____ fuel _____	10. If 1-story building w/masonry walls: wall thickness _____ height _____	11. BEDROOM WINDOWS: height _____ width _____ sill height _____ egress window? yes <input type="checkbox"/> no <input type="checkbox"/>
4. FOUNDATION: type _____ thickness _____ footing _____		
5. ROOF: type _____ pitch _____ covering _____ load _____		
6. PLUMBING: SPRINKLER SYSTEM? yes <input type="checkbox"/> no <input type="checkbox"/>		

**VIII. OFFICE USE:** TAX MAP # \_\_\_\_\_ LOT # \_\_\_\_\_ VALUE/STRUCTURE \_\_\_\_\_ PERMIT EXPIRATION \_\_\_\_\_  
**IX. NEW OR PHASED SUBDIVISION REFERENCE:** Name \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_  
**CODE:** \_\_\_\_\_ if other explain \_\_\_\_\_ Seasonal Condominium Apartment  
**X. PROPOSED USE:** \_\_\_\_\_  
**XI. PAST USE:** \_\_\_\_\_  
**XII. OWNERSHIP:** PUBLIC PRIVATE  
**XIII. EST. CONSTRUCTION COST:** 1,100 **XIV. GR. SQ. FT. OF LOT BUILDING:** \_\_\_\_\_

**COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE**

<b>XV. RESIDENTIAL BUILDINGS ONLY:</b> # NEW DWELLING UNITS WITH _____ BDRMS _____ 2 BDRMS _____ 3 BDRMS _____ # EXISTING DWELLING UNITS WITH _____	<b>XVI. # RESIDENTIAL UNITS:</b> # NEW DWELLING UNITS _____ # EXISTING DWELLING UNITS _____ <b>TOTAL RESIDENTIAL UNITS</b> _____
---	---

**APPROVALS BY:** \_\_\_\_\_ DATE \_\_\_\_\_  
 BUILDING INSPECTION - PLAN EXAMINER \_\_\_\_\_  
 ZONING \_\_\_\_\_  
 C.E.O. \_\_\_\_\_  
 FIRE DEPT. \_\_\_\_\_

**MISCELLANEOUS:**  
 Will work require clearing of any trees on a public street? \_\_\_\_\_  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? \_\_\_\_\_

**NOTE TO APPLICANT:** Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanicals.

District No. <u>2</u>	<b>XVII. SIGNATURE OF APPLICANT:</b> _____ <b>TYPE NAME OF ABOVE:</b> _____ PHONE # _____
-----------------------	---

White - GPCOG Green - Applicant Yellow - Assessor Pink - Office File Gold - Contractor





# APPLICATION FOR AMENDMENT TO PERMIT

PERMIT ISSUED

Amendment No. 1

APR 12 1988

Portland, Maine, April 11 1988

City of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 87/1254 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any submitted herewith, and the following specifications:

Location 235 Bancroft Street Within Fire Limits?  Dist. No.         

Owner's name and address William Bray 235 Bancroft St. 04102 Telephone ext. 428 468

Lessee's name and address          Telephone         

Contractor's name and address          Telephone         

Architect          Telephone         

Proposed use of building One car detached garage Plans filed          No. of sheets         

Use          No. families         

Increased cost of work 3,000 Additional fee 15

### Description of Proposed Work

Amend original foundation permit to construct garage.

### Details of New Work

Is any plumbing involved in this work?

Height average grade to top of plate          Is any electrical work involved in this work?

Size, front          depth          Height average grade to highest point of roof         

Material of foundation          No. stone          solid or filled?          earth or rock?         

Material of underpinning          Thickness, top          bottom          cell         

Kind of roof          Rise per foot          Height          Thickness         

No. of chimneys          Material of chimneys          Roof covering          of lining         

Framing lumber—Kind          Dressed or full size?         

Corner posts          Sills          Girt or ledge board?          Size         

Columns          Size          Columns under girders          Size          Max. on centers         

Joists (outside wall end carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor         , 2nd         , 3rd         , roof         

On centers: 1st floor         , 2nd         , 3rd         , roof         

Maximum span: 1st floor         , 2nd         , 3rd         , roof         

Approved:          Signature of Owner         

Approved:          Inspector of Buildings

         M.B. Carroll

INSPECTION COPY

FILE COPY

APPLICANT'S COPY

ASSESSOR'S COPY



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date October 14, 1988  
 Receipt and Permit number 29687

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 235 Bancroft St.

OWNER'S NAME: William Brey ADDRESS: same

FEES

<b>OUTLETS:</b>		
Receptacles <u>1</u>	Switches <u>1</u>	Plugmold _____ ft. TOTAL <u>2</u> ..... <u>3.00</u>
<b>FIXTURES: (number of)</b>		
Incandescent <u>1</u>	Flourescent _____ (not strip) TOTAL <u>1</u> .....	<u>3.00</u>
Strip Flourescent _____ ft. ....		
<b>SERVICES:</b>		
Overhead _____	Underground _____	Temporary _____ TOTAL amperes _____ ..
<b>METERS: (number of)</b> .....		
<b>MOTORS: (number of)</b>		
Fractional _____ .....		
1 HP or over _____ .....		
<b>RESIDENTIAL HEATING:</b>		
Oil or Gas (number of units) _____ .....		
Electric (number of rooms) _____ .....		
<b>COMMERCIAL OR INDUSTRIAL HEATING:</b>		
Oil or Gas (by a main boiler) _____ .....		
Oil or Gas (by separate units) _____ .....		
Electric Under 20 kws _____	Over 20 kws _____	
<b>APPLIANCES: (number of)</b>		
Ranges _____	Water Heaters _____	
Cook Tops _____	Disposals _____	
Wall Ovens _____	Dishwashers _____	
Dryers _____	Compactors _____	
Fans _____	Others (denote) _____	
TOTAL _____ .....		
<b>MISCELLANEOUS: (number of)</b>		
Branch Panels <u>1</u> .....		<u>1.00</u>
Transformers _____ .....		
Air Conditioners Central Unit _____ .....		
Separate Units (windows) _____ .....		
Signs 20 sq. ft. and under _____ .....		
Over 20 sq. ft. _____ .....		
Swimming Pools Above Ground _____ .....		
In Ground _____ .....		
Fire/Burglar Alarms Residential _____ .....		
Commercial _____ .....		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under <u>1</u> .....		<u>1.00</u>
over 30 amps _____ .....		
Circus, Fairs, etc. _____ .....		
Alterations to wires _____ .....		
Repairs after fire _____ .....		
Emergency Lights, battery _____ .....		
Emergency Generators _____ .....		
	INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT .....	DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....		
	TOTAL AMOUNT DUE: _____	<u>8.00</u>

**INSPECTION:**  
 Will be ready on \_\_\_\_\_, 1988; or Will Call XX  
**CONTRACTOR'S NAME:** Robert Gallant  
**ADDRESS:** 36 Irving St  
**TEL.:** \_\_\_\_\_  
**MASTER LICENSE NO.:** 07758 **SIGNATURE OF CONTRACTOR:** *[Signature]*  
**LIMITED LICENSE NO.:** \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN







# APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1

Portland, Maine, April 11, 1988

PERMIT ISSUED

APR 12 1988

City of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 87/1254 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 235 Bancroft Street Within Fire Limits?  Dist. No.           
 Owner's name and address William Bray 235 Bancroft Str 04102 Telephone ext. 478 468  
 Lessee's name and address          Telephone           
 Contractor's name and address Same Telephone           
 Architect          Plans filed          No. of sheets           
 Proposed use of building One car detached garage No. families           
 Last use          No. families           
 Increased cost of work 3,000 Additional fee 15

### Description of Proposed Work

Amend original foundation permit to construct garage.

### Details of New Work

Is any plumbing involved in this work?  Is any electrical work involved in this work?   
 Height average grade to top of plate          Height average grade to highest point of roof           
 Size, front          depth          No. stories          solid or filled land?  earth or rock?   
 Material of foundation          Thickness, top          bottom          cellar           
 Material of underpinning          Height          Thickness           
 Kind of roof          Rise per foot          Roof covering           
 No. of chimneys          Material of chimneys          of lining           
 Framing lumber—Kind          Dressed or full size?   
 Corner posts          Sills          Girt or ledger board?  Size           
 Girders          Size          Columns under girders          Size          Max. on centers           
 Stads (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor         , 2nd         , 3rd         , roof           
 On centers: 1st floor         , 2nd         , 3rd         , roof           
 Maximum span: 1st floor         , 2nd         , 3rd         , roof         

Approved:

OK M. J. Turner R-3 Zone April 11 1988

Signature of Owner

Approved:

Inspector of Buildings

INSPECTION COPY

FILE COPY

APPLICANT'S COPY

ASSESSOR'S COPY

MA. Carroll