

CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451



DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

October 12, 1988

Allied Construction Co.
208 Fore Street
Portland, Maine 04104

RE: 1040-1122 Westbrook St. Ptd., Me.

Dear Sir:

Your application to construct a 100,000 sq. foot hotel (R-1) (1-B) has been reviewed and a permit is herewith issued subject to the following requirements.

SITE PLAN REVIEW REQUIREMENT

Inspection Services	Approved by Planning Board	W.J. Turner	10/11/88
Fire Department	Approved by Lt. Collins		
Planning Division	Approved by Ms O'Meara		9/30/88
Public Works	Approved by S. Harris		10/05/88

Building and Fire Code Requirements

- 1.) A complete automatic fire alarm system and sprinkler system shall be installed in accordance with the appropriate NFPA standards. A separate permit and approval will be required for each.
- 2.) Every door to an exit stairway shall be provided with a self illuminated exit sign no less than 6" or more than 8" above floor level. This exit sign shall be placed on the door.
- 3.) All doors between exit access corridors and guest rooms shall be 20 minutes fire rated and self-closing.
- 4.) Emergency lighting and exit signs shall be placed throughout as required.
- 5.) The required sprinkler and fire alarm systems shall be monitored by an approved Central Receiving Station in the Municipal fire alarm loop in accordance with Municipal Ordinance 2.5.
- 6.) Provide a Class III stand pipe system in accordance with NFPA #14.
- 7.) In addition to the fire alarm, an approved voice evacuation system and fire-fighter telephone system is to be installed.



CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION


Cont.

Building and Fire Code Requirements

- 8.) Standby power, light and emergency systems shall be done in accordance with 602.9
- 9.) This structure shall meet the requirements of section 602.0 High Rise Building as per the building code.
- 10.) This building shall be dewigned for Seismic Zone 2.

If you have any questions regarding these requirements please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses
Chief, Inspection Services

CITY OF PORTLAND, MAINE

SITE PLAN REVIEW

Processing Form

Applicant Airport Partners
Co Sunfay Corp
 Mailing Address Hotel
 Proposed Use of Site 62A / 14777 #1
 Acreage of Site / Ground Floor Coverage _____
 Date Aug 5, 1988
 Address of Proposed Site 1040-1122 Westbrook St
 Site Identifier(s) from Assessors Maps 207-A-12 210-A-3-4
 Zoning of Proposed Site AB

Site Location Review (DEP) Required: () Yes () No
 Board of Appeals Action Required: () Yes () No
 Planning Board Action Required: () Yes () No
 Proposed Number of Floors 6
 Total Floor Area 88,664 #1

Other Comments: _____
 Date Dept. Review Due: _____

BUILDING DEPARTMENT SITE PLAN REVIEW
 (Does not include review of construction plans)

- Use does NOT comply with Zoning Ordinance
 - Requires Board of Appeals Action
 - Requires Planning Board/City Council Action

Explanation _____

Use complies with Zoning Ordinance — Staff Review Below

Zoning:
 SPACE & BULK,
 as applicable

COMPLIES

COMPLIES
 CONDITIONALLY

DOES NOT
 COMPLY

DATE	ZONE LOCATION	INTERIOR OR CORNER LOT	40 FT. SETBACK AREA (SEC. 21)	USE	SEWAGE DISPOSAL	REAR YARDS	SIDE YARDS	FRONT YARDS	PROJECTIONS	HEIGHT	LOT AREA	BUILDING AREA	AREA PER FAMILY	WIDTH OF LOT	LOT FRONTAGE	OFF-STREET PARKING	LOADING BAYS

CONDITIONS SPECIFIED BELOW

REASONS SPECIFIED BELOW

REASONS: Received approval from Planning Board
10/13/88

Warren Turner 10/11/88
 SIGNATURE OF REVIEWING STAFF/DATE

JETPORT-HOTEL - Audrey Buttsfield 772-2888 772-2888

PERMIT # 1260 TOWN OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Portland Jetport Hotel Associates
 Address: 130 Middle St., P.O.B. 7312 DDT, Portland, ME 04112
1040-1122 Westbrook St., Portland, ME 1040-1122

CONTRACTOR: Allied Construction SUBCONTRACTORS:
 ADDRESS: 208 Fore Street, Portland, ME 04104

Est. Construction Cost: 3,227,819 Type of Use: 100,000 sq.ft. Hotel per attached plans

Past Use: _____
 Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____
 Conversion - Explain _____

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE
 Residential Buildings Only:
 # Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____

Floors:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Floor Material: _____

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather Exposure _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

For Official Use Only

Date September 23, 1988 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost \$3,227,819 Permit Expiration: _____
 Value/Structure _____ Ownership: _____ Public _____ Private _____
 Fee \$16,145.00

Ceiling:
 1. Ceiling Joists Size: _____
 2. Ceiling Strapping Size _____ Spacing _____
 3. Type Ceilings: _____
 4. Insulation Type _____ Size _____
 5. Ceiling Height: _____

Roof:
 1. Truss or Rafter Size _____ Span _____
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 4. Other _____

Chimneys:
 Type: _____ Number of Fire Places _____

Heating:
 Type of Heat: _____

Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Zoning:
 District A-B Street Frontage Req.: _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____ Side _____


Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt. _____ Special Exception _____
 Other (Explain) _____
 Date Approved: O.K. [Signature] Oct 3, 1988

Permit Received By [Signature] **PERMIT ISSUED**
 Signature of Applicant [Signature] **APPLICANT LETTER**
 Signature of GPC [Signature] Date 9-28-88
 Inspection Dates _____

1-11-89 - Progressing as per plans - minor cosmetic loss ends to finish up
5th of July. Fire Dept approved.
11/25/89 - Final house cleaning completed on 5th of the month -

PLOT PLAN

N



FEES (Breakdown From Front)	
Base Fee \$	_____
Subdivision Fee \$	_____
Site Plan Review Fee \$	_____
Other Fees \$16,145.00	_____
(Explain)	_____
Late Fee \$	_____

Inspection Record	Date
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____

COMMENTS

11/1/88 Grading the perimeter - preparing the foundation location, will place the footing in a few days.
Nov/88 -
Dec/88 - Erecting steel - Roof work completed - working on interior slab grading - placing concrete in some sections - have placed the swimming pool concrete - Heat is being provided and hang area is enclosed with plastic covers & tracked with Jim at the head office and I requested several fire extinguishers be placed through out the area in case one of the heaters creates a fire problem -

Signature of Applicant

Clare Dumaine for Allied Construction Co. Date 9-23-88



At the Portland International Jetport
1050 Westbrook Street
Portland, Maine 04102
Phone: (207) 775-2200

November 17, 1989


Lt. Wallace Garroway
Portland Fire Department
380 Congress Street
Portland, Maine 04101

Dear Lt. Garroway:

As we discussed, the stanpipe connections required by Class 3 will be installed by December 31, 1989. Also, the floor of alarm change you requested for the Simplex Fire Alarm System has been ordered today.

Thank you for your help and continued cooperation.

Sincerely,


ROBERT J. DUNFEY, JR.
EXECUTIVE DIRECTOR

RJD, JR.:bk1

040155

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee \$25. Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Hertz Corp. Phone # 774-6391

Address: 1049 Westbrook St. Ptd, ME 04102

LOCATION OF CONSTRUCTION 1049 Westbrook St.

Contractor: lessee Sub: _____

Address: _____ Phone # _____

Est. Construction Cost: \$500 Proposed Use: car rental/service

Past Use: _____ w shed

of Existing Res. Units _____ # of New Res. Units car rental/service

Building Dimensions L _____ W _____ Total (Sq. Ft. _____

Stories _____ # Bedrooms _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion construct shed - 8' x 22' - (for storage)

Foundation:

- Type of Soil: _____
- Set Backs - Front _____ Rear _____ Side(s) _____
- Footings Size: _____
- Foundation Size: _____
- Other _____

Floor:

- Sills Size: _____ Sills must be anchored.
- Girder Size: _____
- Lally Column Spacing: _____ Size: _____
- Joists Size: _____ Spacing 16" O.C.
- Bridging Type: _____ Size: _____
- Floor Sheathing Type: _____ Size: _____
- Other Material: _____

Exterior Walls:

- Studding Size _____ Spacing _____
- No. windows _____
- No. Doors _____
- Header Sizes _____ Span(s) _____
- Bracing: Yes _____ No _____
- Corner Posts Size _____
- Insulation Type _____ Size _____
- Sheathing Type _____ Size _____
- Siding Type _____
- Masonry Materials _____
- Metal Materials _____

Interior Walls:

- Studding Size _____ Spacing _____
- Header Sizes _____ Span(s) _____
- Wall Covering Type _____
- Fire Wall if required _____
- Other Materials _____

For Official Use Only

Date 2/24/94 Subdivision: _____

Inside Fire Limits: _____ Name: _____

Bldg Code _____ Lot: 1049

Time Limit _____ Ownership: _____ Public: _____

Estimated Cost: 500 City of Portland

HISTORIC PRESERVATION

1. Ceiling Joists Size: _____

2. Ceiling Strapping Size _____ Spacing _____ Not in District nor Landmark.

3. Type Ceilings: _____ Does not require review.

4. Insulation Type _____ Size _____

5. Ceiling Height: _____ Requires Review

Roof:

1. Truss or Rafter Size _____ Span _____ Action: Approved

2. Sheathing Type _____ Size _____ Approved w/o Conditions.

3. Roof Covering Type: _____

Chimneys:

Type: _____ Number of Fire Places _____ Date: _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____

2. Pool Size: _____ Square Footage _____

3. Must conform to National Electrical Code and State Law.

PERMIT ISSUED

Permit Received By Louise

Signature of Applicant Edward Madden Date 2-24-94

CEO's District 2 Edward Madden

CONTINUED TO REVERSE SIDE [4] Mr. Carroll

Ivory Tag - CEO

White - Tax Assessor

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

PROPERTY ADDRESS

Town Or Plantation	PORTLAND
Street	INTERNATIONAL JETPORT
Subdivision Lot #	LOT 8A
PROPERTY OWNERS NAME	
CITY OF PORTLAND	
Last:	First:
Applican. Name:	TRAPPER BROWN CORP.
Billing Address of Owner/Applicant (If Different)	RD 3 BOX 94 PLYMOUTH, NEW HAMPSHIRE 03264

PORTLAND PERMIT # 2,797 TOWN COPY

10317188

\$ 110 FEE Double Fee Charged

L.P.I. #

Local Plumbing Inspector Signature

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules.

6/25/87

Signature of Owner/Applicant

Date

Local Plumbing Inspector Signature

Date Approved

PERMIT INFORMATION

THIS APPLICATION IS FOR:

- NEW SYSTEM
- REPLACEMENT SYSTEM: *10 1988*
- EXPANDED SYSTEM
- SEASONAL CONVERSION
- EXPERIMENTAL SYSTEM

THIS APPLICATION REQUIRES:

- NO RULE VARIANCE REQUIRED
- NEW SYSTEM VARIANCE
Attach New System Variance Form
- REPLACEMENT SYSTEM VARIANCE
Attach Replacement System Variance Form
- Requires only Local Plumbing Inspector Approval
- Requires both State and Local Plumbing Inspector Approval

INSTALLATION IS COMPLETE SYSTEM

- NON-ENGINEERED SYSTEM
- PRIMITIVE SYSTEM
(Includes Alternative Toilet)
- ENGINEERED (+2000 gpd)

INDIVIDUALLY INSTALLED COMPONENTS:

- TREATMENT TANK (ONLY)
- HOLDING TANK
- ALTERNATIVE TOILET (ONLY)
- NON-ENGINEERED DISPOSAL AREA (ONLY)
- ENGINEERED DISPOSAL AREA (ONLY)
- SEPARATED LAUNDRY SYSTEM

IF REPLACEMENT SYSTEM:

YEAR FAILING SYSTEM INSTALLED _____

THE FAILING SYSTEM IS:

- BED
- CHAMBER
- TRENCH
- OTHER: _____

DISPOSAL SYSTEM TO SERVE:

- SINGLE FAMILY DWELLING
- MODULAR OR MOBILE HOME
- MULTIPLE FAMILY DWELLING
- OTHER: REPAIR HANGER
SPECIFY _____

TYPE OF WATER SUPPLY
PUBLIC WATER

SIZE OF PROPERTY

81,750 SF ±

ZONING

AIRPORT/BUSINESS

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK

- SEPTIC: Regular Low Profile
- AEROBIC

SIZE: 1200 GALS.
MINIMUM

WATER CONSERVATION

- NONE
- LOW VOLUME TOILET
- SEPARATED LAUNDRY SYSTEM
- ALTERNATIVE TOILET

SPECIFY: _____

PUMPING

- NOT REQUIRED
- MAY BE REQUIRED
(DEPENDING ON TREATMENT TANK LOCATION AND ELEVATION)
- REQUIRED

DOSE: _____ GALS.

CRITERIA USED FOR DESIGN FLOW (BEDROOMS, SEATING, EMPLOYEES, WATER RECORDS, ETC.)

50 WORKMEN/DAY
MAXIMUM @
15 GALLONS/DAY/MAN

SOIL CONDITIONS USED FOR DESIGN PURPOSES

PROFILE | CONDITION
9 | C

DEPTH TO LIMITING FACTOR: 17

SIZE RATINGS USED FOR DESIGN PURPOSES

- SMALL
- MEDIUM
- MEDIUM-LARGE
- LARGE
- EXTRA LARGE

DISPOSAL AREA TYPE/SIZE

- BED _____ Sq. Ft.
- CHAMBER 1875 Sq. Ft.
 REGULAR H-20
- TRENCH _____ Linear Ft.
- OTHER: _____

DOMESTIC WASTE ONLY

DESIGN FLOW: 750 (GALLONS/DAY)

SITE EVALUATOR STATEMENT

On JUNE 8, 1987 (date)

USED 75 INFILTRATOR POLYETHYLENE CHAMBERS IN TRENCH CONFIGURATION

I conducted a site evaluation for this project and certify that the data reported is accurate. The system I propose is in accordance with the Subsurface Wastewater Disposal Rules.

William B. Gardner
Site Evaluator or Professional Engineer's Signature

0003/4814
SE# / PE#


6/25/87
Date

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering

Town, City, Plantation: **PORTLAND** Street, Road, Subdivision: **INTERNATIONAL JETPORT LOT 8A** Owners Name: **CITY OF PORTLAND**

SITE PLAN Scale 1" = 100 Ft. **SITE LOCATION PLAN** (Attach Map from Maine Atlas for New System Variance)



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)																		
Observation Hole <u>1</u> <input checked="" type="checkbox"/> Test Pit <input type="checkbox"/> Boring		Observation Hole <u>2</u> <input checked="" type="checkbox"/> Test Pit <input type="checkbox"/> Boring																
3' SOD " Depth of Organic Horizon Above Mineral Soil		2' SOD " Depth of Organic Horizon Above Mineral Soil																
Texture	Consistency	Color	Mottling															
CLAY LOAM	LOOSE	GRAY BROWN	NONE															
MARINE CLAY	FIRM	GRAY	FEW															
<table border="1"> <tr> <td>Soil Profile: <u>9</u></td> <td>Classification: <u>C</u></td> <td>Slope: <u>1</u> %</td> <td>Limiting Factor: <u>17</u></td> <td><input checked="" type="checkbox"/> Ground Water</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td><input type="checkbox"/> Restrictive Layer</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td><input type="checkbox"/> Bedrock</td> </tr> </table>				Soil Profile: <u>9</u>	Classification: <u>C</u>	Slope: <u>1</u> %	Limiting Factor: <u>17</u>	<input checked="" type="checkbox"/> Ground Water					<input type="checkbox"/> Restrictive Layer					<input type="checkbox"/> Bedrock
Soil Profile: <u>9</u>	Classification: <u>C</u>	Slope: <u>1</u> %	Limiting Factor: <u>17</u>	<input checked="" type="checkbox"/> Ground Water														
				<input type="checkbox"/> Restrictive Layer														
				<input type="checkbox"/> Bedrock														
Texture	Consistency	Color	Mottling															
LOAMY CLAY	FRIABLE	GRAY BROWN	NONE															
CLAYEY SAND	LOOSE	YELLOW GRAY																
MARINE CLAY	FIRM	GRAY	FEW															
<table border="1"> <tr> <td>Soil Profile: <u>9</u></td> <td>Classification: <u>C</u></td> <td>Slope: <u>1</u> %</td> <td>Limiting Factor: <u>18</u></td> <td><input checked="" type="checkbox"/> Ground Water</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td><input type="checkbox"/> Restrictive Layer</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td><input type="checkbox"/> Bedrock</td> </tr> </table>				Soil Profile: <u>9</u>	Classification: <u>C</u>	Slope: <u>1</u> %	Limiting Factor: <u>18</u>	<input checked="" type="checkbox"/> Ground Water					<input type="checkbox"/> Restrictive Layer					<input type="checkbox"/> Bedrock
Soil Profile: <u>9</u>	Classification: <u>C</u>	Slope: <u>1</u> %	Limiting Factor: <u>18</u>	<input checked="" type="checkbox"/> Ground Water														
				<input type="checkbox"/> Restrictive Layer														
				<input type="checkbox"/> Bedrock														

D. Williams B. Jordan 0003 / 4814
Site Evaluator or Professional Engineer's Signature

6/25/87
Date

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering

Town, City, Plantation
PORTLAND

Street, Road, Subdivision
INTERNATIONAL JETPORT LOT 8A

Owners Name
CITY OF PORTLAND

SITE PLAN

Scale 1" = _____ Ft.

SITE LOCATION PLAN (Attach
Map from Maine Atlas for
New System Variance)

SOIL DESCRIPTION AND CLASSIFICATION

(Location of Observation Holes Shown Above)

Observation Hole 3 Test Pit Boring
3" SOD * Depth of Organic Horizon Above Mineral Soil

Observation Hole 4 Test Pit Boring
3" SOD * Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (Inches)	Texture	Consistency	Color	Mottling
0	LOAMY CLAY	FRIABLE	GRAY	
6	CLAY LOAM	LOOSE	GRAY BROWN	NONE
15	MARINE CLAY	FIRM	GRAY	FEW
20				
30				
40				
50				

DEPTH BELOW MINERAL SOIL SURFACE (Inches)	Texture	Consistency	Color	Mottling
0	LOAMY CLAY	FRIABLE		
6	CLAY LOAM	LOOSE	GRAY BROWN	NONE
15	MARINE CLAY	FIRM	GRAY	FEW
20				
30				
40				
50				

Soil Profile 9 Classification C Slope 1 % Limiting Factor II
 Ground Water
 Restrictive Layer
 Bedrock

Soil Profile 9 Classification C Slope 1 % Limiting Factor 15
 Ground Water
 Restrictive Layer
 Bedrock

William B. Goodwin 0003/4814
Site Evaluator or Professional Engineer's Signature SE # / PE #

6/25/87
Date

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering


Town, City, Plantation
PORTLAND

Street, Road, Subdivision
INTERNATIONAL JETPORT LOT 8A

Owners Name
CITY OF PORTLAND

SUBSURFACE WASTEWATER DISPOSAL PLAN


Scale 1" = 20' Ft.



FILL REQUIREMENTS		CONSTRUCTION ELEVATIONS		ELEVATION REFERENCE POINT LOCATION & DESCRIPTION	
Depth of Fill (Upslope)	15'	Reference Elevation Is	38.22	TOP OF HYDRANT NUT	
Depth of Fill (Downslope)	27'	Bottom of Disposal Area	35.73	HYDRANT AT END OF TAXIWAY "H"	
		Top of Distribution Lines or Chambers	36.98		

DISPOSAL AREA CROSS SECTION

Scale:
Vertical: 1 Inch = 4' Ft.
Horizontal: 1 Inch = 10' Ft.



William B. Lovelace
Site Evaluator or Professional Engineer's Signature

0003/4814
SE #1/PE #

6/25/07
Date

Page 3 of 3
HHE-200 Rev. 4/03