



APPLICATION FOR PERMIT

DEPARTMENT OF BUILDING INSPECTIONS SERVICES

ELECTRICAL INSTALLATIONS

Date January 23, 1989, 19
 Receipt and Permit number 2997

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Jetport Suites Hotel
 OWNER'S NAME: _____ ADDRESS: _____ Road at Jetport

	FEES
OUTLETS:	
Receptacles <u>1969</u> Switches <u>1490</u> Plugmold _____ ft. TOTAL <u>3459</u>	344.90
FIXTURES: (number of)	
Incandescent <u>1163</u> Fluorescent <u>160</u> (not strip) TOTAL <u>1323</u>	134.30
Strip Fluorescent <u>839</u> ft.	12.89
SERVICES:	
Overhead _____ Underground <u>XX</u> Temporary _____ TOTAL amperes <u>3000</u>	10.00
METERS: (number of) <u>1</u>	.50
MOTORS: (number of)	
Fractional <u>59</u>	29.50
1 HP or over <u>18</u>	18.00
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) <u>XX</u>	5.00
Oil or Gas (by separate units) _____	
Electric Under 20 kws <u>21</u> Over 20 kws _____	5.00
APPLIANCES: (number of)	
Ranges _____	
Cook Tops _____	
Wall Ovens _____	
Dryers _____	
Fans _____	
Water Heaters <u>1</u>	
Disposals _____	
Dishwashers _____	
Compactors _____	
Others (denote) <u>9 Misc. Kitchen Equip</u>	22.50
TOTAL <u>15</u>	
MISCELLANEOUS: (number of)	
Branch Panels <u>29</u>	29.00
Transformers <u>13</u>	26.00
Air Conditioners Central Unit <u>10</u> Ac. Units. (Separate) _____	50.00
Separate Units (windows) <u>197</u>	394.00
Signs 20 sq. ft. and under <u>1</u>	2.50
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	5.00
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	3.00
Emergency Generators <u>1</u>	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) TOTAL AMOUNT DUE: <u>1094.09</u>	

INSPECTION: Will be ready on _____, 19__; or Will Call XX

CONTRACTOR'S NAME: Favorall Elec.
 ADDRESS: 37 Jordan Ave.

TEL: 725-2005 SIGNATURE OF CONTRACTOR: _____
 MASTER LICENSE NO.: 04232
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 25978
Location Wichita Falls, TX

Owner _____

Date of Permit 1/23/89

Final Inspection 1/24/89

By Inspector [Signature]

Permit Application Register Page No. 54

INSPECTIONS: Service 3000 amps by Ernest Cleaver
Service called in 5/10/89
Closing-in 5/26/89 by [Signature]

PROGRESS INSPECTIONS: _____

CODE
COMPLIANCE
COMPLETED
DATE _____

DATE:	REMARKS:
8/25/89	Checked panels & Bonding floors + floor 3
10/26/89	Final for Conf A Basement, 1st, 2nd & 3rd floors only of all equipment rooms must be locked and access to authorized personnel only
11/14/89	Final for Conf A floors 4, 5, 6 & 7 for Conf 5th floor equipment room - flexible metal conduit is changed for conduit body

APPROVED FOR THE CITY OF WICHITA FALLS

PERMIT # **002555**

TOWN OF Portland

BUILDING PERMIT APPLICATION

MAP # _____

LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form
OWNER: Portland Jetport Hotel Associates CALL WHEN READY
(Brenda - 775-2200)

Address: 1050 Westbrook St., Portland 04102

LOCATION OF CONSTRUCTION 1050 Westbrook St.

CONTRACTOR: Alliea Construction SUBCONTRACTORS: 772-1069

ADDRESS: same (located in hotel lobby)

Est. Construction Cost: _____ Type of Use: Quality Suites hotel

Part Use: _____

Building Dimensions: L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain to erect new free standing sign. 168 sq ft.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE 1 plot plan, 1 visual
Residential Buildings Only: _____ and 1 consent form
Of Dwelling Units _____ # Of New Dwelling Units _____ submitted.

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side: _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____
5. Bracing: Yes _____ No _____ Span(s) _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____
10. Masonry Materials _____ Weather Exposure _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Size _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

[B] Fred Williams

White-Tax Assessor

Yellow-GPCOG

White Tag -CEO

© Copyright GPCOG 1987

For Official Use Only

Date Sept. 6, 1989 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost _____ Permit Expiration: _____
 Value/Structure _____ Ownership: _____
 Fee \$58.64 _____ Public _____
 _____ Private _____

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceilings: _____
4. Insulation Type _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____
4. Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Advised No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning:

District A-B Street Frontage Req: _____ Provided _____
Required Setbacks: Front _____ Back _____ Side _____

Review:

Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt _____ Special Exception _____
 Other (Explain) _____
 Date Approved: 9-6-89

Permit Received By Nancy Grossman

Signature of Applicant Brenda Date _____

Signature of CEO _____ Date _____

Inspection Dates _____

PLOT PLAN




FEES (Breakdown From Front)

Base Fee \$	58.64
Subdivision Fee \$	
Site Plan Review Fee \$	
Other Fees \$	
(Explain)	
Late Fee \$	

Type	Inspection Record	Date
		/ /
		/ /
		/ /
		/ /
		/ /

COMMENTS

4/6/59 In place as per plan



Signature of Applicant

Brenda H. Harmon
as agent for owner

Date

4/6/59

FOR Branda
 DATE 8/31/89 TIME _____ AM
 FROM Mel
 FIRM Advanced Signage
 PHONE 1050 Westbrook St
 AREA CODE _____ NUMBER _____ EXTENSION _____

TELEPHONED		PLEASE CALL	
RETURNED YOUR CALL		WILL CALL AGAIN	
CAME TO SEE YOU		RUSH	
WANTS TO SEE YOU		SPECIAL ATTENTION	
WAITING TO SEE YOU		HOLDING LINE	

MESSAGE Steel and Aluminum
Face Materials - Panaflex
Lower Cabinets - Lexan
RSD, JR has blue print w/all info
which should be included w/ permit

SIGNED _____

TOPS  FORM 4007


MESSAGE



At the Portland International Jetport
1050 Westbrook Street
Portland, Maine 04102
Phone: (207) 775-2200

TO: WHOMEVER IT MAY CONCERN
FROM: ROBERT J. DUNFEY, JR.
DATE: AUGUST 30, 1989
RE: PERMANENT SIGN APPLICATION

I, ROBERT J. DUNFEY, JR., owner of property located
at 1050 Westbrook Street, give Brenda K. Larson
permission to complete PERMANENT SIGN APPLICATION
for THE QUALITY SUITES HOTEL sign.



ROBERT J. DUNFEY, JR.

RECEIVED

SEP 06 1989

DEPT OF BUILDING INSPECTIONS
CITY OF PORTLAND

GRANITE CURB
ONC CURB



COORDINATE

POINT	NC
A	298

E	298
---	-----

NOTES:

- BOUNDARY AND BY OWEN HA
- REFERENCE IS AND WESTBROOK DUNFEY PROP DATED APRIL
- AREA = 2.78

1050
Westbrook
St.

RECEIVED

SEP 06 1989

DEPT. OF BUILDING INSPECTIONS
CITY OF PORTLAND

**CONTRACT WORK *
S HOTEL CONTRACT**

- 14 2-15-89 PARKING EXPANSION SJB
- 13 12-14-88 BLDG FOOTPRINT R/W SJB
- 12 9-8-88 PUBLIC R/W SJB
- 11 8-30-88 ENTRANCE DRIVE REV. SJB
- 10 8-3-88 PROPERTY LINES REVISED A NOTE



PERMIT # 002555

TOWN OF Portland

BUILDING PERMIT APPLICATION

MAP # _____

LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form. CALL WHEN READY

Owner: Portland Jetport Hotel Associates (Brenda - 775-2200)

Address: 1050 Westbrook St., Portland 04102

LOCATION OF CONSTRUCTION: 1050 Westbrook St.

CONTRACTOR: Allied Construction SUBCONTRACTORS: 772-1069

ADDRESS: same (located in hotel lobby)

Est. Construction Cost: _____ Type of Use: Quality Suites hotel

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain to erect new free standing sign. 168 sq ft.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE 1 plot plan, 1 visual

Residential Buildings Only: _____ and 1 consent form

Of Dwelling Units _____ # Of New Dwelling Units _____ submitted.

Foundation:

- 1. Type of Soil: _____
- 2. Set Backs - Front _____ Rear _____ Side(s) _____
- 3. Footings Size: _____
- 4. Foundation Size: _____
- 5. Other _____

Floor:

- 1. Sills Size: _____ Sills must be anchored.
- 2. Girder Size: _____
- 3. Lolly Column Spacing: _____ Size: _____
- 4. Joists Size: _____ Spacing 16" O.C.
- 5. Bridging Type: _____ Size: _____
- 6. Floor Sheathing Type: _____ Size: _____
- 7. Other Material: _____

Exterior Walls:

- 1. Studding Size _____ Spacing _____
- 2. No. windows _____
- 3. No. Doors _____
- 4. Header Sizes _____ Spau(s) _____
- 5. Bracing: Yes _____ No _____
- 6. Corner Posts Size _____
- 7. Insulation Type _____ Size _____
- 8. Sheathing Type _____ Size _____
- 9. Siding Type _____ Weather Exposure _____
- 10. Masonry Materials _____
- 11. Metal Materials _____

Interior Walls:

- 1. Studding Size _____ Spacing _____
- 2. Header Size _____ Span(s) _____
- 3. Wall Covering Type _____
- 4. Fire Wall if required _____
- 5. Other Materials _____

For Official Use Only

Date Sept. 6, 1989 Subdivision: Yes / No _____

Inside Fire Limits _____ Name _____

Bldg Code _____ Lot _____

Time Limit _____ Block _____

Estimated Cost _____ Permit Expiration: _____

Value/Structure _____ Ownership: _____ Public _____ Private _____

Fee \$58.64

Ceiling:

- 1. Ceiling Joists Size: _____
- 2. Ceiling Strapping Size _____ Spacing _____
- 3. Type Ceilings: _____
- 4. Insulation Type: _____
- 5. Ceiling Height: _____

PERMIT ISSUED

Roof:

- 1. Truss or Rafter Size _____ Span SEP 7 1989
- 2. Sheathing Type _____ Size _____
- 3. Roof Covering Type _____
- 4. Other _____

City Of Portland

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

- 1. Approval of soil test if required Yes _____ No _____
- 2. No. of Tubs or Showers _____
- 3. No. of Flushes _____
- 4. No. of Lavatories _____
- 5. No. of Other Fixtures _____

Swimming Pools:

- 1. Type: _____
- 2. Pool Size: _____ Square Footage _____
- 3. Must conform to National Electrical Code and State Law.

Zoning:

District _____ Street Frontage Req.: _____ Provided _____

Review Required:

Required Setbacks: Front _____ Back _____ Side _____

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt. _____ Special Exception _____

Other (Explain) _____

Date Approved _____

Permit Received By Nancy Grossman

Signature of Applicant Brenda K. Hanson Date 9/6/89

Signature of CEO _____ Date _____

Inspection Dates 8 FW

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Jetport Hotel Associates
 Address: PO Box 7312, DTS, Portland, 04112
 LOCATION OF CONSTRUCTION: 1050 Westbrook St.
 CONTRACTOR: Allied Construction SUBCONTRACTORS: _____
 ADDRESS: (located in hotel lobby)

Est. Construction Cost: \$30,000 Type of Use: hotel
 Past Use: mail to: Dunley Properties, 130 Middle St, 3rd Fl, Portland 04101
 Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____
 Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____
 Conversion - Explain constructing new awning. (front entrance canopy)

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE
 Residential Buildings Only: _____ 1 consent form, 2 visuals submitted.
 # Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____

Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather Exposure: _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

For Official Use Only

Date N Sept. 6, 1989 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost: \$30,000 Permit Expiration: _____
 Value Structure _____ Ownership: _____ Public _____ Private _____
 Fee: \$175.00

Ceiling:
 1. Ceiling Joists Size: _____ Spacing _____
 2. Ceiling Strapping Size _____
 3. Type Ceilings: _____
 4. Insulation Type _____
 5. Ceiling Height: _____

1. Truss or Rafter Size _____
 2. Sheathing Type _____
 3. Roof Covering Type _____
 4. Other _____

Chimney: Type: _____ Number of Fire Places: _____

Heating: Type of Heat: _____

Electrical: Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Zoning: District _____ Street Frontage Req.: _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt. _____ Special Exception _____
 Other (Explain) _____
 Date Approved _____

Permit Received By Nancy Grossman

Signature of Applicant Wm. Michael Patton Date 9-6-89
AS AGENT FOR OWNER

Signature of CEO _____ Date _____

Inspection Dates (8) FW

PERMIT # 1201 TOWN OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Dunfey Group - Jetport Assoc.

Address: Westbrook St., Portland, ME

LOCATION OF CONSTRUCTION 1050 Westbrook Street

CONTRACTOR: Allied Const. SUBCONTRACTORS Sprinkler Systems, Inc

ADDRESS: Fore St., Portland P.O. Box 1285, Lewiston, ME

Est. Construction Cost: \$122,000.00 Type of Use: Hotel

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

_____ Conversion - Explain To install sprinkler system for commercial

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE bdg. - throughout, as

Residential Buildings Only: _____ per 2 sets of plans.

Of Dwelling Units _____ # Of New Dwelling Units 2 sets of plans.

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other: _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall If required _____
5. Other Materials _____

For Official Use Only

Date <u>November 27, 1989</u>	Subdivision: Yes / No _____
Inside Fire Limits _____	Name _____
Bldg Code _____	Lot _____
Time Limit _____	Block _____
Estimated Cost <u>\$122,000.00</u>	Permit Expiration: _____
Value Structure _____	Ownership _____ Public _____ Private _____
Fee <u>\$630.00</u>	

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceilings: _____
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____
4. Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning:

District _____ Street Frontage Req. _____ Provided _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt. _____ Special Exception _____

Other (Explain): _____


Date Approved: _____

Permit Received By Joyce M. Rinaldi

Signature of Applicant [Signature] Date 11-27-89

Signature of CEO [Signature] Date 12-6-89

Inspection Dates _____





CITY OF PORTLAND, MAINE

399 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 874-8300

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

Date: 11 December, 1989

Address: Dunfey Group - Jetport Association
1050 Westbrook Street
Portland, Maine

RE: 1050 Westbrook Street; Portland, Maine

Dear Sir:

Your application to install sprinkler system has been reviewed and a permit is herewith issued subject to the following requirement:

No certificate of occupancy can be issued until all requirements of this letter are met.

Revision of 11-20-89 for stand pipe valve arrangement to include a minimum of a 2 1/2 " national standard thread valve on each level of the stairwell, second through sixth floors; and a minimum of a 2 1/2 " national standard thread valve in the corridor wall - either in a recessed space or a cabinet equipped with a 2 1/2 " to 1 1/2" reducer - 1 1/2 " thread to be iron pipe standard. All valves to be capped with a screw-on cap.

If you have any questions regarding these requirements, Please do not hesitate to contact this office.

Sincerely,

P. Samuel Hoffses
Chief of Inspection Services

lec

cc: Lt. Garroway; P.F. D.

PERMIT #002560

TOWN OF Portland BUILDING PERMIT APPLICATION

MAP # LOT #

Owner: Jetport Hotel Associates
Address: PO Box 7312, DTS, Portland, 04112

LOCATION OF CONSTRUCTION: 1050 Westbrook St.

CONTRACTOR: Allied Construction SUBCONTRACTORS:

ADDRESS: (located in hotel lobby)

Est. Construction Cost: \$30,000 Type of Use: hotel

Past Use: mixed use, 130 Middle St

Building Dimensions L W Sq. Ft. # Stories: 761-4606 3rd FL. Lot Size: Portland

Is Proposed Use: Conversion - Explain: constructing new awning, (front entrance canopy)
Seasonal Condominium Apartment

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE 1 consent form, 2 visuals submitted.
Residential Buildings Only: # Of Dwelling Units # Of New Dwelling Units

Foundation:
1. Type of Soil:
2. Set Backs - Front Rear Side(s)
3. Footings Size:
4. Foundation Size:
5. Other:

Floor:
1. Sills Size: Sills must be anchored.
2. Girder Size:
3. Lally Column Spacing: Size:
4. Joists Size: Spacing 16" O.C.
5. Bridging Type: Size:
6. Floor Sheathing Type: Size:
7. Other Material:

Exterior Walls:
1. Studding Size Spacing
2. No. windows
3. No. Doors
4. Header Sizes
5. Bracing: Yes No Span(s)
6. Corner Posts Size
7. Insulation Type Size
8. Sheathing Type Size
9. Siding Type Weather Exposure
10. Masonry Materials
11. Metal Materials

Interior Walls:
1. Studding Size Spacing
2. Header Size Span(s)
3. Wall Covering Type
4. Fire Wall if required
5. Other Materials

For Official Use Only
Date: Sept. 6, 1989
Subdivision: Yes / No
Name:
Bldg Code:
Lot:
Time Limit:
Estimated Cost: \$30,000
Value/Structure:
Fee: \$175.00
Ownership: Public Private

Ceiling:
1. Ceiling Joists Size:
2. Ceiling Strapping Size Spacing
3. Type Ceilings:
4. Insulation Type:
5. Ceiling Height:
PERMIT ISSUED
SEP 8 1989
City of Portland

Chimneys: Type: Number of Fire Places
Heating: Type of Heat:
Electrical: Service Entrance Size: Smoke Detector Required Yes No

Plumbing:
1. Approval of soil test if required
2. No. of Tubs or Showers
3. No. of Flushes
4. No. of Lavatories
5. No. of Other Fixtures
Swimming Pools:
1. Type:
2. Pool Size: x Squ. Footage
3. Must conform to National Electrical Code and State Law.

Zoning: District: AB Street Frontage Req.: Provided:
Required Setbacks: Front Back Side Side
Review Required:
Zoning Board Approval: Yes No Date:
Planning Board Approval: Yes No Date:
Conditional Use: Variance: Site Plan Subdivision:
Shore and Floodplain Mgmt. Special Exception:
Other: (Explain)
Date Approved: 9-2-89

Permit Received By: Nancy Grossman
Signature of Applicant: Nancy Grossman Date: 9-6-89
Signature of CEO: AS AGENT FOR OWNER Date:

Inspection Dates:
White-Tax Assessor Yellow-GPCOG
© Copyright GPCOG 1987

Fred Williams

White-Tax Assessor Yellow-GPCOG

© Copyright GPCOG 1987

PLOT PLAN



FEEES (Breakdown From Front)

Base Fee \$ 175.00
Subdivision Fee \$ _____
Site Plan Review Fee \$ _____
Other Fees \$ _____
(Explain) _____
Late Fee \$ _____

Type

Inspection Record

Date

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS

10/27/89 On-plate

Signature of Applicant

Wm. Michael J. Falter
AS AGENT FOR THE OWNER

Date

9.6.89



At the Portland International Jetport
1050 Westbrook Street
Portland, Maine 04102
Phone: (207) 775-2200

TO: NANCY & MARGE
ROOM 315
CITY HALL

RE: PERMIT/QUALITY SUITES HOTEL
STEEL ERECTION ON MONDAY BY
MEGQUIRER & JONES OF MAINE
BAY CANVASS AWNING PLANS

RECEIVED

SEP 08 1989

DEPT OF PLANNING
CITY OF PORTLAND

THANK YOU FOR ALL YOUR HELP IN GETTING THIS PERMIT
TO US SO THE STEEL CAN BE ERECTED ON MONDAY.

ENCLOSED IS THE SIGNED CHECK....ALSO ENCLOSED IS A
COPY OF THE FLAME RETARDANT CERTIFICATE FOR YOUR
INFORMATION.

THE AWNINGS THEMSELVES WILL NOT BE UP FOR SOME TIME
AS THEY ARE IN THE PROCESS OF BEING CONSTRUCTED.

PLEASE GIVE ME A CALL IF YOU HAVE ANY QUESTIONS AND
I CAN BE OF HELP.

JUNE ALICE HAYES
EXECUTIVE ASSISTANT
DUNFEY PROPERTIES
130 MIDDLE STREET
PORTLAND, ME. 04101

9/8/89

207/761-4606


P.S.: IF IT IS POSSIBLE TO BE ADVISED THAT THE PERMIT
IS READY I WOULD BE HAPPY TO HAVE INTOWN COURIER
PICK IT UP FOR US. MANY, MANY THANKS!

\$175

WRITTEN CONSENT AND AGREEMENT RELATING TO A CERTAIN SIGN OR AWNING PROPOSED TO BE ERECTED ON A BUILDING AT 1050 Westbrook St IN PORTLAND, MAINE Portland Jetport Hotel Associates being the owner of the premises at 130 Middle St in Portland, Maine hereby gives consent to the erection of a certain sign owned by Portland Jetport Hotel Associates over the sidewalk or on the building from said premises as described in application to the Division of Inspection Services of Portland, Maine for a permit to cover the erection of said sign:

And in consideration of the issuance of said permit Portland Jetport Hotel Associates owner of said premises, in event said sign shall cease to serve the purpose for which it was erected or shall become dangerous and in event the owner of said sign shall fail to remove said sign or make it permanently safe in case the sign still serves the purpose for which it was erected, hereby agrees for himself or itself, for his heirs, its successors, and his or its assigns, to completely remove said sign is in such condition and of order from him to remove it.

In Witness whereof, the owner of said premises has signed this consent and agreement this _____ day of _____ 19 ____.



Owner's signature
President
Portland Jetport Hotel Corp.
General Partner of
Portland Jetport Hotel Associates

Lessee's signature

RECEIVED

SEP 06 1989

DEPT OF BUILDING AND PERMITS
CITY OF PORTLAND

PERMIT # 000013 TOWN OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Durfee Group- Jetport Assoc.

Address: Westbrook St., Portland, ME

LOCATION OF CONSTRUCTION 1950 Westbrook Street

CONTRACTOR: Allied Const. SUBCONTRACTORS Sprinkler Systems, Inc

ADDRESS: Fore St., Portland P.O. Box 1285, Lewiston, ME

Est. Construction Cost: \$122,000.00 Type of Use: Hotel

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain To install sprinkler system for commercial bldg. - throughout, as per 2 sets of plans.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: _____ # Of Dwelling Units _____ # Of New Dwelling Units 2 sets of plans.

Foundation:

- Type of Soil: _____
- Set Backs - Front _____ Rear _____ Side(s) _____
- Footings Size: _____
- Foundation Size: _____
- Other _____

Floor:

- Sills Size: _____ Sills must be anchored.
- Girder Size: _____
- Lally Column Spacing: _____ Size: _____
- Joists Size: _____ Spacing 16" O.C.
- Bridging Type: _____ Size: _____
- Floor Sheathing Type: _____ Size: _____
- Other Material: _____

Exterior Walls:

- Studding Size _____ Spacing _____
- No. windows _____
- No. Doors _____
- Header Sizes _____ Span(s) _____
- Bracing: Yes _____ No _____
- Corner Posts Size _____
- Insulation Type _____ Size _____
- Sheathing Type _____ Size _____
- Siding Type _____ Weather Exposure _____
- Masonry Materials _____
- Metal Materials _____

Interior Walls:

- Studding Size _____ Spacing _____
- Header Size _____ Span(s) _____
- Wall Covering Type _____
- Fire Wall if required _____
- Other Materials _____

For Official Use Only

Date November 27, 1989 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost \$122,000.00 Permit Expiration: _____
 Value _____ Ownership: _____
 Fee \$630.00 Public _____ Private _____

Ceiling:

- Ceiling Joists Size: _____
- Ceiling Strapping Size _____ Spacing _____
- Type Ceilings: _____
- Insulation Type _____
- Ceiling Height: _____

Roof:

- Truss or Rafter Size _____ Span 12 Size 1989
- Sheathing Type _____
- Roof Covering Type Asph/Flt
- Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

- Approval of soil test if required Yes No _____
- No. of Tubs or Showers: _____
- No. of Flushes _____
- No. of Lavatories _____
- No. of Other Fixtures _____

Swimming Pools:

- Type: _____
- Pool Size: _____ x _____ Square Footage _____
- Must conform to National Electrical Code and State Law.

Zoning:

District _____ Street Frontage Req: _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____
 Shore and Floodplain Mgmt _____ Special Exception _____
 Other (Explain): _____
 Date Approved: _____

Permit Received By Joyce M. Rinaldi

Signature of Applicant _____ Date 11/27/89

Signature of CEO 11/27/89 Date 12-1-89

Inspection Dates _____

Handwritten: Rec'd by NW 12/1/89

PERMIT ISSUED

DEC 12 1989

Handwritten: City of Portland

PERMIT ISSUED WITH LETTER

Handwritten signature: [Signature]

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ 630.00 _____
 Subdivision Fee \$ _____
 Site Plan Review Fee \$ _____
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Inspection Record

Type	Date
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____

COMMENTS

4/90 - All sprinkler work completed as per plans
 fire dept approved & tested
 alarm system approved by F.D. of Elgin, Ill.

Signature of Applicant

Michael Lakey (Sub for owner)

Date

11/27/89

912688

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 300. Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Inn Touch Systems Inc Phone # 512-127
 Address: P O Box 3033 ; 2511. 15 1111
 LOCATION OF CONSTRUCTION 1057 Eastbrook St.
 Contractor: OWNER Sub: (Quality Suites)
 Address: _____ Phone # _____
 Est. Construction Cost: _____ Proposed Use: hotel / office
 Past Use: hotel
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion erect risck in hotel lobby

(aprx 25 sq ft)

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size: _____
8. Sheathing Type _____ Size: _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

For Official Use Only

Date: 6/5/91 Subdivision: _____
 Inside Fire Limits _____
 Bldg Code _____
 Time Limit _____
 Estimated Cost _____

Name: _____
 Lot: _____
 Ownership: _____ Public _____

PERMIT ISSUED
JUN 11 1991
CITY OF PORTLAND

Zoning: _____
 Street Frontage Provided: _____
 Provided Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
 Special Exception _____
 Other: WDA 2-10-91 (Explain) _____

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____ Met in District nor Lanacert.
3. Type Ceilings: _____ Does not require review.
4. Insulation Type _____ Size _____ Requires Review.
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____ Action: Approved.
2. Sheathing Type _____ Size _____ Approved with Condition
3. Roof Covering Type _____ Design _____

Chimneys:

Type: _____ Number of Fire Places: _____ Date: 6/5/91

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By: Louise F. Chase

Signature of Applicant: Alan S. Freedman Date: 6/5/91

Signature of CEO: _____ Date: _____

Inspection Dates: _____

10/2/91 White-Tax Assesor Yellow-GPCOG White-Tag-CEO 10/7/91 Only right 07306 1989

PLOT PLAN



FEE'S (Breakdown From Front)

Base Fee \$ 30-

Subdivision Fee \$ _____

Site Plan Review Fee \$ _____

Other Fees \$ _____

(Explain) _____

Late Fee \$ _____


Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS *Site completed as per plan*

Signature of Applicant *Wm S. Decker*


Date 6/5/91

10.50 Westbrook



FRONT VIEW

5'6"



Materials used: Plexiglass, laminates,
Birch, oak and ^{photo}transparencies, a telephone and
fluorescent lights. —

980613

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee \$970 Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

\$300 Minor Site Plan review

Embassy
 Owner: Quality Suites Hotel Phone # 775-2200
 Address: 1050 Westbrook St- Ptd, ME 04102 D.Hopkins
 LOCATION OF CONSTRUCTION 1050 Westbrook St.
 Contractor: Solar Design & Construction
 Address: Windham, ME Phone # _____
 Est. Construction Cost: 190,000 Proposed Use: hotel w addition
 Past Use: hotel
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion const addition for enclosed pool

For Official Use Only **PERMIT ISSUED**
 Date 6/15/93 Subdivision: _____
 Inside Fire Limits _____ Name: _____
 Bldg Code _____ Lot: _____
 Time Limit _____ Ownership: Public
 Estimated Cost: 190,000 Private
CITY OF PORTLAND
 Zoning: _____
 Street Frontage Provided: _____
 Provided Setbacks: Front _____ Back _____ Side _____
 Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
 Special Exception _____
 Other (Explain) 7-17-93

35'x50' - Minor Site Plan rev
 Foundation: Dumpster permit: 15-0101
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____
 Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Coiling: **HISTORIC PRESERVATION**
 1. Ceiling Joists Size: _____
 2. Ceiling Strapping Size _____ Spacing _____ Not in District nor Landmark
 3. Type Ceilings: _____ Does not require review
 4. Insulation Type _____ Size _____ Requires Review
 5. Ceiling Height: _____
 Roof: *********
 1. Truss or Rafter Size _____ Span _____ Approved
 2. Sheathing Type _____ Size _____ Approved with conditions
 3. Roof Covering Type _____
 Chimneys:
 Type: _____ Number of Fire Places _____ Date: _____
 Heating:
 Type of Heat: _____
 Electrical:
 Service Entrances Size: _____ Smoke Detector Required Yes _____ No _____
 Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____
 Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. winJows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____
 10. Masonry Materials _____
 11. Metal Materials _____
 Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

PERMIT ISSUED WITH LETTER

PERMIT ISSUED WITH LETTER

Permit Received By Louise E. Chase
 Signature of Applicant Donald W Hopkins Date 6-15-93
 Signature of CEO Donald W Hopkins O.K. Date 7-16-93
 Inspection Dates _____

White-Tax Assesor Yellow-GPCOG White Tag -CEO Copyright GPCOG 1988

930563

Permit # 930563 City of Portland BUILDING PERMIT APPLICATION Fee \$103. Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Embassy Suites Co Phone # 88X 775-2200
 Address: 1050 Westbrook St- Ptld, ME 04102
 LOCATION OF CONSTRUCTION 1050 Westbrook St.
 Contractor: Bail ey Sign Co Sub: XXXXXXXXXX 774-2843
 Address: 9 Thomas Dr- Westbrook Phone # ME 04092
 Est. Construction Cost: _____ Proposed Use: hotel w 2 signs
 Past Use: hotel
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion erect two signs - 64'x5' & 10'x7'

For Official Use Only	
Date <u>7/1/93</u>	Subdivision <u>JA 2 1993</u>
Inside Fire Limits _____	Name _____
Bldg Code _____	Owner <u>CITY OF PORTLAND</u>
Time Limit _____	Estimated Cost _____

Zoning:
 Street Frontage Provided: _____
 Provided Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
 Special Exception _____
 Other (Explain) _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____

Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Exterior Walls:
 1. Studing Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather Exposure _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studing Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

Ceiling:
 1. Ceiling Joists Size: _____ Not in District nor Landmark.
 2. Ceiling Strapping Size _____ Spacing _____ Does not require review.
 3. Type Ceilings: _____ Requires Review.
 4. Insulation Type _____ Size _____
 5. Ceiling Height: _____ *****?*****
 Action: Approved.

Roof:
 1. Truss or Rafter Size _____ Span _____
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 Date: 7/1/93
 Signature: [Signature]

Chimneys:
 Type: _____ Number of Fire Places _____

Heating:
 Type of Heat: _____

Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Fixtures _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Permit Received By Louise E. Chase

Signature of Applicant Kyle Noyes Date 7/1/93

Signature of CEO [Signature] Date _____

Inspection Dates _____

930563

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee \$103. Zone _____ Map # _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Embassy Suites Co Phone # 886 775-2200

Address: 1050 Westbrook St- Ptd, ME 04102

LOCATION OF CONSTRUCTION 1050 Westbrook St.

Contractor: VBailsey Sign Co Sub.: XXXXXXXX 774-2843

Address: 9 Thomas Dr- Westbrook Phone # ME 99 04092

Est. Construction Cost: _____ Proposed Use: hotel w 2 signs

_____ Past Use: hotel

of Existing Res. Units _____ # of New Res. Units _____

Building Dimensions L _____ W _____ Total Sq. Ft. _____

Stories: _____ # Bedrooms _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion erect two signs - 64'x5' & 10'x7'

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

PERMIT ISSUED	
For Official Use Only	
Date: 7/1/93	Subdivision: _____
Inside Fire Limits: _____	Name: _____
Bldg Code: _____	Ownership: _____
Time Limit: _____	_____ Private
Estimated Cost: _____	

Zoning: _____

Street Frontage Provided: _____

Provided Setbacks: Front _____ Back _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shoreland Zoning: Yes _____ No _____ Floodplain Yes _____ No _____

Special Exception _____

Other (Explain) _____

Ceiling:

1. Ceiling Joists Size: _____ Not in District nor Landmark
2. Ceiling Strapping Size _____ Spacing _____ Does not require review
3. Type Ceilings: _____ Size _____ requires review
4. Insulation Type _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Action: Approved
2. Sheathing Type _____ Size _____ Approved with Conditions
3. Roof Covering Type _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Louie E. Chase

Signature of Applicant Kyle Noyes Date 7/1/93

Signature of CEO _____ Date _____

Inspection Dates _____

White-Tax Assesor

Yellow-GPCOG

White Tag -CEO

© Copyright GFCOG 1988

Handwritten signature: M. Carroll

PLOT PLAN

N



FEES (Breakdown From Front)	Type	Inspection Record	Date
Base Fee \$ <u>103</u>			/ /
Subdivision Fee \$ _____			/ /
Site Plan Review Fee \$ _____			/ /
Other Fees \$ _____			/ /
(Explain) _____			/ /
Late Fee \$ _____			/ /

COMMENTS

Work Complete / never called / Express of 12/7/23

Signature of Applicant

Rick Adams

Date



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date 9/16/ 1993
 Receipt and Permit number 2336

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 1050 Westbrook Street

OWNER'S NAME: Quality Suite ADDRESS: 1050 Westbrook Street

	FEES
OUTLETS:	
Receptacles <u>1</u> Switches <u>4</u> Plugnold _____ ft. TOTAL <u>5</u>	1.00
FIXTURES: (number of)	
Incandescent <u>9</u> Fluorescent _____ (not strip) TOTAL _____	1.80
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____ ..	
METERS: (number of)	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) <u>1</u>	5.00
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels <u>1</u>	4.00
Transformers _____	
Air Conditioners Central Unit <u>1</u>	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground <u>1</u>	10.00
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery <u>1</u>	1.00
Emergency Generators _____	
INSTALLATION FEE DUE	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE	
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	
TOTAL AMOUNT DUE:	22.80

INSPECTION:

Will be ready on 9/16/93, 1993; or Will Call _____

CONTRACTOR'S NAME: Ames Electric

ADDRESS: P.O. 633 Portland, Maine

TEL.: 774-0604

MASTER LICENSE NO.: 2336

SIGNATURE OF CONTRACTOR:

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

1 S.F. 10'-0" X 7'-2" INTERN. ILLUM. SIGN CABINET WITH FLEX FACE & VINYL GRAPHICS

COLORS: CAB. & 2 1/4" RET. = TO MATCH GREEN VINYL. FACES = WHITE PANAFLEX FACE GREEN = 3-M GREEN VINYL V.T.-2362 TO BE SUPPLIED BY OTHERS

8'-4" V.O.



10'-0" SIGN CAB.

10'-0"

7'-2"

6'-0"

VINYL GRAPHIC SUPPLIED BY OTHERS



NOTE: PAINT BETWEEN
SIGN AND
MATCH GREEN FILM
3 M PVT-2362


WHITE

GREEN FILM OVERLAY
3 M PVT-2362

1/2" OUTLINE ON
"E" ON BACK SIDE
OF GREEN FILM
WILL APPEAR ONLY
WHEN LIGHT IS ON

NOTE:
LARGER VERSIONS
OF LOGO MAY HAVE
PAROLET FACES

FILM CONTACT -
Simplex Space-Bite
2315 WEST VERNON
P.O. BOX 1197B
NEW BRITAIN, CT 06053
TEL: (860) 269-6325
FAX: (860) 269-6325



scale 1/8" = 1'

NOTE: COLORS SHOWN HERE ARE BEFORE DISTRIBUTION ONLY - COLOR MATCH NOS. WILL BE NEEDED



9 Thomas Drive
Col. Westbrook, Executive Park
Westbrook, ME 04092
207-774-2843 / 1-800-639-SIGN

Customer
EMBASSEY SUITES

Location
1050 WESTBROOK STREET
PORTLAND, ME

Designer
L.W.MERRIFIELD

Salesperson
K. NOYES

6/2/93

VINYL NOTES

Scale 1/2" = 1'

Date 4/30/93

Job/W.O.# 2502


Sheet 3 of 4

(ACCEPTANCE SIGNATURE/DATE)



Project # D-942

Drawing # C-02664 C R1




1 SET OF 5'-0" CHANNEL NEON LETTERS ON 5'-0" X 64'-0" X 2" FABRICATED ALUM. B/G

COLORS: SIGNAGE WILL READ WHITE DURING DAYTIME HOURS & RED AT NITE


PAINT INSIDE & OUTSIDE OF CANS WHITE / USE CLEAR RED NEON FOR GREATER NITE VISIBILITY / FACES = CLEAR PLEXI TRIM = WHITE

B/G - TO BE FABRICATED OF ALUM WITH 2" ANGLE IRON SUPPORT - COLOR: BROWN TO MATCH BLDG. PMS # _____
SOFFIT = .060 METAL SHEETS BOLTED TO SUPPORTS WITH 1" DRAIN HOLES (SEE SECTION) COLOR = BROWN TO MATCH BLDG. PMS # _____




TYPEFACE WILL NEED TO BE MODIFIED TO ACCOMMODATE NEON

EMBASSY SUITES



NOTE: COLORS SHOWN HERE ARE BEFORE DISTRIBUTION ONLY - COLOR MATCH NOS. WILL BE NEEDED



9 Thomas Drive
Col. Westbrook Executive Park
Westbrook, ME 04092
207-774-2843 / 1-800-539-SIGN

Customer		EMBASSY SUITES	
Location		1050 WESTBROOK STREET PORTLAND, ME	
Designer	LMMERFIELD	Salesperson	K. NOYES
6/3/93	COLORS / SECTION		
Revised			
Scale	1/8" = 1'	Date	4/28/93
Job/W.O.#	2503	Sheet	1 of 3
(ACCEPTANCE SIGNATURE/DATE)		Drawing #	
Project #		C-020664 R1	
D-942			





APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date 12/15/93 19
 Receipt and Permit number 4645

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 1050 Westbrook St.
 OWNER'S NAME: Embassy Suites ADDRESS: _____

FEES

OUTLETS:
 Receptacles 2 Switches _____ Plugmold _____ ft. TOTAL 240

FIXTURES: (number of)
 Incandescent _____ Fluorescent _____ (not strip) TOTAL _____
 Strip Fluorescent _____ ft.

SERVICES:
 Overhead x Underground _____ Temporary _____ TOTAL amperes 100 .. 15.00

METERS: (number of) 1 1.00

MOTORS: (number of)
 Fractional _____
 1 HP or over _____

RESIDENTIAL HEATING:
 Oil or Gas (number of units) _____
 Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING:
 Oil or Gas (by a main boiler) _____
 Oil or Gas (by separate units) _____
 Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of)
 Ranges _____ Water Heaters _____
 Cook Tops _____ Disposals _____
 Wall Ovens _____ Dishwashers _____
 Dryers _____ Compactors _____
 Fans _____ Others (denote) _____
 TOTAL _____

MISCELLANEOUS: (number of)
 Branch Panels _____
 Transformers _____
 Air Conditioners Central Unit _____
 Separate Units (windows) _____
 Signs 20 sq. ft. and under _____
 Over 20 sq. ft. _____
 Swimming Pools Above Ground _____
 In Ground _____
 Fire/Burglar Alarms Residential _____
 Commercial _____
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____
 over 30 amps _____
 Circus, Fairs, etc. _____
 Alterations to wires _____
 Repairs after fire _____
 Emergency Lights, battery _____
 Emergency Generators _____

INSTALLATION FEE DUE: _____
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
 FOR REMOVAL OF A "STOP ORDER" (304-16.b)
 TOTAL AMOUNT DUE: 16.40

INSPECTION:
 Will be ready on 12/22 - 2 PM; or Will Call _____
 CONTRACTOR'S NAME: Burleigh Elect
 ADDRESS: 27 Town Line Rd - Falmouth Fenside
 TEL.: 781-2495
 MASTER LICENSE NO.: James Boehm #04645 SIGNATURE OF CONTRACTOR: _____
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

REVIEWED
FOR
HANDICAPPED
COMPLIANCE

210A-A-5

STATE OF MAINE
DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
AUGUSTA
CONSTRUCTION PERMIT



Permit No. 6094

PERMISSION IS HEREBY GIVEN TO:

Portland Jetport Hotel Assoc.

1050 Westbrook St.

Portland, ME 04102

Location of project

1050 Westbrook St.

Portland, ME

PROJECT TITLE:

Embassy Suite Pool Addition

OCCUPANCY CLASSIFICATION:

Hotel/Motel

To construct or alter the aforesaid building according to the plans hitherto filed with the Commissioner and now approved. No departure from such plans shall be made without prior approval in writing.

This permit will expire at midnight on February 22, 19 94.

This permit is issued under the provisions of Title 25, Chapter 317, Section 2448

Nothing herein shall excuse the holder of this permit for the failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Dated the 23rd day of August A.D. 19 93

FEE \$ 150.00/50.00

John R. Clunney

Commissioner - Public Safety

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

October 3, 1994

RE: 1050 Westbrook ST.

M. R. Brewer
Fine Woodworking Inc.
P. O. Box 3035
Portland, ME 04104


Dear Sir:

Your application to construct enclosure for existing loading dock (walls & roof), has been reviewed and a permit is herewith issued subject to the following requirements: This permit does not preclude the applicant from meeting applicable State and Federal laws.

1. The automatic fire suppression system shall be provided throughout this proposed addition.
2. The doors leading from the loading dock to the hotel must have a fire rating of a one hour minimum.
3. The fire protective signaling system shall be extended into this new proposed area.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


S. Samuel Hoffses
Chief of Inspection Services

/el

cc: LT. Gaylen McDougal, Fire Prevention Bureau

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1050 Westbrook St.		Owner: Embassy Suites	Phone:	Permit No: 941070
Owner Address: 1050 Westbrook St. Ptd, ME		Leasee/Buyer's Name: ME 04102	Phone:	Business Name:
Contractor Name: M.R. Brewer Fine Woodworking		Address: P O BOX 3035-Ptd, ME 04104		Phone: 797-7534
Past Use: Hotel	Proposed Use: Hotel w enclosed loading dock	COST OF WORK: \$ 8000	PERMIT FEE: \$ 60	Permit Issued: OCT 4 1994
Proposed Project Description: construct enclosure for existing loading dock (walls, roof)		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: A1 Type: 1B DOCA 93	CITY OF PORTLAND
		Signature: <i>H. Chase</i>	Signature: <i>H. Chase</i>	Zone: CBL:
		Signature: _____	Date: _____	Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>

- This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH LETTER

L Chase
9/29/94

CERTIFICATION

I hereby certify that I am the owner of record of the name, property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

William P. Brewer
SIGNATURE OF APPLICANT

ADDRESS:

9-29-94
DATE:

797-7534
PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

PHONE:

White-Permit Desk Greer-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: 9/30/94

[Signature]

CEO DISTRICT

[Signature]
4 mm Carver

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1050 Westbrook St		Owner: PJH Associates		Phone:	Permit No: 960513
Owner Address:		Lease/Buyer's Name: Embassy Suites 1050 Westbrook St		Phone:	Business Name: ME 04102
Contractor Name: Maine Bay Canvas		Address:		Phone: 775-2200	
Past Use: Hotel		Proposed Use: Same		COST OF WORK: \$	PERMIT FEE: \$ 50.00
Proposed Project Description: Erect Tent July 1 - July 2, 1996		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
		Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied: <input type="checkbox"/>		Zoning Approval: <input checked="" type="checkbox"/> Special Zone or Review <i>[Signature]</i> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> major <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Mary Gresik		Date Applied For: 24 June 1996			

PERMIT ISSUED
JUN 28 1996
CITY OF PORTLAND

- This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

Zone: **AB** CBL: 210-A-A-005
Zoning Appeal:
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT: *[Signature]* Don Hopkins ADDRESS: DATE: 24 June 1996 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: PHONE:
White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Action:
 Approved
 Approved with Conditions
 Denied
Date: 6/24/96
[Signature]
CEO DISTRICT **4**
[Signature]

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8105, FAX: 874-8110

Location of Construction: 1050 Westbrook St.		Owner: Embassy Suites		Phone:		Permit No: 941070	
Owner Address: 1050 Westbrook St. Ptd, ME		Leasee/Buyer's Name: E 04102		Phone:		Business Name:	
Contractor Name: M.R. Brewer Fine Woodworking		Address: P O BOX 3035-Ptd, ME 04104		Phone: 797-7534		<div style="border: 1px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED OCT 4 1994 CITY OF PORTLAND </div>	
Past Use: Hotel		Proposed Use: Hotel w enclosed loading dock		COST OF WORK: \$ 8000 FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		PERMIT FEE: \$ 60 INSPECTION: Use Group: Type:	
Proposed Project Description: construct enclosure for existing loading dock (walls, roof)				Signature: _____		Signature: _____	
				PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied <input type="checkbox"/>		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
				Signature: _____		Date: _____	

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

L Chase
9/29/94

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

William R. Brewer
SIGNATURE OF APPLICANT

ADDRESS:

9-29-94
DATE:

797-7534
PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT



021011

Good w/out
suspension

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

October 3, 1994

RE: 1050 Westbrook ST.

M. R. Brewer
Fine Woodworking Inc.
P. O. Box 3035
Portland, ME 04104


Dear Sir:

Your application to construct enclosure for existing loading dock (walls & roof), has been reviewed and a permit is herewith issued subject to the following requirements: This permit does not preclude the applicant from meeting applicable State and Federal laws.

1. The automatic fire suppression system shall be provided throughout this proposed addition.
2. The doors leading from the loading dock to the hotel must have a fire rating of a one hour minimum.
3. The fire protective signaling system shall be extended into this new proposed area.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


S. P. Hoffses
Chief of Inspection Services

/el
cc: LT. Gaylen McDougal, Fire Prevention Bureau