

172 CAPISIC STREET



SMEAD

Full cut #9201 • Half cut #9202 • Third cut #9203 • Full cut #9204



APPLICATION FOR PERMIT

DEPARTMENT OF BUILDING INSPECTIONS SERVICES

ELECTRICAL INSTALLATIONS

Date XX# 9-23-80, 19
 Receipt and Permit number A51729

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 172 Capisic St.
 OWNER'S NAME: Northport Builders ADDRESS: _____

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL <u>1-30</u> ✓	3.00
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	no rew-apt.
SERVICES:	
Overhead <u>✓</u> Underground _____ Temporary _____ TOTAL amperes <u>100</u>	3.00
METERS. (number of) <u>1</u>	.50
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	6.50
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT _____	INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	DOUBLE FEE DUE:
	6.50
	TOTAL AMOUNT DUE:
	6.50

INSPECTION:

Will be ready on _____ now _____, 19 _____; or Will Call _____

CONTRACTOR'S NAME: Young's Elec.

ADDRESS: 1400 Washington Ave.

TEL.: 797-0593

MASTER LICENSE NO.: 03288

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

00801

B.O.C.A. TYPE OF CONSTRUCTION

SEP 29 1980

ZONING LOCATION PORTLAND, MAINE, Sept. 26, 1980

CITY OF PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 172 Capisic St.
1. Owner's name and address Phillip Griffin same Fire District #1 [] #2 []
2. Lessee's name and address Builders Telephone
3. Contractor's name and address Northport Restorers 1400 Washington Telephone 797-7257
4. Architect Specifications Plans No. of sheets
Proposed use of building dwelling No. families 1
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 5000 Fee \$ 23.50

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451 To construct dormer on the side of existing dwelling as per plan (dormer 30'x12')
Dwelling Ex. 234
Garage
Masonry Bldg.
Metal Bldg.
Alterations Stamp of Special Conditions
Demolitions
Change of Use
Other

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 [] 2 [] 3 [x] 4 []

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated ... number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING:

BUILDING CODE:

Fire Dept.:

Health Dept.:

Others:

MISCELLANEOUS

Will work require disturbing of any tree on a public street?

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? ... Y N

Signature of Applicant Earl Waycotte Phone #

Type Name of above Earl Waycotte 1 [] 2 [] 3 [] 4 []

FIELD INSPECTOR'S COPY

Other and Address

NOTES

9-30-80 HAD CONTRACTOR COME IN FOR PERMIT -

WORK ALREADY STARTED -

10-20-80 Framing in place -

will put in smoke detector -

Not a new apt only added on for kids -

2-23-81 Couldn't get in - from outside

looks as tho not completed - will

try to get in later -

5-16-81 Owner furnishing rest of work

noticed them of smoke

detector (owner in suit

told by contractor or this

officer) -


Permit No. 80/501 #3

Location 1731 9th Street

Owner [Signature]

Date of permit 9-26-80

Approved 9-29-80 [Signature]



CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. 55719
 Issued ..
 Portland, Maine 4-17-67, 19...

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Robert G. Thoren 172 Caspawic Tel.

Contractor's Name and Address Portland Electric Co. & Ins. Tel.

Location 172 Caspawic Use of Building Res.

Number of Families 1 Apartments 1 Stores .. Number of Stories

Description of Wiring: New Work .. Additions .. Alterations

Pipe .. Cable .. Metal Molding .. BX Cable .. Plug Molding (No. of feet) ..

No. Light Outlets .. Plugs .. Light Circuits .. Plug Circuits

FLUORESCENT LAMPS: No. .. Light Switches .. Fluor. or Strip Lighting (No. feet) ..

SERVICE: Pipe .. Cable .. Underground .. No. of Wires .. Size ..

METERS: Relocated .. Added .. Total No. Meters ..

MOTORS: Number .. Phase .. H. P. .. Amps .. Volts .. Starter ..

HEATING UNITS: Domestic (Oil) No. Motors .. Phase 1 H.P. 1/2 - 1/4

Commercial (Oil) .. No. Motors .. Phase .. H.P.

Electric Heat (No. of Rooms) ..

APPLIANCES: No. Ranges .. Watts .. Brand Feeds (Size and No.) ..

Elec. Heaters .. Watts ..

Miscellaneous .. Watts .. Extra Cabinets or Panels ..

Transformers .. Air Conditioners (No. Units) .. Signs (No. Units) ..

Will commence .. 19 .. Ready to cover in .. 19 .. Inspection .. 19 ..

Amount of Fee \$ 2.00 .. Signed A. J. Smith ..

DO NOT WRITE BELOW THIS LINE

SERVICE .. METER .. GROUND ..

VISITS: 1 .. 2 .. 3 .. 4 .. 5 .. 6 ..

7 .. 8 .. 9 .. 10 .. 11 .. 12 ..

REMARKS:

INSPECTED BY J. W. Harbo
(OVER)



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, April 17, 1967

PERMIT ISSUED 00235 APR 18 1967 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 172 Capisic St. Use of Building Dwelling No. Stories 1 New Building Existing Name and address of owner of appliance Robert H. Thorn, 172 Capisic St. Installer's name and address Portland Sebago Oil & Ice Co, 302 Commercial Telephone Oil Burner's Lic. 1891

General Description of Work

To install Oil-fired forced hot water heating system in place of oil-fired gravity warm air heat.

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none If so, how protected? Kind of fuel? oil Minimum distance to burnable material, from top of appliance or casing top of furnace 3' From top of smoke pipe 21' From front of appliance over 4' From sides or back of appliance over 3' Size of chimney flue 8x10 Other connections to same flue none If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? YES

IF OIL BURNER

Name and type of burner A B C-Euntype Labelled by underwriters' laboratories? YES Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/2" Location of oil storage basement Number and capacity of tanks 275 gal. existing Low water shut off Make No. Will all tanks be more than five feet from any flame? YES How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED: OK 4-17-67 [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

Portland Sebago Oil & Ice Company

[Signature]

Signature of Installer by:

CS 300

INSPECTION COPY

7M

PERMIT TO INSTALL PLUMBING

Address 172 Capric Street

PERMIT NUMBER **17167**

Installation For: Dwelling

Owner of Bldg: Robert H. Thoren

Owner's Address: 172 Capric Street

Plumber: Portland Sabago Oil & Ice Co.

Date: 4/17/67

Date Issued 4/27/67

Portland Plumbing Inspector

By ERNOLD R. GOODWIN

App. First Insp.

Date 4/18/67

By J. Montgomery

App. Final Insp.

Date APR 25 1967

By ERNOLD R. GOODWIN

CHIEF PLUMBING INSPECTOR

Type of Bldg.

- Commercial
 Residential
 Single
 Multi Family
 New Construction
 Remodeling

NEW	REPL.		NO.	FFE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		
	1	TANKLESS WATER HEATERS	1	2.00
		GARBAGE DISPOSALS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS		
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER		
			TOTAL	1 2.00

Building and Inspection Services Dept: Plumbing Inspection

13-919-2.00



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 3/12/51

PERMIT ISSUED
MAR 13 1951
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 172 Capaic St. Use of Building Dwelling No. Stories 2 New Building Excluded? No

Name and address of owner of appliance George H. Howe, 172 Capaic St., Portland, Maine Telephone 2-1991

Installer's name and address Ballard Oil & Equipment Co

General Description of Work

To install one fully automatic oil burner under one pipe gravity furnace

IF HEATER, OR POWER BOILER

Location of appliance or source of heat

If wood, how protected?

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace

From top of smoke pipe

Size of chimney flue

If gas fired, how vented?

Type of floor beneath appliance

Kind of fuel

From front of appliance

From sides or back of appliance

Other connections to same flue

Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Ballard BG-4 Labelled by underwriters' laboratory? Yes

Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? Bottom

Type of floor beneath burner Cement Number and capacity of tanks 1 - 27 1/2 gal

Location of oil storage Basement How many tanks fire protected? None

If two 27 1/2-gallon tanks, will three-way valve be provided?

Will all tanks be more than five feet from any flame? Yes

Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance

If wood, how protected?

Minimum distance to wood or combustible material from top of appliance

From front of appliance

From sides and back

Size of chimney flue

Other connections to same flue

Is hood to be provided?

If so, how vented?

If gas fired, how vented?

Type of floor beneath appliance

From top of worktop

Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

RECEIVED
MAR 13 1951
CITY OF PORTLAND

APPROVED: *[Signature]*
3/13/51

Will issue a certificate of the above work, with a permit, subject to the laws of the State and the requirements pertaining thereto, and consistent? Yes

Signature of installer: *[Signature]*
Ballard Oil & Equipment Co.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for poultry house

at 84 Capric Street

Date 3/16/56

1. In whose name in the title of the property now recorded? *See H. Home*
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? _____
3. Is the outline of the proposed work now staked out upon the ground? *No* If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? *Yes*
4. What is to be maximum projection or overhang of eaves or drip? *4"*
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porch, and other projections? *Yes*
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? *Yes*
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? *Yes*

See H. Home



GENERAL RESIDENCE ZONE

Permit No. ISSUED

APPLICATION FOR PERMIT

MAR 17 1938 0209

Class of Building or Type of Structure Third Class

Portland, Maine, March 16, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ alter ~~the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:~~

Location 84 Caplice Street Ward B Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address George H. Howe, et al 84 Caplice St. Telephone 4-2558

Contractor's name and address Ormar Telephone _____

Architect's name and address _____ No. families _____

Proposed use of building Faunery house

Other buildings on same lot dwelling house

Plans filed as part of this application? yes No. of sheets 1

Estimated cost \$ 50. Fee \$.50

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

To erect one story frame building 12' x 24'

NOTIFICATION BEFORE LA BOND OR CLOSING-IN IS NOT REQUIRED

CERTIFICATE OF OCCUPANCY REQUIRED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separate by the heating contractor.

Details of New Work

Size, front 12' depth 24' No. stories 1 Height average grade to top of plate _____

To be erected on solid or filled land? solid Height average grade to highest point of roof 8'

Material of foundation cedar posts earth or rock? earth Thickness, top _____ bottom _____

Material of underpinning _____ Upright _____ Thickness _____

Kind of Roof long and short Rise per foot 8" Roof covering Asphalt roofing Class C and Lab.

No. of chimneys no Material of chimneys _____ No. living _____

Kind of heat no Type of fuel _____ Is gas fitting involved? _____

Corner posts 2x4 Sills 4x8 Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. (Girders 6x8 or larger. Bracing in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section)

Joists and rafters: 1st floor 2x8 2nd _____ 3rd _____ roof 2x4

On centers: 1st floor 18" 2nd _____ 3rd _____ roof 16"

Maximum span: 1st floor 12' 2nd _____ 3rd _____ roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs _____ cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner George H. Howe

INSPECTION COPY

1277B

M
 Ward 4 Permit No. 56/209
 Locality 14 Cupric St.
 Owner George H. Howe
 Date of permit 3/17/36
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. 2/25/37
 Cert. of Occupancy issued Howe

NOTES:

~~3/17/36 - existing
 fronting house built
 without a permit
 a year or more
 ago to be demolished
 4/3/36 - Blkpointing
 house for do on.
 No work done
 New one at do
 4/10/36 - No change
 2/25/37 - Building
 erected~~

Exhibit A of B

U. W. 201

[Faint, illegible text from the reverse side of the document, possibly bleed-through or a separate page.]



OFFICE HOURS
10 TO 12 M.
4 TO 6 P. M.

City of Portland.

OFFICE OF INSPECTOR OF BUILDINGS

1-2-3 191

To the Inspector of Buildings of the City of Portland:

172

The undersigned respectfully makes application for a permit to erect enlarge a building on.....
Capacis St. street, at number..... to be.....
One stories high. Thirty-two long. Twenty-two
feet wide; also an addition to be..... stories high.....
feet long..... feet wide, and to be used as a Dwelling.....

CELLAR WALL—To be constructed of Concrete to be 12 inches wide on bottom and
batter to 12 inches on top.

UNDERPINNING—To be Blocks Height of underpinning from top of cellar wall to bottom of
sill..... inches in thickness.

EXTERIOR WALLS—To be constructed of Wood If of Brick, Stone, etc. Total length of wall
..... ft. inches. Thickness of 1st..... 2d..... 3d..... 4th.....
5th..... 6th..... story walls. If of reinforced concrete state mix and reinforcing system
to be used. 4-8 4-8

If wood construction, sills to be..... Girders
Posts 4-5..... Girts..... 2-4..... Stubs..... 2-4 to be spaced 16 in. on C.
This building will be used for the purposes of..... Dwelling..... (If for apartments,
tenements, or other family uses state number of families accommodated and number on each floor.
If for manufacturing or mercantile purposes state character of business and amount of estimated
weight to be carried by the floor.)
Number of families on floor..... One
Total number of families..... one
Manufacturing (state character).....
Estimated load on floors per sq. ft.
Mercantile business (state character and load per sq. ft.).....

If building is used for tenement house or family use and more than one family, the following provis-
ions of the Building Laws regarding dividing partitions shall be adhered to (Quote Law re. this).

FIRESTOPS—All bearing and center partitions will have firestops cut in tight on top of each partition cap
and between each set of floor timbers. Where ledger boards are used there shall be firestops cut in
tight against bottom of ledger boards, of same size as wall studs. Also wherever the Inspector of
Buildings may consider necessary.

STAIRWAYS—No. in building..... location..... to be enclosed
with..... walls to be lathed with..... lathing.

ROOF—To be constructed of Wood Rafters to be 2-6 inches to be spaced 24
..... inches on centers. Roof to be covered with Shingles

Gutters to be made of..... Cornices to be made of.....
Bay windows to be made of..... to be covered with.....

Dormer Windows to be made of..... to be covered.....
Chimneys, Smoke flues to be lined with Flue Lining and provided with a 10 inch outside collar and an
inside collar to go to the inside of the flue.

Estimated Cost of Building \$1200

INSPECTION—The Inspector of Buildings is to be notified when building is ready for lathing and at least
24 hours before the lathing is begun.

The Builder is J. E. Edwards Address 217 Spring St.

The Architect is..... Address.....
The Owner is..... Do. Address.....

No Deviation will be made from the above application without written permission from the Inspector of
Buildings.

The above petition was granted the 2 day of Jan. 191
All floor timbers to be 2-7 in. and to be spaced 16 in. on centers.

(Applicant to sign here J. H. Edwards)

923471

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 25.00 Zone _____ Map # _____ Lot# _____
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Jane Chase Phone # 797-8469 Burt Moore

Address: 172 Capisic St. Ptld

LOCATION OF CONSTRUCTION 172 Capisic St.

Contractor: Northern Propane Sub: _____

Address: 1075 Forest Ave 04101 Phone # 1-800-225-2052

Est. Construction Cost: _____ Proposed Use: 1-fam w/Propane tanks

Past Use: 1-fam

of Existing Res. Units _____ # of New Res. Units _____

Building Dimensions L _____ W _____ Total Sq. Ft. _____

Stories: _____ # Bedrooms _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion Install 2-50 Gallon Propane Tanks/Above Ground

For Official Use Only	
Date: <u>March 5, 1992</u>	Subdivision: <u>MAR 12 1992</u>
Inside Fire Limits: _____	Name: _____
Blkg Code: _____	Lot: _____
Time Limit: _____	Ownership: _____ Public _____ Private _____
Estimated Cost: _____	

Zoning: _____
Street Frontage Provided: _____
Provided Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required: _____
Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other (Explain) WDA 3-10-92

Ceiling: _____ **HISTORIC PRESERVATION**

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____ Not in District nor Landmark.
3. Type Ceilings: _____ Does not require review.
4. Insulation Type _____ Size _____ Requires Review.
5. Ceiling Height: _____

Roof: _____

1. Truss or Rafter Size _____ Span _____ Action _____ Approved.
2. Sheathing Type _____ Size _____ Approved with Conditions.
3. Roof Covering Type _____

Chimneys: _____
Type: _____ Number of Fire Places _____ Date 3/5/92
Status: Denial

Heating: _____
Type of Heat: _____

Electrical: _____
Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing: _____
1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools: _____
1. Type: _____
2. Pool Size _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Mary Grealk

Signature of Applicant Kevin Fitzgerald Date March 5, 1992

CEO's District 4

PERMIT ISSUED WITH REQUIREMENTS

CONTINUED TO REVERSE SIDE

Ivory Tag - CEO

14 Mr. Carroll

Foundation: _____

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other _____

Floor: _____

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____

4. Joists Size: _____ Spacing 16" O.C.

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls: _____

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls: _____

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall if required _____

5. Other Materials _____

City - Tax Assessor

923471

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee 25.00 Zone _____ Map # _____ **PERMIT ISSUED**

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Jana Chaez Phone # 191-5497

Address: 172 Capisic St. Pld

LOCATION OF CONSTRUCTION 172 Capisic St.

Contractor: Northern Propane Sub: _____

Address: 1075 Forest Ave 04101 Phone # 1-800-225-2062

Est. Construction Cost: _____ Proposed Use: 1-fam w/Propane tanks

Past Use: 1-fam

of Existing Res. Units _____ # of New Res. Units _____

Building Dimensions L _____ W _____ Total Sq. Ft. _____

Stories: _____ # Bedrooms: _____ Lot Size: _____

Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____

Explain Conversion Install 2-50 Gallon Propane Tanks/Above Ground

For Official Use Only

Date March 5, 1992 Subdivision _____

Inside Fire Limits _____

Bldg Code _____

Time Limit _____

Estimated Cost _____

Name _____

Ownership _____ Public _____ Private _____

MAR 12 1992

CITY OF PORTLAND

Zoning: _____

Street Frontage Provided: _____

Provided Setbacks: Front _____ Back _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____

Special Exception _____

Other (Explain) 172-3-10-92

Foundations:

1. Type of Soil: _____

2. Set Backs - Front _____ Rear _____ Side(s) _____

3. Footings Size: _____

4. Foundation Size: _____

5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.

2. Girder Size: _____

3. Lally Column Spacing: _____ Size: _____

4. Joists Size: _____ Spacing 16" O.C.

5. Bridging Type: _____ Size: _____

6. Floor Sheathing Type: _____ Size: _____

7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____

2. No. windows _____

3. No. Doors _____

4. Header Sizes _____ Span(s) _____

5. Bracing: Yes _____ No _____

6. Corner Posts Size _____

7. Insulation Type _____ Size _____

8. Sheathing Type _____ Size _____

9. Siding Type _____ Weather Exposure _____

10. Masonry Materials _____

11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____

2. Header Sizes _____ Span(s) _____

3. Wall Covering Type _____

4. Fire Wall If required _____

5. Other Materials _____

Ceiling:

1. Ceiling Joists Size: _____

2. Ceiling Strapping Size _____ Spacing _____

3. Type Ceilings: _____

4. Insulation Type _____ Size _____

5. Ceiling Height: _____

HISTORIC PRESERVATION

Not in District or Landmark _____

Does not require review.

Require Review. _____

Roof:

1. Truss or Rafter Size _____ Span _____ Action: Approved.

2. Sheathing Type _____ Size _____

3. Roof Covering Type _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrances Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____

2. No. of Tubs or Showers _____

3. No. of Flushes _____

4. No. of Lavatories _____

5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____

2. Pool Size: _____

3. Must conform to National Electrical Code and State _____

Permit Received By Mary Grepik

Name of Applicant K. Grepik Date March 5, 1992

CEO's District 4

PERMIT ISSUED WITH REQUIREMENTS

CONTINUED TO REVERSE SIDE

Ivory Tag - CEO

White - Tax Assessor

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ _____
 Subdivision Fee \$ _____
 Site Plan Review Fee \$ _____
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Inspection Record

Type	Date
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____
_____	____/____/____

COMMENTS

*Work never done
 Permit Expired 2/15/95*

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as has authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

[Signature] *1075 FOREST AVE* *800-225-2082*
 SIGNATURE OF APPLICANT ADDRESS PHONE NO.
NORTHERN PROGRAM
 RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE NO.

BUILDING PERMIT REPORT

DATE: 3-10-92
ADDRESS: 172 Capital St
REASON FOR PERMIT: 2-50 gal ABOVE GROUND L/P TANKS
BUILDING OWNER: Jane Chase
CONTRACTOR: Northrup Properties
PERMIT APPLICANT: Kevin Fitzgerald
APPROVED: LS DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All above ground L/P storage tanks shall be located in accordance with NFPA #58 standards. *And The Fire Prevention Code*
- 2.) Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.
- 3.) All piping shall be protected from possible mechanical damage and vandalism.

2-100^{lbs} PROPAGETANICS

00

#172

CAPISIC ST