

246 CAPISIC STREET

STANDARD



**APPLICATION FOR PERMIT**  
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES  
 ELECTRICAL INSTALLATIONS

Date Feb. 15, 19 80  
 Receipt and Permit number 45547

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 246 Capisis Street  
 OWNER'S NAME: Moschetto Constr. ADDRESS: 93 Winding Way

OUTLETS: Receptacles \_\_\_\_\_ Switches \_\_\_\_\_ Plugmold \_\_\_\_\_ ft. TOTAL 31-60 FEES  
 \_\_\_\_\_ 5.00  
 FIXTURES: (number of) \_\_\_\_\_  
 Incandescent \_\_\_\_\_ Flourescent xxxx (not strip) TOTAL 15 \_\_\_\_\_ 3.50  
 Strip Flourescent \_\_\_\_\_ ft. \_\_\_\_\_

SERVICES: Overhead \_\_\_\_\_ Underground \_\_\_\_\_ Temporary \_\_\_\_\_ TOTAL amperes \_\_\_\_\_

METERS: (number of) \_\_\_\_\_  
 MOTORS: (number of) \_\_\_\_\_

Fractional \_\_\_\_\_  
 1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING: Oil or Gas (number of units) \_\_\_\_\_  
 Electric (number of rooms) \_\_\_\_\_

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) \_\_\_\_\_  
 Oil or Gas (by separate units) \_\_\_\_\_  
 Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

APPLIANCES: (number of)  
 Ranges \_\_\_\_\_ Water Heaters \_\_\_\_\_  
 Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_  
 Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_  
 Dryers \_\_\_\_\_ Compactors \_\_\_\_\_  
 Fans \_\_\_\_\_ Others (denote) \_\_\_\_\_  
 TOTAL \_\_\_\_\_

MISCELLANEOUS. (number of)  
 Branch Panels \_\_\_\_\_  
 Transformers \_\_\_\_\_  
 Air Conditioners Central Unit \_\_\_\_\_  
 Separate Units (windows) \_\_\_\_\_  
 Signs 20 sq. ft. and under \_\_\_\_\_  
 Over 20 sq. ft. \_\_\_\_\_  
 Swimming Pools Above Ground \_\_\_\_\_  
 In Ground \_\_\_\_\_  
 Fire/Burglar Alarms Residential \_\_\_\_\_  
 Commercial \_\_\_\_\_  
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_  
 over 30 amps \_\_\_\_\_  
 Circus, Fairs, etc. \_\_\_\_\_  
 Alterations to wires \_\_\_\_\_  
 Repairs after fire \_\_\_\_\_  
 Emergency Lights, battery \_\_\_\_\_  
 Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE: \_\_\_\_\_  
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE: \_\_\_\_\_  
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....  
 TOTAL AMOUNT DUE: 8.50

INSPECTION: Will be ready on \_\_\_\_\_, 19\_\_\_\_; or Will Call XX  
 CONTRACTOR'S NAME: Michael Gowan  
 ADDRESS: RFD # 1 Saco Rd. West Buxton  
 TEL.: 642-3962  
 MASTER LICENSE NO.: 3069 SIGNATURE OF CONTRACTOR: Michael V. Gowan  
 LIMITED LICENSE NO.: \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 45547

Location 246 Republic St.

Owner Masonite Const.

Date of Permit 2-14-80

Final Inspection 6-2-80

By Inspector F. Libby

Permit Application Register Page No. 148

INSPECTIONS: Service \_\_\_\_\_ by \_\_\_\_\_

Service called in \_\_\_\_\_

Closing-in 2-25-80 by Libby

PROGRESS INSPECTIONS:

2-15-80 \_\_\_\_\_

2-20-80 \_\_\_\_\_

3-26-80 \_\_\_\_\_

6-2-80 \_\_\_\_\_

**CODE**

**COMPLIANCE**

**COMPLETED**

DATE: 2-80

DATE:	REMARKS:

3068

1-21-80

11-21-80

**CERTIFICATE OF APPROVAL  
FOR INTERNAL PLUMBING**

TOWN/CITY CODE: 06170 LPI NUMBER: 123 DATE ISSUED: 2/20/80 THE TOWN/CITY OF: Dartmouth  
 No. **36865 IC**  
 Certificate of App. Number  
 Installer's Name (Last Name): STUART F.I.M.I. Installer Code: 2  
 Owner: Margaret A. T.  
 Address: 246 Cambridge St. St./Lot Number: 246 Street/Road Name: Cambridge St. Subdivision: North  
 (Location where plumbing was done and inspected)

- 1. Owner
- 2. Licensed Master Plumber
- 3. Licensed OH Burnerman
- 4. Employees of Public Utilities
- 5. Manufactured Housing Dealer
- 6. Manufactured Housing Mechanic

THE INTERNAL PLUMBING INSTALLED PURSUANT TO THE ABOVE CERTIFICATE OF APPROVAL NUMBER HAS BEEN TESTED IN MY PRESENCE, FOUND TO BE FREE FROM LEAKS, AND WAS INSTALLED IN COMPLIANCE WITH THE MUNICIPAL AND STATE PLUMBING REGULATIONS.

Signature of LPI: [Signature]  
 Date Inspected: 2/21/80

**OWNER'S COPY**

ORIGINAL - To be sent to: Department of Human Services, Division of Health Engineering, Augusta, Maine 04333

**INTERNAL PLUMBING PERMIT FOR THE TOWN/CITY OF** Dartmouth

Town/City Code: 06170 LPI Number: 123 Date Issued: 2/20/80 INSTALLER'S License No.: 1854  
 No. **36865 IP**  
 PERMIT NUMBER  
 Address of Where Plumbing Is Done: 246 Cambridge St. St./Lot Number: 246 Street/Road Name: Cambridge St. Subdivision: North  
 Name of Owner (Last Name): MUSCHETTI F.I.M.I. Mailing Address: [Address] Zip Code: [Zip]

- 1. Owner
- 2. Licensed Master Plumber
- 3. Licensed OH Burnerman
- 4. Employees of Public Utilities
- 5. Manufactured Housing Dealer
- 6. Manufactured Housing Mechanic

Type of Construction	1. New	2. Remodeling	3. Addition	4. Remodeling & Addition	5. Replacement of Hot Water Heater	6. Hook-up of Mobile Home	7. Hook up of Modular Home	8. Other (Specify)
Plumbing To Serve	1. Single (Res)	2. Multi-Fam (Res)	3. Mobile Home	4. Modular Home	5. Commercial	6. School	7. Other (Specify)	
Number of Fixtures or Hook Ups	Sink(s) <u>1</u>	Toilet(s) <u>2</u>	Bath(s) <u>1</u>	Lavator(s) <u>2</u>	Shower(s) <u>2</u>	Chinal(s) <u>0</u>	Hot Water Heater(s) <u>1</u>	Floor Drain(s) <u>0</u>
	Clothes Washer(s) <u>0</u>	Dish-Washer(s) <u>1</u>	Hot Water Heater(s) <u>1</u>	Floor Drain(s) <u>0</u>	Hook-Up(s) <u>1</u>			

This "Internal Plumbing Permit" is invalid if work is not commenced within 6(6) months from date of issuance. Upon completion of work a "Certificate of Approval" must be obtained from the LPI.

**SCHEDULE OF "FEES"**

1 10	Fixtures	\$2.00 each
11 20	Fixtures	\$1.00 each
21	Fixtures on up	\$.50 each
	Hook Ups	\$2.00 each

NOTE: Hotwater Heater (Tank or Tankless) is a Fixture

Fixture Fee	<u>27</u> . <u>00</u>
Hook-Up Fee	<u>00</u> . <u>00</u>
Administrative Fee	<u>3</u> . <u>00</u>
Total Fee	<u>30</u> . <u>00</u>

If Double Fee Check Box:

**TOWN'S COPY**

Signature of LPI: [Signature]



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date Jan. 7, 19 80  
 Receipt and Permit number A 39836

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine.

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 246 Capisic Street  
 OWNER'S NAME: Moschetto Constr. ADDRESS: 93 Winding Way

	FEES
<b>OUTLETS:</b>	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
<b>FIXTURES:</b> (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	
<b>SERVICES:</b>	
Overhead _____ Underground _____ <input checked="" type="checkbox"/> Temporary _____ TOTAL amperes <u>200</u>	3.00
METERS: (number of) <u>1</u>	.50
<b>MOTORS:</b> (number of)	
Fractional _____	
1 HP or over _____	
<b>RESIDENTIAL HEATING:</b>	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
<b>COMMERCIAL OR INDUSTRIAL HEATING:</b>	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
<b>APPLIANCES:</b> (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
<b>MISCELLANEOUS:</b> (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) ..... _____	
TOTAL AMOUNT DUE: <del>xx 3.50</del>	3.50

**INSPECTION:**  
 Will be ready on \_\_\_\_\_ or Will Call  **xx**  
**CONTRACTOR'S NAME:** Michael Goan  
**ADDRESS:** RFD # 1 Saco Rd. West Buxton  
**TEL.:** 642-3962  
**MASTER LICENSE NO.:** 03069 **SIGNATURE OF CONTRACTOR:**  
**LIMITED LICENSE NO.:** \_\_\_\_\_ Michael Goan

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 39836

Location 246 Republic St

Owner Marcello Costa

Date of Permit 1-7-80

Final Inspection \_\_\_\_\_

By Inspector \_\_\_\_\_

Permit Application Register Page No. 45

INSPECTIONS. Service 1 amp by Hilly  
Service called in 1-8-80  
Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

CODE COMPLIANCE COMPLETED  
DATE 1-8-80

DATE:	REMARKS:
<u>1-8-80</u>	<u>Change fuses to 20 amp</u>

FORM 2



## CITY OF PORTLAND

JOSEPH E. GRAY, JR.  
DIRECTOR OF PLANNING  
AND URBAN DEVELOPMENT

June 25, 1982

Mr. Michael Nelson  
230 Capisic Street  
Portland, Maine 04102

Re: 230 Capisic Street


Dear Mr. Nelson:

Your application and plans for a building permit to construct a 22'x24', 2-car detached garage at 230 Capisic Street is being issued with the following requirements:

1. The 2"x8" rafters at 16" on centers, can not be used on a 22' span. 2"x10" at 16" on centers may be used with the same structural design as per plan received by this office on June 25, 1982.

If you have any questions on this requirement, please call.

Sincerely,

  
P. S. Hoffses  
Chief of Inspection Services

PSH/jmr



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP ..... 7  
B.O.C.A. TYPE OF CONSTRUCTION ..... HB 00475  
ZONING LOCATION ..... R-3 ..... PORTLAND, MAINE ..... May 27, 1982

JUN 28 1982

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE  
The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION ..... 230 Capisic Street ..... Fire District #1 , #2   
1. Owner's name and address ..... Michael Nelson, same ..... Telephone 772-4919  
2. Lessee's name and address ..... Telephone 775-7271  
3. Contractor's name and address ..... Telephone .....  
Proposed use of building ..... 2 car detached garage ..... No. of sheets .....  
Last use ..... No. families .....  
Material ..... No. stories ..... Heat ..... Style of roof ..... No families .....  
Other buildings on same lot ..... Roofing .....  
Estimated contractual cost \$ ..... 6,000 .....  
FIELD INSPECTOR—Mr. .... @ 775-5451

Appeal Fees \$ 25.00  
Base Fee \$ 40.00  
Late Fee .....  
TOTAL \$ 40.00

To construct 22' x 24' 2 car detached garage as per plans. 2 sheets of plans.

send permit to # 1 04102

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT ISSUED WITH LETTER

DETAILS OF NEW WORK

Is any plumbing involved in this work? ..... Is any electrical work involved in this work? .....  
Is connection to be made to public sewer? ..... If not, what is proposed for sewage? .....  
Has septic tank notice been sent? ..... Form notice sent? .....  
Height average grade to top of plate ..... Height average grade to highest point of roof .....  
Size, front ..... depth ..... No. stories ..... solid or filled land? ..... earth or rock? .....  
Material of foundation ..... Thickness, top ..... bottom ..... cellar .....  
Kind of roof ..... Rise per foot ..... Roof covering .....  
No. of chimneys ..... Material of chimneys ..... of lining ..... Kind of heat ..... fuel .....  
Framing Lumber—Kind ..... Dressed or full size? ..... Corner posts ..... Sills .....  
Size Girder ..... Columns under girders ..... Size ..... Max. on centers .....  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet  
Joists and rafters: 1st floor ..... 2nd ..... 3rd ..... roof .....  
On centers: 1st floor ..... 2nd ..... 3rd ..... roof .....  
Maximum span: 1st floor ..... 2nd ..... 3rd ..... roof .....  
If one story building with masonry walls, thickness of walls? ..... height? .....

IF A GARAGE

No cars now accommodated on same lot ..... to be accommodated ..... number commercial cars to be accommodated .....  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? .....

APPROVALS BY:

BUILDING INSPECTION—PLAN EXAMINER DATE

ZONING: OK M.G.D. 6/23/82

BUILDING CODE: .....

Fire Dept.: .....

Health Dept.: .....

Others: .....

Will work require disturbing of any tree on a public street? .....

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? .....

Signature of Applicant ..... Phone # same .....

Type Name of above Michael Nelson

Other  2  3  4  
and Address .....

FIELD INSPECTOR'S COPY PERMIT ISSUED WITH LETTER APPLICANT'S COPY  
Ms Schmuckert

OFFICE FILE COPY



NOTES

7-8-82 Nit Started yet

7-12-82 Stone

7-29-82 Frost wall already 8"

poored (has fastig) - will be

backfill in both sides -

has actually joined foundations

but the above ground will

not be attached yet -> The owner

is aware of side pit line in future

whom they may attach in the future

(rear pt. garage corner would

be the closest) -

should have 4" below

grade when back filled -

8-17-82 FRAMING & SHOPPING

is completed -> has the

2x10's AS required -

Permit No. 82/495

Location 231

Owner Michael Melanson


Date of permit 5-27-82

Approved 6-28-82

Dwelling

Garage 2 Car Detached

Alteration



CITY OF PORTLAND, MAINE  
Department of Building Inspection



## Certificate of Occupancy

LOCATION 250 Capisic Street

Issued to **Moschetto Construction**

Date of Issue **April 6, 1981**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **79/1102**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

**Entire**

**Single Family Dwelling**

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

**4-6-81**  
(Date)

*[Signature]*  
Inspector

*[Signature]*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

December 12, 1979

Moschetto Construction Company, Inc.  
93 Winding Way Road  
Portland, Maine

Re: 246 Capisic Street

Dear Sir:

Your building permit application to construct a single family dwelling unit with an attached garage, at the above named address, is hereby approved subject to the followings:

- (1) Where the garage wall is attached to the breezeway, one hour fire protection is required. (1/2" sheetrock on both sides of the garage wall to provide the necessary fire protection.) (Sec. 413.1.1)
- (2) A 1-3/4" solid wood core door equipped with a self-closing device is required in the opening between the garage and breezeway. (Sec. 413.1.1)
- (3) The sills of all door openings between the garage and dwelling shall be raised not less than four (4) inches above the garage floor. (Sec. 413.1.1)

16' Garage opening requires 4x12 header  
9' " " " " 4x8 "

If I can be of further service, please do not hesitate to call this office, Building Inspection, 775-5451, Ext. 300.

Very truly yours,

Walter W. Hilton  
Chief of Building Inspections

WWH/x



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP . . . . .

Dec 12 1979

B.O.C.A. TYPE OF CONSTRUCTION 001102

ZONING LOCATION #3 PORTLAND, MAINE, Dec. 11, 1979

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 246 Capisic Street Fire District #1, #2
1. Owner's name and address Moschetto Constr. Co., Inc. - 27 Winding Way, Portland, ME 772-7225
2. Lessee's name and address
3. Contractor's name and address Comer Telephone
4. Architect Specifications Plans No. of sheets
Proposed use of building dwelling with attached garage No. families 1
Last use No. families
Material No. stories Feet Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 60,000 Fee \$ 271.00

been discussed

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451
Dwelling Ext. 234 To construct single willy, split for er 36 x 38 with 28 x 26 garage attached to dwelling
Garage Stamp of Special Conditions
Masonry Bldg.
Metal Bldg.
Alterations
Demolitions
Change of Use
Other

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 2 3 4

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Yes Is any electrical work involved in this work? Yes
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate 12 ft. Height average grade to highest point of roof 29 ft.
Size, front 36 depth 38 No. stories 2 solid or filled land? earth or rock? earth
Material of foundation cement Thickness, top 10 in bottom 10 in
Kind of roof pitch Rise per foot 6/12 Roof covering asphalt shingles
No. of chimneys 2 Material of chimneys brick Kind of heat electric fuel
Framing Lumber—Kind spruce, pine or full size? Corner posts 4 x 6 Sills 2 x 10
Size Girder constr. grade Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 4 x 10, 2nd 3rd roof 2 x 8
On centers: 1st floor 48 in, 2nd 3rd roof 16
Maximum span: 1st floor 2nd 3rd roof

IF A GARAGE

No. cars now accommodated on same lot . . . . . to be accommodated 2 number commercial cars to be accommodated . . . . .
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? . . . . .

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? No
ZONING: P.A. MacCallister Building Code Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant M.L. Moschetto Pres. Phone # same

Type Name of above Moschetto Construction Co. Inc. 2 3 4

FIELD INSPECTOR'S COPY

PERMIT ISSUED WITH LETTER

Other and Address

NOTES

12-18-79 Not started yet  
 12-31-79 started pouring  
 in - 15 Nov. H. Ready to pour  
 The close side of the wall is 15 ft  
 10" on the wall - 1/2" from  
 at back wall to get. At 1/2" below  
 side - 1/2"  
 2-4-80 Most of beam is up -  
 talked to contractor to provide  
 steps - his son to have a finished  
 curb and closer at  
 the different curb  
 raised - also side  
 no stopper on beam  
 partitions & will  
 call before close in  
 also discussed state  
 law on fire insurance  
 ? The need for "Sheet  
 Rock protection -  
 2-27-80 with guys at  
 to sheet rock patches on  
 wall sheet instead of two  
 dampers at floor levels  
 Extra guys ok to close in  
 OK kids to close in -  
 found what appears to be  
 a hair crack - told to  
 about in - will sheet rock  
 up patches protection in  
 basement for base of  
 fire stop -  
 4-14-80 NEARLY completion  
 still needs some sheet rock  
 in bath -  
 4-24-80 Pushed up four  
 glass paths just back  
 nearly completion - reworked  
 contractor to call before  
 occupancy -  
 7-15-80 BAILEY Smith &  
 plan in Annex called in  
 concern to the unfinished  
 decks on rear & side -  
 they have been temp posted  
 on rear No sale has been

placed yet since no  
 sonotubes poured yet  
 tried to call owner / contractor  
 but number has been  
 disconnected -  
 7-17-80 spoke to Mr.  
 Moschetto at his home  
 about the decks & the  
 necessity to get in finish  
 up the decks (e.g.  
 esp.) of AT LEAST temp.  
 re-anchors them both  
 11-17-80 HAS REINFORCED  
 little better on rear -  
 No sonotubes poured yet  
 1-17-80 noticed that people  
 moved in (I wasn't notified)  
 I told them about the  
 patches - The dangers  
 involved. Owner seemed  
 to understand - will call  
 when poured sonotubes  
 (probably in spring)  
 4-6-81 HAS PROJECTED  
 sonotubes & electric  
 supports - rear deck  
 still needs some extra  
 support (told owner  
 they will correct)  
 OK by WACT to  
 issue C.O.

Approved: \_\_\_\_\_  
 Date of permit: 12-11-79  
 Permit No: 99-1102  
 Location: 1102  
 Owner: Moschetto, locate in

246 Capisic St.

May 16, 1977

Mr. Harold Hansen  
246 Capisic Street  
Portland ME

Dear Mr. Hansen

This office is unable to issue a permit to construct a sunporch on the rear of the dwelling because no structural plans, showing how it is to be constructed, were submitted with the application for a permit.

This office will be in a position to issue a permit only when structural plans have been received and certified by the Department.

Very truly yours

Earle S. Smith  
Plan Examiner

ESS:cm



# APPLICATION FOR PERMIT

B.O.C.A. USE GROUP .....

B.O.C.A. TYPE OF CONSTRUCTION .....

ZONING LOCATION A-3 PORTLAND, MAINE, 033 May 11, 1977

**PERMIT ISSUED**

MAY 16 1977

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 246 Capisic St.

1. Owner's name and address Harold Hansen - same Fire District #1  #2

2. Lessee's name and address Telephone 774-0291

3. Contractor's name and address Owner Telephone .....

4. Architect Telephone .....

Proposed use of building dwelling Specifications Plans No. of sheets .....

Last use No. families 1

Material No. stories Heat Style of roof Roofing .....

Other buildings on same lot .....

Estimated contractual cost \$ 140.00 Fee \$ 5.00

FIELD INSPECTOR—Mr. .... GENERAL DESCRIPTION

This application is for: @ 775-5451

Dwelling Ext. 234

Garage

Masonry Bldg.

Metal Bldg.

Alterations

Demolitions

Change of Use

Other sun porch

Permit to construct sun porch on rear of dwelling

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1  2  3  4   
Other: .....

### DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work? .....

Is connection to be made to public sewer? If not, what is proposed for sewage? .....

Has septic tank notice been sent? Form notice sent? .....

Height average grade to top of plate Height average grade to highest point of roof .....

Size, front depth No. stories solid or filled land? earth or rock? .....

Material of foundation Thickness, top bottom cellar .....

Kind of roof Rise per foot Roof covering .....

No. of chimneys Material of chimneys of lining Kind of heat fuel .....

Framing Lumber—Kind Dressed or full size? Corner posts Sills .....

Size Girder Columns under girders Size Max. on centers .....

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor, 2nd, 3rd, roof

Co centers: 1st floor, 2nd, 3rd, roof

Maximum span: 1st floor, 2nd, 3rd, roof

If one story building with masonry walls, thickness of walls? height? .....

### IF A GARAGE

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated .....

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? .....

APPROVALS BY: DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING O.R. M.G.P. 5/13/77

BUILDING CODE: .....

Fire Dept.: .....

Health Dept.: .....

Others: .....

### MISCELLANEOUS

Will work require disturbing of any tree on a public street? ..

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? .....

Signature of Applicant Harold Hansen Phone # same

Type Name of above Harold Hansen 1  2  3  4

FIELD INSPECTOR'S COPY

Other and Address .....



NOTES

5-18-77 Nearly completed - got an ok from  
this office on the sonotubes (undersized) - mlg  
6-23-77 Work completed - mlg

Permit No. 77 10331  
Location 246 Capital Dr.  
Owner Harold J. Hester  
Date of permit 5-11-77  
Approved 5-16-77 J. R. D. D. D.

Two columns of horizontal lines for notes, with a large handwritten 'X' on the left side.

Small handwritten notes at the bottom left corner.



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Sept. 6 1961

PERMIT ISSUED 01121 SEP 6 1961 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 246 Capisic St. Use of Building Dwelling No. Stories 2 New Building Existing
Name and address of owner of appliance Harold Hanson, 246 Capisic St.
Installer's name and address E.J. Carland, 271 Cumberland Ave. Telephone

General Description of Work

To install Steam boiler (replacement)

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 4'
From top of smoke pipe 4' From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 8x8 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? YES

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner Size of vent pipe
Location of oil storage Number and capacity of tanks
Low water shut off Make No.
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

[Blank lines for miscellaneous information]

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] 9.6.61. [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES
E J Carland

CS 300

Signature of Installer

by: [Signature]

INSPECTION COPY

7.11

178

Form No. C-1/11/21

Location 246 Cypress St.

Owner Sharon Williams

Date of permit 9/6/21

Approved INSPECTION NOT COMPLETED

9.25.61 *[Signature]*

**NOTES**

- 1. Full Name
- 2. Year Bldg
- 3. Kind of Work
- 4. Name of Applicant
- 5. Name of Inspector
- 6. Date of Issue
- 7. High School
- 8. Name of City
- 9. Explain Scope of Work
- 10. Value of Application
- 11. Object of Work
- 12. What Building is proposed
- 13. What Building is proposed
- 14. Other notes
- 15. Inspector's Signature
- 16. License Number

9.18.61. Int at home

9.25.61. Int at home

[Lined area for handwritten notes and signatures]



R3 RESIDENCE ZONE

## APPLICATION FOR PERMIT

Class of Building or Type of Structure Third ClassPortland, Maine, June 15, 1961

PERMIT ISSUED

JUN 19 1961

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 246 Capisic Street Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Harold Hanson, 246 Capisic St. Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address OWNER Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Proposed use of building 2 car garage No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot dwelling  
 Estimated cost \$ 400. Fee \$ 2.00

## General Description of New Work

To construct 2-car open carport 24'x24'

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

## Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Height average grade to top of plate 8' Height average grade to highest point of roof 10'  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation concrete slab Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar from notes sent.  
 Material of underpinning 9" Sonotubes Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof flat Rise per foot \_\_\_\_\_ Roof covering Class C asphalt  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind hemlock Dressed or full size? dressed  
 Corner posts 6x6 Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-24" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor concrete, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x8  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 16"  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 12'  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot 0., to be accommodated 2 number commercial cars to be accommodated no  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

APPROVED:

H. E. M.

## Miscellaneous

Will work require disturbing of any tree on a public street? yes no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

C24 (88 SC MAINE PRINTING CO.


INSPECTION COPY

Signature of owner

Harold Hanson

NOTES

6/16/61 - Lecture over. *Allen*  
 7-10-61 Sonatubos ok to pour  
 7-20-61 1. poured. *AD*  
 8-16-61 Abant completed *AD*



Permit No. 611 674

7-24-61  
8-17-61  
8-2

Location 241 Opacic Dr.

Over *Edward Johnson*

Date of permit 6/19/61

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

246 Capric Street - 6/16/61 - Allen  
2-car carport (R3) CHECK AGAINST ZONING ORDINANCE

✓ Date - Before 6/15/57 - O.K.

✓ Zone Location - R3 O.K.

✓ 40 ft. setback area? (Section 21) No - O.K.

✓ Use - O.K.

~~Sewage Disposal~~

✓ Interior or Corner Lot - O.K.

✓ Rear Yards - O.K.

✓ Side Yards - O.K.

✓ Front Yards - O.K.

✓ Height - O.K.

✓ Building Area - 50,416 - House & carport 1,423 sq'

✓ Lot Area - 201,663 sq' - O.K.

~~Area per Family -~~

~~Width of Lot -~~

✓ Lot Frontage - O.K.

✓ Off-street Parking - O.K.



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, September 19, 1952

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~the following building~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 246 Capisic Street Within Fire Limit no Dist. No. \_\_\_\_\_  
 Owner's name and address Harold Hanson, 246 Capisic Street Telephone 4-0291  
 Lessee's name and address Dr. C. Cragin, 831 Congress Street Telephone \_\_\_\_\_  
 Contractor's name and address owner Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Proposed use of building garage (carport) No. families \_\_\_\_\_  
 Last use \_\_\_\_\_ No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot dwelling house  
 Estimated cost \$ 300. Fee \$ 2.00

## General Description of New Work

To construct 1-car carport 14' x 20'.

*226-248 & 223 B1-2  
 246-248 & Capisic (Hanson) 222 B16-17*

2-2x3 plate 10' span

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Permit to be issued to owner Details of New Work

Is any plumbing work involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Height average grade to top of plate 7' Height average grade to highest point of roof 11'  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation cedar posts at least 4' below grade Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof pitch-gable Rise per foot \_\_\_\_\_ Roof covering Asphalt Class C Und Lab  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind pine Dressed or full size? dressed and full size  
 Corner posts 2-2x4 Sills 4x4 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor dirt, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x4  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 23"  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 7'  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot 0, to be accommodated 1 number commercial cars to be accommodated 0  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

APPROVED: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner Harold Hanson

9/19



Permit No. 52/  
 Location 246 Cobourg St.  
 Owner Harold Hansen  
 Date of permit 1/52  
 Notif. closing-in \_\_\_\_\_  
 Inspn. closing-in \_\_\_\_\_  
 Final Notif. \_\_\_\_\_  
 Final Inspn. \_\_\_\_\_  
 Cert. of Occupancy issued \_\_\_\_\_

and he has started  
 to demolish carport and  
 take it all down  
 City of 1952  
 10/7/52

NOTES

9-22-52. Foundation are 2-2x4  
 bolted together & spaced approx  
 10" O.C. Sill in 4x4 not too  
 good with splines having no  
 air & any splines on layers  
 the ground. Studs are 2x4  
 + 2x3 - 5' on with horizontal  
 bars half way up & tied to  
 studs with angle iron clips  
 at bottom of some studs beam  
 narrow bolted & corner  
 part 2-2x4 are braced in  
 angle iron on corner  
 plate 3x4 with splines. Top rafters  
 are 2x3 approx 24" O.C. - gas board  
 1/2" thick  
 Sill after are 2x4 top splines  
 10/7/52 Harold Hansen was

AP 246 Capiale Street

10/16/52 WHE:U

October 6, 1952

Mr. Harold Hansen  
246 Capiale Street

c.c. Corporation Counsel

Dr. Charles L. Cragin  
831 Congress Street  
Portland, Maine

Gentlemen:-

When Mr. Hansen applied for a building permit on September 19th to construct a so-called "carport" 14 ft. x 20 ft. on the lot at 236-242 Capiale Street, reported to be owned by Dr. Cragin, and adjoining the Hansen lot, it appears that the construction work was well along toward completion in violation of the Building Code which requires a permit to be secured and posted on the premises before the work is started. If he had applied for his permit before starting the work, he would have found out that the carport, built on the adjoining vacant lot, would be contrary to the Zoning Ordinance in the Residence A Zone where the property is located because a building or structure of such a use is required to be on the same lot as the dwelling to which it is accessory, according to Section 15A of the Zoning Ordinance.

We also have also found out that his proposed methods of framing and supporting the structure were contrary to the Building Code:

Instead of double 2x4's of ordinary lumber buried in the ground for foundations - cedar posts extending no less than 4 ft. below the surface of the ground required.

Instead of 4x4 sills (some of these not in good condition), some of them spliced between supports - solid 4x6 required with a support under every splice.

Instead of 2x4 and 2x3 studs (pickets) about 5 ft. from center to center - no less than 2x4's required, and braced more definitely than has been done, in fact no less than 4x4 ought to be used in an open structure.

Instead of 3x4 plate (horizontal member at top of studs) - no less than 4x4 or doubled 2x4 required.

Instead of 2x3 rafters - no less than 2x4 required.

Now, it is fully realized that Mr. Hansen probably hurried ahead with this job without any idea of violating the laws, but with the thought of providing quickly a more or less temporary structure to shelter his car. If there were nothing in violation of the law, but the feature of not securing a permit first, we could help him to get the matter straightened out.

Since practically everything else is in violation of either the Zoning Ordinance or the Building Code, it is necessary that he have the structure removed completely before October 16th, 1952 - otherwise by duty will compel me to report the situation to the legal department for enforcement of the laws according to measures which may seem proper.

If there were any way out of this difficulty other than removing the building, I would be glad to tell you, but none appears. With regard to the location of the building on the adjoining vacant lot, there are appeal rights under the Zoning Ordinance to seek an exception from the Zoning Board of Appeals in the name of the owner of the lot on which the structure is proposed. To proceed with such an appeal requires certification of the matter by this department to the Board of Appeals in advance of filing the appeal. In view of the extensive nonconformity with the Building Code requirements for framing

October 6, 1953

Mr. Harold Hansen - - - - - 12

Mr. Charles L. Cragin

and supporting such a structure, we cannot permit the structure to stand while appeal proceedings are attempted.

Very truly yours,

Karren McDonald  
Inspector of Buildings

WMB/0

Mrs. Heasley:

Please do not accept appeal for this job until we have gotten the structure removed.

WMCD

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for carport  
at 246 Capric Street Date 9/19/52

1. In whose name is the title of the property now recorded? Dr. C. Crain
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? partially built  
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? \_\_\_\_\_
4. What is to be maximum projection or overhang of eaves or drip? \_\_\_\_\_
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Harold Hansen

R3 RESIDENCE ZC.

PERMIT ISSUED

01125  
NOV 8 1966

CITY of PORTLAND



### APPLICATION FOR PERMIT

Class of Building or Type of Structure: Third Class

Portland, Maine, April 8, 1966

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 246 Capisic Street Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_  
 Owner's name and address Harold Hansen, 246 Capisic St. Telephone 4-0291  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address OWNER Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
 Proposed use of building Dwelling No. families 1  
 Last use \_\_\_\_\_ " \_\_\_\_\_ No. families 1  
 Material frame \_\_\_\_\_ No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ 2000. Fee \$ 6.00

*Belated*

#### General Description of New Work

To demolish existing rear sunporch and to construct 12'x30' rear sunporch

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

#### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_  
 Height average grade to top of plate 11' Height average grade to highest point of roof 15'  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ at least 4' below grade No. stories 1 solid or filled land? solid earth or rock? earth  
 Material of foundation Sonotubes Thickness, top 9" bottom 9" cellar no  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering asphalt roofing Class C Ind. Lab.  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts 2-2x4 Sills 4x6  
 Size Girder \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor 2x8, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x8  
 On centers: 1st floor 16", 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 16"  
 Maximum span: 1st floor 12', 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 16'  
 If one story building with masonry walls, thickness of wall? \_\_\_\_\_ height? \_\_\_\_\_

#### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

#### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

*H. E. Ho*

DITION COPY

Signature of owner

*Harold T. Hansen*

NOTES

11-2-66 Work completed *MD*

*7*

Permit No. 26/1125

Location 2111 Ogden St.

Owner Harold Stamm

Date of permit 1/3/66

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

Staking Out Notice

Form Check Notice

Large grid area for notes with multiple horizontal lines.



# APPLICATION FOR PERMIT

PERMIT ISSUED  
01542

SEP 19 1952

Class of Building or Type of Structure Third Class

CITY of PORTLAND

Portland, Maine, September 19, 1952

Renewal of permit 47/2026

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~construct~~ demolish ~~the~~ the following building ~~as shown on the plans~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 246 Capisic Street Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's name and address Harold Hansen, 246 Capisic Street Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address owner Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans \_\_\_\_\_ No. of sheets \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
 Last use shed No. families \_\_\_\_\_  
 Material wood No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot dwelling  
 Estimated cost \$ \_\_\_\_\_ Fee \$ .50

### General Description of New Work

To demolish 1-story frame shed 10' x 12'.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO owner**

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

APPROVED:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner

Harold Hansen

INSPECTION COPY



NOTES

11-19-52 - Work completed

Permit No. 52/15423  
 Location 2740  
 Owner Stanley J. ...  
 Date of permit 9/19/52  
 Notif. closing-in  
 Inspn. closing-in  
 Final Notif.  
 Final Inspn. 11-19-52  
 Cert. of Occupancy issued

11-20-52

2491  
 2492  
 2493  
 2494  
 2495  
 2496  
 2497  
 2498  
 2499  
 2500  
 2501  
 2502  
 2503  
 2504  
 2505  
 2506  
 2507  
 2508  
 2509  
 2510  
 2511  
 2512  
 2513  
 2514  
 2515  
 2516  
 2517  
 2518  
 2519  
 2520  
 2521  
 2522  
 2523  
 2524  
 2525  
 2526  
 2527  
 2528  
 2529  
 2530  
 2531  
 2532  
 2533  
 2534  
 2535  
 2536  
 2537  
 2538  
 2539  
 2540  
 2541  
 2542  
 2543  
 2544  
 2545  
 2546  
 2547  
 2548  
 2549  
 2550  
 2551  
 2552  
 2553  
 2554  
 2555  
 2556  
 2557  
 2558  
 2559  
 2560  
 2561  
 2562  
 2563  
 2564  
 2565  
 2566  
 2567  
 2568  
 2569  
 2570  
 2571  
 2572  
 2573  
 2574  
 2575  
 2576  
 2577  
 2578  
 2579  
 2580  
 2581  
 2582  
 2583  
 2584  
 2585  
 2586  
 2587  
 2588  
 2589  
 2590  
 2591  
 2592  
 2593  
 2594  
 2595  
 2596  
 2597  
 2598  
 2599  
 2600

2601  
 2602  
 2603  
 2604  
 2605  
 2606  
 2607  
 2608  
 2609  
 2610  
 2611  
 2612  
 2613  
 2614  
 2615  
 2616  
 2617  
 2618  
 2619  
 2620  
 2621  
 2622  
 2623  
 2624  
 2625  
 2626  
 2627  
 2628  
 2629  
 2630  
 2631  
 2632  
 2633  
 2634  
 2635  
 2636  
 2637  
 2638  
 2639  
 2640  
 2641  
 2642  
 2643  
 2644  
 2645  
 2646  
 2647  
 2648  
 2649  
 2650  
 2651  
 2652  
 2653  
 2654  
 2655  
 2656  
 2657  
 2658  
 2659  
 2660  
 2661  
 2662  
 2663  
 2664  
 2665  
 2666  
 2667  
 2668  
 2669  
 2670  
 2671  
 2672  
 2673  
 2674  
 2675  
 2676  
 2677  
 2678  
 2679  
 2680  
 2681  
 2682  
 2683  
 2684  
 2685  
 2686  
 2687  
 2688  
 2689  
 2690  
 2691  
 2692  
 2693  
 2694  
 2695  
 2696  
 2697  
 2698  
 2699  
 2700

2701  
 2702  
 2703  
 2704  
 2705  
 2706  
 2707  
 2708  
 2709  
 2710  
 2711  
 2712  
 2713  
 2714  
 2715  
 2716  
 2717  
 2718  
 2719  
 2720  
 2721  
 2722  
 2723  
 2724  
 2725  
 2726  
 2727  
 2728  
 2729  
 2730  
 2731  
 2732  
 2733  
 2734  
 2735  
 2736  
 2737  
 2738  
 2739  
 2740  
 2741  
 2742  
 2743  
 2744  
 2745  
 2746  
 2747  
 2748  
 2749  
 2750  
 2751  
 2752  
 2753  
 2754  
 2755  
 2756  
 2757  
 2758  
 2759  
 2760  
 2761  
 2762  
 2763  
 2764  
 2765  
 2766  
 2767  
 2768  
 2769  
 2770  
 2771  
 2772  
 2773  
 2774  
 2775  
 2776  
 2777  
 2778  
 2779  
 2780  
 2781  
 2782  
 2783  
 2784  
 2785  
 2786  
 2787  
 2788  
 2789  
 2790  
 2791  
 2792  
 2793  
 2794  
 2795  
 2796  
 2797  
 2798  
 2799  
 2800

2801  
 2802  
 2803  
 2804  
 2805  
 2806  
 2807  
 2808  
 2809  
 2810  
 2811  
 2812  
 2813  
 2814  
 2815  
 2816  
 2817  
 2818  
 2819  
 2820  
 2821  
 2822  
 2823  
 2824  
 2825  
 2826  
 2827  
 2828  
 2829  
 2830  
 2831  
 2832  
 2833  
 2834  
 2835  
 2836  
 2837  
 2838  
 2839  
 2840  
 2841  
 2842  
 2843  
 2844  
 2845  
 2846  
 2847  
 2848  
 2849  
 2850  
 2851  
 2852  
 2853  
 2854  
 2855  
 2856  
 2857  
 2858  
 2859  
 2860  
 2861  
 2862  
 2863  
 2864  
 2865  
 2866  
 2867  
 2868  
 2869  
 2870  
 2871  
 2872  
 2873  
 2874  
 2875  
 2876  
 2877  
 2878  
 2879  
 2880  
 2881  
 2882  
 2883  
 2884  
 2885  
 2886  
 2887  
 2888  
 2889  
 2890  
 2891  
 2892  
 2893  
 2894  
 2895  
 2896  
 2897  
 2898  
 2899  
 2900



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

02534  
SEP 27 1947

Portland, Maine, Sept. 26, 1947

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 246 Capisic Street Use of Building Dwelling No. Stories 1  New Building  
Existing "  
Name and address of owner of appliance H. T. Henson, 246 Capisic St.  
Installer's name and address Wells Electric, 456 Fore St. Telephone 3-2683

### General Description of Work

To install 2 oil burning equipment in connection with existing steam heat

### IF HEATER, OR POWER BOILER

Location of appliance or source of heat \_\_\_\_\_ Type of floor beneath appliance \_\_\_\_\_  
If wood, how protected? \_\_\_\_\_ Kind of fuel \_\_\_\_\_  
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace \_\_\_\_\_  
From top of smoke pipe \_\_\_\_\_ From front of appliance \_\_\_\_\_ From sides or back of appliance \_\_\_\_\_  
Size of chimney flue \_\_\_\_\_ Other connections to same flue \_\_\_\_\_  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_

### IF OIL BURNER

Name and type of burner Gilbarco Labeled by underwriter's laboratories? yes  
Will operator be always in attendance? \_\_\_\_\_ Does oil supply line feed from top or bottom of tank? bottom  
Type of floor beneath burner concrete  
Location of oil storage basement Number and capacity of tanks 1-220 gal.  
If two 275-gallon tanks, will three-way valve be provided? \_\_\_\_\_  
Will all tanks be more than five feet from any flame? yes How many tanks fire proofed? \_\_\_\_\_  
Total capacity of any existing storage tanks for furnace burners none

### IF COOKING APPLIANCE

Location of appliance \_\_\_\_\_ Kind of fuel \_\_\_\_\_ Type of floor beneath appliance \_\_\_\_\_  
If wood, how protected? \_\_\_\_\_  
Minimum distance to wood or combustible material from top of appliance \_\_\_\_\_  
From front of appliance \_\_\_\_\_ From sides and back \_\_\_\_\_ From top of smokepipe \_\_\_\_\_  
Size of chimney flue \_\_\_\_\_ Other connections to same flue \_\_\_\_\_  
Is hood to be provided? \_\_\_\_\_ If so, how vented? \_\_\_\_\_  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_

### MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

OK 9-26-47 P.M.H.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Wells Electric Co.

By  
Signature of Installer

H. Charles Wells

INSPECTION COPY

Permit No. 47/ 2534

Location 246 Caprice St

Owner H. J. Hanson

Date of permit 9/27/47

Approval NOT COMPLETED

NOTES 12/5-48  
YFM

1. Fill Pipe

2. Vent Pipe

3. Inlet Heat

4. Regulator Support

5. Name Label

6. Stack Control

7. High Limit Control

8. Remote Control

9. Piping Support & Protection

10. Valve Supply Lines

11. Capacity of Tanks

12. Inlet Valve Supports

13. Fuel Inlet

14. Oil Gun

15. Instructor Card

12-16-47. Mt at home.  
YFM



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, August 15, 1947

PRIORITY ISSUED  
02026  
AUG 15 1947

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~demolish~~ ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 216 Capric Street Within Fire Limits? No Dist. No. \_\_\_\_\_  
 Owner's name and address Sally & Harold Hansen, 831 Congress Street Telephone \_\_\_\_\_  
 Former owner: Bertha M. & George A. Gibson Telephone \_\_\_\_\_  
 Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Contractor's name and address Owner Telephone \_\_\_\_\_  
 Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans \_\_\_\_\_ No of sheets \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
 Last use Sqab. storage No. families \_\_\_\_\_  
 Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Other buildings on same lot Dwelling  
 Estimated cost \$ \_\_\_\_\_ Fee \$ 1.50

### General Description of New Work

To demolish one story building 10' x 12'.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
 Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
 Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? No  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

APPROVED:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Sally & Harold Hansen

Signature of owner By: Sally Hansen

Permit No. 47/2426  
Location 246 Capland St.  
Owner Shelley & Harold Hansen  
Date of Permit 1/15/47  
Notif. closing-in \_\_\_\_\_  
Inspn. closing in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. 1/15/47  
Cert. of Occupancy issued none

NOTES

~~1/26/47 - 140 - not started  
1/15/47 - 140 - finished~~

~~Shelley~~

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for one-family dwelling-house

at Capisic (224-A-1)

Date 5/4/31

1. In whose name is the title of the property now recorded? George J. Berthel Gibson
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Yes
3. Is the outline of the proposed work now staked out upon the ground? Yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? Yes
4. What is to be maximum projection or overhang of eaves or drip? 18"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? Yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? Yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? Yes

Hamilton & Richardson  
by Edwin M. Hamilton  
Partner



RESIDENCE ZONE APPLICATION FOR PERMIT PERMIT ISSUED

Building or Type of Structure Three Class 0570

Portland, Maine, May 6, 1939 MAY 9 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter ~~extend~~ the following building structure ~~equipment~~, in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 320 Caplain Street Within Fire Limits? no Dist. No.       
Owner's or lessor's name and address Assessors 221-A-1 - Vol. 3 page 32  
George J. Gibson, et al 54 Grant St. Telephone       
Contractor's name and address G. J. Hamilton, 13 Leonard Street Telephone 3-5756  
Architect      Plans filed yes No. of sheets 1  
Proposed use of building dwelling house No. families 1  
Other buildings on same lot none  
Estimated cost \$ 3500. Fee \$ 1.25

Description of Present Building to be Altered

Material      No. stories      Heat      Style of roof      Roofing       
Last use      No. families     

General Description of New Work

To erect one family frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

yes Height average grade to top of plate yes 216"  
Size, front 38'6" depth 22' No. stories 1 Height average grade to highest point of roof 18'  
To be erected on solid or filled land? solid earth or rock? earth  
Material of foundation concrete Thickness, top 10" bottom 12" cellar yes  
sill at least 6" above grade  
Material of underpinning " to sill Height      Thickness       
Kind of Roof pitch Rise per foot 0" Roof covering Asphalt roofing Class 0 D. in. in.  
No. of chimneys 1 Material of chimneys brick of lining tile  
Kind of heat steam Type of fuel coal Is gas fitting involved? no  
Framing Lumber—Kind hard oak Dressed or Full Size? dressed  
Corner posts 4x6 Sills 4x6 Girt or ledger board? none Size       
Material columns under girders iron columns Size 4" Max. on centers 2'  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in no substitution - no corners  
Joists and rafters: 1st floor 2x7, 2nd 2x6 inf., 3rd     , roof 2x8  
On centers: 1st floor 16", 2nd 16", 3rd     , roof 20"  
Maximum span: 1st floor 12', 2nd 12', 3rd     , roof       
If one story building with masonry walls, thickness of walls?      height?     

If a Garage

No. cars now accommodated on same lot     , to be accommodated       
Total number commercial cars to be accommodated       
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?     

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto observed? yes

Signature of owner George J. Gibson  
G. J. Hamilton

RECEIVED COPY

4-153C



Permit No. 39/570  
 128 ~~Camden~~ St.  
 Owner: ~~George~~ ~~Gilson~~  
 Date: 5/9/39  
 Notif. closing in: 6/30/39 for 7/1/39  
 Insj. closing in: 7/1/39 GT  
 Final Inspn. 8/12/39 or 9/11/39  
 Cert. of Occupancy issued 8/26/39

NOTES  
 5/5/39 - Location staked  
 5/15/39 - Excavating - AGS  
 5/18/39 - Creating foundation - AGS  
 5/23/39 - Foundation by concrete - AGS  
 5/29/39 - No. 128 - AGS  
 6/2/39 - Same - AGS

Date	Description	Inspector	Remarks
6/9/39	Foundation wall	AGS	
6/11/39	Insul. floor frame	AGS	
6/21/39	Trimming	AGS	
6/22/39	Plated Plumbing work	AGS	
6/29/39	Working on electric	AGS	
7/1/39	Budapest mat	AGS	
7/1/39	Insulation	AGS	
7/4/39	Excavating	AGS	
7/21/39	Taken care of	AGS	



FILL IN COMPLETELY AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Permit ISSUED

1066  
JUL 20 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, July 20, 1939

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 227 Capisic Street Use of Building Dwelling No. Stories 1 New Building Existing  
 Name and address of owner of appliance George J. Gibson, et al., 54 Grant Street  
 Installer's name and address John A. Janssen, 35 Trammie Street Telephone 3-5556

General Description of Work

To install steam heating system

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel coal  
 Material of supports of appliance (concrete floor or what kind) concrete  
 Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, 2'  
 from top of smoke pipe 2' from front of appliance Over 4' from sides or back of appliance Over 3'  
 Size of chimney flue 8x12 Other connections to same flue none

IF OIL BURNER

Name and type of burner \_\_\_\_\_ Labeled and approved by Underwriters' Laboratories? \_\_\_\_\_  
 Will operator be always in attendance? \_\_\_\_\_ Type of oil feed (gravity or pressure) \_\_\_\_\_  
 Location oil storage \_\_\_\_\_ No. and capacity of tanks \_\_\_\_\_  
 Will all tanks be more than seven feet from any flame? \_\_\_\_\_ How many tanks fireproofed? \_\_\_\_\_

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of Installer John A. Janssen

PH  
in hand

See 39 / 570 - W79

Permit No. 39/1066

Location 120 Cass St

Owner George Gibson

Date of Permit 6/20/39

Post Card sent

Notif. for insp.

Approval Tag issued 8/24/39

Oil Burner Check List (date)

- 1. Kind of heat
- 2. Label
- 3. Anti-siphon
- 4. Oil storage
- 5. Tank distance
- 6. Vent Pipe
- 7. Fill Pipe
- 8. Gauge
- 9. Rigidity
- 10. Feed safety
- 11. Pipe sizes and material
- 12. Control valve
- 13. Ash pit vent
- 14. Temp. or pressure safety
- 15. Instruction card
- 16.

NOTE: IN CHECKING LIST, MARK X OR WITH LINE

NOTES

8/14/39 - 1/2" riser in chimney  
work for service pipe of water  
does not extend into flue

Curing and needles making  
up around top

*[Faint, mostly illegible handwritten notes and markings on the right side of the form, including vertical text on the far right edge.]*