

710-712 BRIGHTON AVENUE



A.P.-710 Brighton Avenue

Nov. 21, 1967

B & D Builders
Att: William D. DiBiase, Jr.
23 Leighton Road, Falmouth

cc to: Rudolph Paolilli
710 Brighton Avenue

Dear Mr. DiBiase:

Permit to construct 1-car frame garage 14'x20' at the above named location is being issued subject to plans received with the application and in compliance with Building Code restrictions as follows:

1. A permit cannot be issued in the future if it is desired to rigidly connect the garage to the dwelling by a breezeway or otherwise as the dwelling has a foundation below frost whereas the garage will rest on a concrete slab that is subject to frost action.
2. Ties of at least 2x4 inch stock are required at every other rafter at the plate level and hung in the center by a board to the rafters near the ridgeboard.

Very truly yours,

A. Allan Soule
Inspector II

AAS:m

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for 1 car garage
at 710 Brighton Ave. Date 11/17/67

1. In whose name is the title of the property now recorded? Rudolph Paolilli
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stake and hedge
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? 6"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? _____

William J. P. Paine



R3 PERM 113

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, November 17, 1967

PERMIT ISSUED
01273
21 1967
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 710 Brighton Ave. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Rudolph Paolilli, 710 Brighton Ave. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address B & D Builders, 23 Leighton Rd., Falme, Me. Telephone _____
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building 1 car garage No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot dwelling
Estimated cost \$ 1000. Fee \$ 5.00

General Description of New Work

To construct 1-car frame garage 14'x20'

9' opening - gable end
4x6 header

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO contractor**

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Height average grade to top of plate 9' Height average grade to highest point of roof 14'
Size, front 14' depth 20' No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation con. slab Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof pitch Rise per foot 6" Roof covering asphalt roofing Class C Und. Lab.
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind hemlock Dressed or full size? dressed
Corner posts 4x6 Sills 4x6 Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-24" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor concrete, 2nd _____, 3rd _____, roof 2x6
On centers: 1st floor _____, 2nd _____, 3rd _____, roof 24"
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 7'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot 0, to be accommodated 1 number commercial cars to be accommodated 0
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

APPROVED:

O.K. - 11/21/67 - Allan V. Blodgett

Miscellaneous

Will work require disturbing of any tree on a public stre no
Will there be in charge of the above work a person c. : to see that the State and City requirements pertaining hereto are observed? yes

Rudolph Paolilli
B & D Builders

INSPECTION COPY

Signature of owner By: Allan V. Blodgett

PH

A.P.-710 Brighton Avenue

Nov. 21, 1967

B & D Builders
Att: William D. DiBiase, Jr.
23 Leighton Road, Falmouth

cc to: Rudolph Paolilli
710 Brighton Avenue

Dear Mr. DiBiase:

Permit to construct 1-car frame garage 14'x20' at the above named location is being issued subject to plans received with the application and in compliance with Building Code restrictions as follows:

1. A permit cannot be issued in the future if it is desired to rigidly connect the garage to the dwelling by a breezeway or otherwise as the dwelling has a foundation below frost whereas the garage will rest on a concrete slab that is subject to frost action.
2. Ties of at least 2x4 inch stock are required at every other rafter at the plate level and hung in the center by a board to the rafters near the ridgeboard.

Very truly yours,

A. Allan Soule
Inspector II

AAS:m

CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. 55614
 Issued 3/1/67
 Portland, Maine Feb. 22, 1967

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Rudy Gallotta Tel. 7750422
 Contractor's Name and Address Anthony Marcin Tel. 7750422
 Location 710 B. Washington Ave Use of Building _____
 Number of Families _____ Apartments _____ Stores _____ Number of Stories _____
 Description of Wiring: New Work _____ Additions _____ Alterations _____

Pipe _____ Cable _____ Metal Molding _____ BX Cable _____ Plug Molding (No. of feet) _____
 No. Light Outlets _____ Plugs _____ Light Circuits _____ Plug Circuits _____
 FIXTURES: No. _____ Light Switches _____ Flu. or Strip Lighting (No. feet) _____
 SERVICE: Pipe _____ Cable Underground _____ No. of Wires 3 Size 100AMP
 METERS: Relocated _____ Added _____ Total No. Meters _____
 MOTORS: Number _____ Phase _____ P. _____ Amps _____ Volts _____ Starter _____
 HEATING UNITS: Domestic (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Commercial (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Electric Heat (No. of Rooms) _____

APPLIANCES: No. Ranges _____ Watts _____ Brand Feeds (Size and No.) _____
 Elec. Heaters _____ Watts _____
 Miscellaneous _____ Watts _____ Extra Cabinets or Panels _____
 Transformers _____ Air Conditioners (No. Units) _____ Signs (No. Units) _____
 Will commence 2/22 1967 Ready to cover in W. Veale Inspection _____ 19 _____
 Amount of Fee \$ 2.00 Signed Anthony Marcin

DO NOT WRITE BELOW THIS LINE

SERVICE METER _____ GROUND
 VISITS: 1 _____ 2 _____ 3 _____ 4 _____ 5 _____ 6 _____
 7 _____ 8 _____ 9 _____ 10 _____ 11 _____ 12 _____
 REMARKS:

INSPECTED BY J.W. Hester
 (OVER)

R3 RESIDENCE ZONE

PERMIT ISSUED
00350
MAY 12 1966
CITY of PORTLAND



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, May 9 1966

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 710 Brighton Ave. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Rudolph Paolilli, 710 Brighton Ave. Telephone 772-1543
Lessee's name and address _____ Telephone _____
Contractor's name and address B & D Builders, 27 Leighton Road Falmouth Telephone 797-3675
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building Dwelling No. families 1
Last use _____ No. families 1
Material frame No. stories 1 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 1200.00 Fee \$ 6.00

General Description of New Work

To construct 1-story frame addition 13' x 14' on rear of dwelling.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** _____ contractor

Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? no
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate 10' Height average grade to highest point of roof 17'
Size, front 13' depth 14' No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation concrete at least 4" below grade, top 10" bottom 10" cellar _____
Kind of roof pitch Rise per foot 5" Roof covering Asphalt Class C and Label. _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts _____ Sills 2x8 box _____
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd _____, 3rd _____, roof 2x6
On centers: 1st floor 12", 2nd _____, 3rd _____, roof 16"
Maximum span: 1st floor 12'6", 2nd _____, 3rd _____, roof 12'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any trees on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Chas. Allen - 5112164

Rudolph Paolilli
B & D Builders

Signature of owner by: William J. D. Pringle

CS 301

INSPECTION COPY

NOTES

5/10/66 - Tried to reach Mr. Di Baise by phone. - Call
 5/12/66 - Mr. Di Baise says 60% of wall inside addition will be open - Call
 5-25-66 Not started
 6-23-66 Not started
 7-11-66 " "
 9-6-66 E.I. made
 9-9-66 Forms O.K. to pour.
 10-6-66 O.K. to close in

Permit No. 66/350
 Location 710 Smith Ave.
 Owner Russell R. Riddle
 Date of permit 5/10/66
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice

Permit needed for Brick Front platform from wood.

X

in

43 RESIDENCE ZONE

PERMIT ISSUED

0059
JUL 19 1966



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, May 18, 1966

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 710 Brighton Ave. Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Eucolph Paolilli, 710 Brighton Ave. Telephone 772-1543
 Lessee's name and address _____ Telephone _____
 Contractor's name and address owners Telephone _____
 Architect _____ Specifications _____ Plans _____ No. of sheets _____
 Proposed use of building dwelling No. families 1
 Last use _____ No. families _____
 Material frame _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____ Fee \$ 3.00
 Estimated cost \$ 275.00

General Description of New Work

To demolish existing platform and steps (brick) on front of dwelling

To construct brick platform, steps and planter, 6'6" x 6'4"

Belated.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation concrete below _____ Thickness, top _____ bottom _____ cellar _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? _____
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

J. E. M.

CS 301

INSPECTION COPY

Signature of owner

Anna M. Paolilli



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, November 21, 1963

PERMIT ISSUED

NOV 22 1963

01564

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 710 Brighton Ave. Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Rudolph Paylilli, 710 Brighton Ave. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Philip Sloan, 9 Baily Ave. Telephone 773-4503
 Architect _____ Specifications _____ Plans _____ No. of sheets _____
 Proposed use of building Dwelling No. families 1
 Last use _____ " _____ No. families 1
 Material frame No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____
 Estimated cost \$ 400.00 Fee \$ 3.00

General Description of New Work

To demolish existing 4' x 3' side platform and steps. ^{left}
 To construct 5' x 10' addition on ^{left} side of dwelling, same location.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? yes
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? YLI
 Height average grade to top of plate 8' Height average grade to highest point of roof 12'
 Size, front 5' depth 10' No. stories 1 solid or filled land? solid earth or rock? earth
 Material of foundation (3) 9" sonotubes at least 4' below grade Thickness, to _____ bottom _____ cellar _____
 Kind of roof pitch Rise per foot 4" Roof covering Asphalt Class C Und Label
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts 4x6 Sills 4x6
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x6, 2nd _____, 3rd _____, roof 2x6
 On centers: 1st floor 16", 2nd _____, 3rd _____, roof 16"
 Maximum span: 1st floor 5', 2nd _____, 3rd _____, roof 5'
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

J. E. M.

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Rudolph Paylilli
Philip Sloan

CS 301


INSPECTION COPY

Signature of owner by: Philip M. Sloan

J.M.

NOTES

As R-C you are a min of a
 3' npt. allowed.
 2' - 5' = 1' remaining on side of
 addition, approx 7' x 10' is
 is 14' there after 2' x 2' x 2' x 2'
 12-5-63. Same as before
 in
 12-30-63 Completed
 HZ



Permit No. 57/1564
 Location 1114 1/2 Street, S. C. S.
 Owner J. L. H. H. H. H. H.
 Date of permit 11/27/63
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy Issued
 Starting Out Notice
 Form Check Notice

12-4
 12-15



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, May 26, 1960

224A - A 15
2410
VE
PERMIT ISSUED
00612
MAY 27 1960
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 710 Brighton Ave. Within Fire Limits? no Dist. No. _____
Owner's name and address Rudolph A Paolilli, 710 Brighton Ave. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone 2-3513
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building Dwelling No. families 1
Last use _____ No. families 1
Material brick No. stories 1 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 175.00 Fee \$ 2.00

General Description of New Work

To construct 3'8" x 5' -2" high bulkhead on rear of existing dwelling.
46' to rear lot line

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories 1 below solid or filled land? _____ earth or rock? _____
Material of foundation concrete at least 4" below grade Thickness, top 10" bottom 10" cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber--Kind hemlock Dressed or full size? dressed Corner posts _____ Sills _____
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Kind and thickness of outside sheathing of exterior walls? _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Rudolph A Paolilli

APPROVED:

ON-5/27/60-APP

Signature of owner


by Mrs. Rudolph Paolilli

INSPECTION COPY

F.M.

NOTES

6-13-60 Forms OK
to pour
6-16-60 Poured OK



Permit No. 00/619
 Location 710 English Ave.
 Owner F. L. Roberts
 Date of permit 6/27/60
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice 6/14/60

6-9-60

Header under 60-511



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 7/25/52

011
N-WJM

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 712 Brighton Ave Use of Building Dwelling No. Stories 1 1/2 New Building Existing " Name and address of owner of appliance Margaret G. Gagne Installer's name and address F. J. Talbot Oil & Co Telephone

General Description of Work

To install New Foroxil Warm Air Furnace and Burner

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? No If so, how protected? Kind of fuel? Oil Minimum distance to burnable material, from top of appliance or casing top of furnace 3 ft From top of smoke pipe 20 in From front of appliance 10 ft From sides or back of appliance 15 ft Size of chimney flue 2 x 12 Other connections to same flue No If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner General Automatic Pressure Labeled by underwriter's laboratories? Yes Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? Bottom Type of floor beneath burner Concrete Location of oil storage Basement Number and capacity of tanks 3 - 275 If two 275-gallon tanks, will three-way valve be provided? Will all tanks be more than five feet from any flame? Yes How many tanks fire proofed? Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Kind of fuel? Minimum distance to wood or combustible material from top of appliance From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: 7/25/52 O.H. W. J. M.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of Installer

Talbot Oil & Co S. J. Talbot

INSPECTION COPY



(RC) RESIDENCE ZONE - C
APPLICATION FOR PERMIT

PERMIT ISSUED

00390
APR 7 1952

Class of Building or Type of Structure Third Class

Portland, Maine, April 5, 1952

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~the proposed building~~ the following building ~~in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:~~

Location 710-712 Brighton Avenue Within Fire Limits? no Dist. No. _____
Owner's name and address The Minat Corp., 220 Cumberland Ave. Telephone 4-8013
Lessee's name and address _____ Telephone _____
Contractor's name and address owners Telephone _____
Architect _____ Specifications Standard Plan F Plans yes No. of sheets 1
Proposed use of building dwelling house No. families 1
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 6,800. Fee \$ 7.00

General Description of New Work

To construct $1\frac{1}{2}$ -story frame dwelling 24' x 38'.

Important notice sent

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owners

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? yes If not, what is proposed for sewage? _____
Height average grade to top of plate 13' Height average grade to highest point of roof 24'
Size, front 38' depth 24' at least 4' below grade No. stories 1\frac{1}{2} solid or filled land? solid earth or rock? earth
Material of foundation concrete Thickness, top 10" bottom 12" cellar yes
Material of underpinning " to sill _____ Height _____ Thickness _____
Kind of roof pitch-gable Rise per foot 10" Roof covering Asphalt Class C Und Lab
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat steam fuel oil
Framing lumber—Kind hemlock Dressed or full size? dressed
Corner posts 4x6 Sills box Girt or ledger board? _____ Size _____
Girders yes Size 6x8 full size Columns under girders Lally Size 3\frac{1}{2}" Max. on centers 7'
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8 2nd 2x8 3rd _____ roof 2x8
On centers: 1st floor 16" 2nd 16" 3rd _____ roof 24"
Maximum span: 1st floor 12' 2nd 12' 3rd _____ roof 12'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

OK - 4/7/52 - agj

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

The Minat Corp.

Signature of owner by: *[Signature]*

INSPECTION COPY

(COPY)

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION 710-712 Brighton Avenue

Issued to The Kinat Corp.

Date of Issue December 26, 1952

This is to certify that the building, premises, or part thereof, at the above location, built or ~~erected~~ under Building Permit No. 52/390, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

One-family Dwelling House

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

12/23/52

(Date)

Inspector


Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for dwelling Date 4/5/52
at 710-712 Brighton Avenue

1. In whose name is the title of the property now recorded? The Minat Corp.
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? yes
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? _____
4. What is to be maximum projection or overhang of eaves or drip? _____
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes



WARNING !!!

THIS BUILDING PERMIT IS ISSUED
SUBJECT TO SPECIAL CONDITION:

THAT NO CONCRETE SHALL BE Poured IN FOUNDATION FORMS AND NO LAYING OF UNIT MASONRY IN FOUNDATION WALLS SHALL BE STARTED UNTIL NOTICE HAS BEEN GIVEN AT THE DEPARTMENT OF BUILDING INSPECTION OF READINESS TO START ACTUAL MASONRY WORK, AND UNTIL RE-CHECK OF LOCATION HAS BEEN MADE BY INSPECTOR.

* * *

Original markings of corners of lot and especially stakes on street line set by Dept. of Public Works must be kept intact and easily accessible for re-check--not covered by excavated earth or building materials. Otherwise the "go-ahead" cannot be given. Dept. of Public Works cannot re-set their stakes.

* * *

Obviously the notice for re-check must be given at such a time as to allow reasonable opportunity to make re-check.

Warren McDonald
Inspector of Buildings

710-712 BRIGHTON AVENUE





APPLICATION FOR PERMIT

PERMIT ISSUED

MAY 10 1984

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION 471

ZONING LOCATION PORTLAND, MAINE May 9, 1984

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 710 Brighton Avenue Fire District #12-1543

1. Owner's name and address Rudolph Paolilli - same Telephone

2. Lessee's name and address Telephone

3. Contractor's name and address Owner Telephone

Proposed use of building dwelling No. of sheets

Last use same No. families 1

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 1,250.00

FIELD INSPECTOR—Mr. Appeal Fees \$

@ 775-5451 Base Fee 20.00

..... Late Fee

TOTAL \$

To replace window rotted, also to change style to bow as per plans 1 sheet of plans. work is completed.
04102

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work? no
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining kind of heat fuel
Framing lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?


APPROVALS BY: DATE
BUILDING INSPECTION—PLAN EXAMINER
ZONING:
BUILDING CODE:
Fire Dept.:
Health Dept.:
Others:

MISCELLANEOUS

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant Rudolph Paolilli Phone # same
Type Name of above 2 3 4
Other
and Address

2
FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



Rudolph A Pasilli
710 BRIGHTON Ave.

RECEIVED
MAY - 9 1984
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION 471

ZONING LOCATION PORTLAND, MAINE May 9, 1984

MAY 10 1984

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 710 Brighton Avenue Fire District #1 #2

1. Owner's name and address Rudolph Paolilli - same Telephone 772-1543

2. Lessee's name and address Telephone

3. Contractor's name and address Owner Telephone

Proposed use of building ... dwelling No. of sheets

Use ... same No. families ... 1

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 1,250.00. Annual Fee \$

FIELD INSPECTOR—Mr. 20.00

@ 775-5451

To replace window rotted, also to change style to bow as per plans 1 sheet of plans. work is completed. 04102

of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? no Is any electrical work involved in this work? no

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining Kind of heat fuel

Framing Lumber—Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? no

ZONING: Will there be in charge of the above work a person competent

BUILDING CODE: to see that the State and City requirements pertaining thereto

Fire Dept.: are observed?

Health Dept.:

Others:

Signature of Applicant Rudolph A Paolilli Phone # same

Type Name of above Rudolph A Paolilli 1 2 3


Other and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

RAISING
3-2 x 8 supports



Rudolph A Pasilli
710 BRIGHTON AVE.

RECEIVED
MAY - 9 1984
DEPT OF BLDG INSP
CITY OF PORTLAND

APPLICATION FOR PERMIT

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 171
ZONING LOCATION PORTLAND, MAINE May 9, 1984

PERMIT ISSUED
MAY 10 1984
CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 714 Brighton Avenue Fire District #1 [] #2 []
1. Owner's name and address Rudolph Paolilli - same Telephone 772-1543
2. Lessee's name and address Telephone
3. Contractor's name and address Owner Telephone
Proposed use of building dwelling No. of sheets
Last use same No. families 1
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$... 1,250.00. Appeal Fees \$
FIELD INSPECTOR - Mr. @ 775-5451 Base Fee .. 20.00
Late Fee
TOTAL \$

To replace window rotted, also to change style to bow as per plans 1 sheet of plans. work is completed. 04102

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? no Is any electrical work involved in this work? no
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs, (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated, number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? no
ZONING: Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant Rudolph A. Paolilli Phone # same
Type Name of above Rudolph A. Paolilli 1 2 3 4
Other and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Aug 21, 1985
 Receipt and Permit number D 05875

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specific items.

LOCATION OF WORK: 710 Brighton Avenue
 OWNER'S NAME: Rudy Paolilly ADDRESS: lives there

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL _____	FEEES _____
FIXTURES: (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____		
	Strip Flourescent _____	ft. _____			
SERVICES:	Overhead <input checked="" type="checkbox"/> Underground _____	Temporary _____	TOTAL amperes <u>200</u>		<u>3.00</u>
METERS: (number of)	<u>1</u>				
MOTORS: (number of)	Fractional _____				<u>.50</u>
	1 HP or over _____				
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____				
	Electric (number of rooms) _____				
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____				
	Oil or Gas (by separate units) _____				
	Electric Under 20 kws _____	Over 20 kws _____			
APPLIANCES: (number of)	Ranges _____	Water Heaters _____			
	Cook Tops _____	Disposals _____			
	Wall Ovens _____	Dishwashers _____			
	Dryers _____	Compactors _____			
	Fans _____	Others (denote) _____			
	TOTAL _____				
MISCELLANEOUS: (number of)	Branch Panels _____				
	Transformers _____				
	Air Conditioners Central Unit _____	Separate Units (windows) _____			
	Signs 20 sq. ft. and under _____				
	Over 20 sq. ft. _____				
	Swimming Pools Above Ground _____				
	In Ground _____				
	Fire/Burglar Alarms Residential _____				
	Commercial _____				
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	over 30 amps _____			
	Circus, Fairs, etc. _____				
	Alterations to wires <u>XX</u>				<u>2.00</u>
	Repairs after fire _____				
	Emergency Lights, battery _____				
	Emergency Generators _____				

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: _____
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____
 TOTAL AMOUNT DUE: 5.50

INSPECTION: 8-22-85
 Will be ready on 2 P.M., 1985; or Will Call _____
 CONTRACTOR'S NAME: Gorham Electric
 ADDRESS: 10 Main St. Gorham
 TEL: 642-2868
 MASTER LICENSE NO.: 08318 SIGNATURE OF CONTRACTOR: _____
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS —

Permit Number 05825

Location 710 Brighton Ave.

Owner R. Peabody

Date of Permit 8-21-85

Final Inspection

By Inspector NH

Permit Application Register Page No. 83

INSPECTIONS: Service ✓ by CH
Service called in OK
Closing-in _____ by _____

PROGRESS INSPECTIONS. _____

CODE
COMPLIANCE
COMPLETED
OK
DATE _____

DATE: _____ REMARKS:

This was done while I was on
vacation!