

156-158 BELFORT STREET

SHAW-WALKER

PERMIT  
NUMBER 5789

Date  
Issued 10-29-57

PORTLAND PLUMBING  
INSPECTOR

By: *[Signature]*

APPROVED FIRST INSPECTION

Date: *[Signature]*

By: *[Signature]*

APPROVED FINAL INSPECTION

Date: Nov. 11-57

By: *[Signature]*

TYPE OF BUILDING

☐ COMMERCIAL

☒ RESIDENTIAL

☐ SINGLE

☐ MULTI FAMILY

☐ NEW CONSTRUCTION

☐ REMODELING

SM 12-51

PORTLAND HEALTH DEPT.

PERMIT TO INSTALL PLUMBING

Address: *9. Pearl Street*

Installation For: *1584 B. St.*

Owner of Bldg.: *Same*

Owner's Address:

Plumber: *Sumner*

Date: 10-29-57

NEW	REP	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS	3	
		GARBAGE GRINDERS		
		SEPTIC TANKS		
1		HOUSE SEWERS		1.75
		ROOF LEADERS (conn. to house drain)		
				1.75
				Total

PLUMBING INSPECTION

<b>PERMIT NUMBER 5853</b> Date Issued: _____ PORTLAND PLUMBING INSPECTOR By: _____ APPROVED FIRST INSPECTION Date: <u>Nov. 13-57</u> By: <u>J. O. Welch</u> APPROVED FINAL INSPECTION Date: <u>Nov. 13-57</u> By: <u>J. O. Welch</u> TYPE OF BUILDING <input type="checkbox"/> COMMERCIAL <input type="checkbox"/> RESIDENTIAL <input type="checkbox"/> SINGLE <input type="checkbox"/> MULTI FAMILY <input type="checkbox"/> NEW CONSTRUCTION <input type="checkbox"/> REMODELING		<b>PERMIT TO INSTALL PLUMBING</b> Address: <u>158 Beacon St.</u> Installation For: <u>Gar. &amp; Kitchen</u> Owner of Bldg.: <u>Same</u> Owner's Address: <u>Same</u> Plan Drawn: <u>George W. Miller</u> Date: <u>11-12-57</u>		
NEW	REPL	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
	<input checked="" type="checkbox"/>	DRAINS	1	1-
		HOT WATER TANKS		
		TANKLESS WATER HEATERS	3	
		GARBAGE GRINDERS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS (conn. to house drain)		
			Total	1-

DM 12-53

PORTLAND HEALTH DEPT.

PLUMBING INSPECTION

CITY OF PORTLAND, MAINE  
Application for Permit to Install Wires

30 amp service change over to 100 amp.

Permit No. 56075

Issued

Portland, Maine Aug 18, 1967

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address George J. Miller Tel. 797-6091

Contractor's Name and Address Paul R. Beaune Tel. 724-3628

Location 158 Bedford St Use of Building Dwelling

Number of Families Apartments Stores Number of Stories 2

Description of Wiring: New Work Additions Alterations

100 amp service & electric range service

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)

No. Light Outlets Plugs Light Circuits Plug Circuits

FIXTURES: No. Light Switches Fluor. or Strip Lighting (No. feet)

SERVICE: Pipe Cable Under-ground No. of Wires 3 Size 2-2-14

METERS: Relocated Yes Added Total No. Meters

MOTORS: Number Phase H. P. Amps Volts Starter

HEATING UNITS: Domestic (Oil) No. Motors Phase H. P.

Commercial (Oil) No. Motors Phase H. P.

Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges 1 Watts 10.0 Brand Feeds (Size and No.) 6-2-4-1

Elec. Heaters Watts

Miscellaneous Watts Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Signs (No. Units)

Will commence work on 8/18/67 Ready to cover in 19 Inspection by 8/18/67

Amount of Fee \$ 3.50

Signed Paul R. Beaune Lic # 2533

DO NOT WRITE BELOW THIS LINE

SERVICE METER GROUND  
VISITS: 1 2 3 4 5 6  
7 8 9 10 11 12  
REMARKS:

INSPECTED BY F. W. [Signature]  
(OVER)



Date  
Issued 8/17/67  
Portland Plumbing Inspector  
By ERNOLD R. GOODWIN

App. First Insp.  
Date AUG 17 1967  
By ERNOLD R. GOODWIN

CHIEF PLUMBING INSPECTOR  
App. Final Insp.  
Date AUG 17 1967  
ERNOLD R. GOODWIN  
CHIEF PLUMBING INSPECTOR

Type of Bldg.  
☐ Commercial  
☐ Residential  
☐ Single  
☐ Multi Family  
☐ New Construction  
☐ Remodeling

# PERMIT TO INSTALL PLUMBING

PERMIT NUMBER 17587

Address <u>158 Pelport Street</u>			
Installation For:			
Owner of Bldg.: <u>George Miller</u>			
Owner's Address: <u>158 Pelport Street</u>		Date: <u>8/17/67</u>	
Plumber: <u>Raymond M. Miller</u>		NO. <u>17587</u>	
NEW	REPL.		
		SINKS	
		LAVATORIES	
		TOILETS	
		BATH TUBS	
		SHOWERS	
		DRAINS FLOOR SURFACE	
		HOT WATER TANKS	
		TANKLESS WATER HEATERS	
<u>1</u>		GARBAGE DISPOSALS	<u>1</u> <u>2.00</u>
		SEPTIC TANKS	
		HOUSE SEWERS	
		ROOF LEADERS	
<u>1</u>		AUTOMATIC WASHERS	<u>1</u> <u>2.00</u>
<u>1</u>		DISHWASHERS	<u>1</u> <u>2.00</u>
		OTHER	
		TOTAL	<u>3</u> <u>6.00</u>

Building and Inspection Services Dept.: Plumbing Inspection

CITY OF PORTLAND, MAINE  
Application for Permit to Install Wires

Permit No. 56054  
Issued 8/15/67  
Portland, Maine Aug 16, 1967

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address George Duval Miller Tel. ....  
Contractor's Name and Address Paul P. Heaume Tel. 724-3628  
Location 158 Bedford St Use of Building Dwelling  
Number of Families 1 Apartments ..... Stores 0 Number of Stories 2  
Description of Wiring: New Work ..... Additions ..... Alterations .....  
Install Disposal & Dish Washer  
Pipe ..... Cable 1 Metal Molding ..... BX Cable ..... Plug Molding (No. of feet) .....  
No. Light Outlets 2 Plugs ..... Light Circuits ..... Plug Circuits .....  
FIXTURES: No. .... Light Switches ..... Fluor. or Strip Lighting (No. feet) .....  
SERVICE: Pipe ..... Cable ..... Underground ..... No. of Wires ..... Size .....  
METERS: Relocated ..... Added ..... Total No. Meters .....  
MOTORS: Number ..... Phase ..... H. P. .... Amps ..... Volts ..... Starter .....  
HEATING UNITS: Domestic (Oil) ..... No. Motors ..... Phase ..... H.P. ....  
Commercial (Oil) ..... No. Motors ..... Phase ..... H.P. ....  
Electric Heat (No. of Rooms) .....  
APPLIANCES: No. Ranges ..... Watts ..... Brand Feeds (Size and No.) .....  
Elec. Heaters ..... Watts .....  
Miscellaneous ..... Watts ..... Extra Cabinets or Panels .....  
Transformers ..... Air Conditioners (No. Units) ..... Signs (No. Units) .....  
Will commence 19..... Ready to cover in 19..... Inspection Aug 16 1967  
Amount of Fee \$ 2.00  
Signed Paul P. Heaume Sr.  
no 2533

DO NOT WRITE BELOW THIS LINE

SERVICE ..... METER ..... GROUND .....  
VISITS: 1 ..... 2 ..... 3 ..... 4 ..... 5 ..... 6 .....  
7 ..... 8 ..... 9 ..... 10 ..... 11 ..... 12 .....  
REMARKS:

INSPECTED BY FWH

(OVER)



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR  
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, February 16, 1965

PERMIT ISSUED  
00149  
FEB 17 1965  
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 158 Belfort Street Use of Building Dwelling No. Stories 1  
Name and address of owner of appliance George Neil Miller, 158 Belfort St.  
Installer's name and address Dixon Bros., E. Gorham, Maine Telephone

General Description of Work

To install oil-fired domestic hot water heater in place of gas-fired water heater

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no  
If so, how protected? Kind of fuel? oil  
Minimum distance to burnable material, from top of appliance or casing top of furnace 15" shield  
From top of smoke pipe 21" From front of appliance 41" From sides or back of appliance 18"  
Size of chimney flue 8x12 Other connections to same flue furnace  
If gas fired, how vented? Rated maximum demand per hour  
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Delco Labelled by underwriters' laboratories? yes  
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?  
Type of floor beneath burner concrete Size of vent pipe  
Location of oil storage basement Number and capacity of tanks existing  
Water shut off Make No.  
All tanks be more than five feet from any flame? How many tanks enclosed?  
Capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?  
If so, how protected? Height of Legs, if any  
Clearing at bottom of appliance? Distance to combustible material from top of appliance?  
From front of appliance From sides and back From top of smokepipe  
Size of chimney flue Other connections to same flue  
Is hood to be provided? If so, how vented? Forced or gravity?  
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.K. 2-16-64 JAW

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Dixon Bros

300

INSPECTION COPY

Signature of Installer By:

Dixon Bros B.R. Robinson

Memorandum from Department of Building Inspection, Portland, Maine

AP- 158 Belfort St.

May 6, 1963

Mr. G. Neil Miller  
158 Belfort St.

Dear Mr. Miller:

Permit to relocate existing 2-car frame garage  
22'4"x20'4" as per plot plan received with application is being  
issued, but your attention is called to the following:

If it is desired to connect the garage  
to the dwelling in the future, we will  
be unable to issue a permit for a rigid  
connection as the garage foundation  
slab is subject to frost action whereas  
the house has a foundation extending  
below the frost level.

Very truly yours,

Gerald E. Mayberry  
Deputy Building Inspection Director

GEM:pa

CS-27





# APPLICATION FOR PERMIT

Class of Building or Type of Structure  
Portland, Maine,

R3 RESIDENCE ZONE

Third Class  
May 6, 1963

PERMIT ISSUED

00456

MAY 7 1963

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 153 Belfort St. Within Fire Limits: Dist. No. 3-6391  
Owner's name and address G. Neil Miller, 158 Belfort St. Telephone 3-6391  
Lessee's name and address Telephone  
Contractor's name and address c. ner Telephone  
Archite Specifications Plans yes No. of sheets 1  
Pro: se of building 2-car garage No. families  
Last use " " No. families  
Material frame No. stories Heat Style of roof Roofing  
Other buildings on same lot dwelling  
Estimated cost \$ 150.00 Fee \$ 3.00

## General Description of New Work

To relocate existing two car frame garage 22'4" x 20'4" on same lot as per plan.

Permit Issued with Memo

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

## Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?  
Is connection to be made to public sewer? If not, what is proposed for sewage?  
Has septic tank notice been sent? Form notice sent?  
Height average grade to top of plate Height average grade to highest point of roof  
Size, front depth No. stories solid or filled land? earth or rock?  
Material of foundation concrete slab Thickness, top bottom cellar  
Kind of roof Rise per foot Roof covering  
No. of chimneys Material of chimneys of lining Kind of heat fuel  
Framing Lumber-Kind Dressed or full size? Corner posts Sills  
Size Girder Columns under girders Size Max. on centers  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor 2nd 3rd roof  
On centers: 1st floor 2nd 3rd roof  
Maximum span: 1st floor 2nd 3rd roof  
If one story building with masonry walls, thickness of walls? height?

## If a Garage

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

G. E. M. W. Memo

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes  
G. Neil Miller

301

INSPECTION COPY

Signature of owner by:

G. Neil Miller



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR  
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 5, 1962

PERMIT ISSUED  
01294  
OCT 5 1962  
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 158 Belfort St. Use of Building Dwelling No. Stories 1 1/2 ~~New~~ Building  
Name and address of owner of appliance G. Neil Miller, 158 Belfort St. Existing "  
Installer's name and address Dixon Bros, 230 Main St, Gorham Maine Telephone

General Description of Work

To install Forced warm air heating system and oil burning equipment in place of gravity  
warm air heat. Delco-Model DeH112-B2

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none  
If so, how protected? Kind of fuel? oil  
Minimum distance to burnable material, from top of appliance or casing top of furnace 2 1/2'  
From top of smoke pipe over 18" From front of appliance over 4' From sides or back of appliance over 3'  
Size of chimney flue 8x8 Other connections to same flue gas water heater  
If gas fired, how vented? Rated maximum demand per hour  
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Delco-guntype Labelled by underwriters' laboratories? yes  
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom  
Type of floor beneath burner concrete Size of vent pipe 1 1/2"  
Location of oil storage basement Number and capacity of tanks 275 gal.  
Low water shut off Make No.  
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?  
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?  
If so, how protected? Height of Legs, if any  
Skirting at bottom of appliance? Distance to combustible material from top of appliance?  
From front of appliance From sides and back From top of smokepipe  
Size of chimney flue Other connections to same flue  
Is hood to be provided? If so, how vented? Forced or gravity?  
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

ON-10/5/62-agg

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Dixon Bros.

by:

[Signature]

CS 300

Signature of Installer

INSPECTION COPY

7M

May 8, 1956

AP - 158 Belfort Street

Mr. George N. Miller  
158 Belfort Street

Dear Mr. Miller:-

Building permit for construction of a  $1\frac{1}{2}$  story addition on rear of dwelling at the above location is issued herewith subject to compliance with the following details as discussed with you:-

- ✓ 1. The 6x8 glider is to be supported on two columns instead of one. Columns are to be of sound pipe having an outside diameter of not less than 4 inches fastened securely top and bottom. Footings are to be of concrete 2 feet square by 12 inches thick.
2. Second floor timbers are to be 2x6 spaced 16 inches on centers and are to be of full size lumber.
- ✓ 3. If rafters are to land on top of floor timbers instead of the double 2x4 plate, they are to be supported on no less than a 2x6 rafter shoe.
- ✓ 4. Sills of rear entrance platform are to be 4x6 all one piece in cross-section, not made up of two pieces of 2x6. Unless floor timbers are to rest on top of sills they are to be notched over 2x3 nailing pieces spiked to sides of sills.
5. Notification is to be given this department for an inspection before any lath or wallboard is applied to walls, partitions, or ceilings.

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS/G

2x6-12L

$\frac{2 \times 1100}{3 \times 12} \times \frac{2 \times 55}{6}$

$\frac{3}{2200}$   
733

$\frac{16}{733}$   
58

May 4, 1956

AP - 158 Belfort Street

$\frac{733}{12 \times 1/3} = 45'$

Owner-Contractor-George Neil Miller.  
158 Belfort Street

Examination of application for permit and plans filed therewith for construction of addition 16 feet by 24 feet on rear of dwelling at the above location discloses questions as to compliance with Building Code requirements as listed below. Before a permit can be issued it is necessary that information indicating compliance be furnished for checking and approval. Details in question are as follows:-

- the 6x8 girder indicated through center of building will not figure out on the spans of 8 feet indicated. Either an additional support will be needed or a larger sized timber used. Which will you do? - Use 2 columns
- we note that you indicate the use of an 8x8 concrete pier for support of the girder. Is this in error or is this what you actually plan to use? It is usual to use pipe columns for support of girders wherever there is a cellar. In any case concrete footings will be needed for support of piers or columns and size and thickness needs to be indicated. Use 4" pipe columns
- are the second floor timbers to be the same size and have the same spacing as those in first floor framing? - 2x6 full size 16" o.c.
- how many and what size windows are to be provided for new bedroom?
- what are sills of rear entrance platform to be? 4x6

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS/G

(RA) RESIDENCE ZONE - A



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, April 30, 1946

PERMIT ISSUED

00385

MAY 8 1946

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ alter ~~rehabilitate~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 158 Belfort St. Neil Within Fire Limits? Dist. No.  
Owner's name and address George Neil Miller, 158 Belfort St. Telephone   
Lessee's name and address  Telephone   
Contractor's name and address owner Telephone   
Architect  Specifications  Plans yes No. of sheets   
Proposed use of building Dwelling No. families 1  
Last use " No. families 1  
Material frame No. stories 1 1/2 Heat  Style of roof hip Roofing asphalt  
Other building on same lot   
Estimated cost \$ 1200. Fee \$ 2.00

## General Description of New Work

To construct 16'x24' addition on rear of building.  
To remove existing rear wall of building.  
To construct 3' dormer on new addition.  
To construct 3'6" x 4' platform and steps rear building  
concrete piers at least 4' below grade 8"  
2x6 floor joists, 16" O.C., 4' span - no roof

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

## Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes  
Is connection to be made to public sewer?  If not, what is proposed for sewage?   
Has septic tank notice been sent?  Form notice sent?   
Height average grade to top of plate 11' Height average grade to highest point of roof 19'  
Size, front  depth  No. stories  solid or filled land?  earth or rock?   
Material of foundation concrete at least 4' below grade Thickness, top 8" bottom 10" cellar yes  
Material of underpinning concrete blocks Height 24" Thickness 8"  
Kind of roof hip Rise per foot  Roof covering asphalt roofing Glass G. Ind. Lat.  
No. of chimneys none Material of chimneys  of lining  Kind of heat fuel  
Framing lumber—Kind hemlock Dressed or full size? dressed  
Corner posts 4x4 Sills 4x6 Girt or ledger board?  Size   
Girders yes Size 6x8 Columns under girders conc. pier Size 12" Max. on centers 8'-5"  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor 2x8 2nd 2x10 full base roof 2x6  
On centers: 1st floor 16" 2nd 16" 3rd  roof 16"  
Maximum span: 1st floor 12' 2nd 12' 3rd  roof   
If one story building with masonry walls, thickness of walls?  height?

## If a Garage

No. cars now accommodated on same lot , to be accommodated  number commercial cars to be accommodated   
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

with letter by AGJ

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

IN COPY

Signature of owner

616-254-15-Mark

George Neil Miller



NOTES

5/16/56 - *Marion, La. L.*  
*E.S.S.*  
 6/11/56 - *Marion, La. L.*  
*Insurance floor, brought*  
*members of box office needs*  
*to be handled. E.S.S.*  
 6/20/56 - *Hannover, La.*  
*E.S.S.*  
 8/16/56 - *in c. to ...*  
*detail with ...*  
*and ...*  
 9/24/56 - *Left C. to ...*  
*Chase in E.S.S.*  
 12/28/56 - *McNulty, Miss.*  
*made E.S.S.*

5/16/56 5:45 P.M.  
 4/16/56 8:45 P.M.  
 Permit No. 561585  
 Location 358 - *Edgar M.*  
 Owner *George Boyd Miller*  
 Date of permit 11/8/56  
 Notif. closing in 8/16/56 8:15  
 Inspn. closing in 12/24/56 9:45 P.M.  
 Final Notif.  
 Final Inspn.  
 Cert. of Occupancy issued  
 Staking Out Notice  
 Form Check Notice



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR  
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 14, 1953

PERMIT ISSUED  
01340

AUG 14 1953

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 158 Belfort St. Use of Building dwelling No. Stories 2 ~~New~~ Building  
Name and address of owner of appliance George Miller, Belfort Existing "158 Belfort St."  
Installer's name and address Holland Furnace Co., 8 Longfellow Square Telephone 5-3283

General Description of Work

To install coal-fired furnace 190 (gravity warm air heat) replacement

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no  
If so, how protected? \_\_\_\_\_ Kind of fuel? coal  
Minimum distance to burnable material, from top of appliance or casing top of furnace 18"  
From top of smoke pipe 18" From front of appliance over 4' From sides or back of appliance over 3'  
Size of chimney flue 8x8 Other connections to same flue no  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_  
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner \_\_\_\_\_ Labelled by underwriter's laboratories? \_\_\_\_\_  
Will operator be always in attendance? \_\_\_\_\_ Does oil supply line feed from top or bottom of tank? \_\_\_\_\_  
Type of floor beneath burner \_\_\_\_\_  
Location of oil storage \_\_\_\_\_ Number and capacity of tanks \_\_\_\_\_  
If two 275-gallon tanks, will three-way valve be provided? \_\_\_\_\_  
Will all tanks be more than five feet from any flame? \_\_\_\_\_ How many tanks fire proofed? \_\_\_\_\_  
Total capacity of any existing storage tanks for furnace burners \_\_\_\_\_

IF COOKING APPLIANCE

Location of appliance \_\_\_\_\_ Any burnable material in floor surface or beneath? \_\_\_\_\_  
If so, how protected? \_\_\_\_\_ Kind of fuel? \_\_\_\_\_  
Minimum distance to wood or combustible material from top of appliance \_\_\_\_\_  
From front of appliance \_\_\_\_\_ From sides and back \_\_\_\_\_ From top of smokepipe \_\_\_\_\_  
Size of chimney flue \_\_\_\_\_ Other connections to same flue \_\_\_\_\_  
Is hood to be provided? \_\_\_\_\_ If so, how vented? \_\_\_\_\_ Forced or gravity? \_\_\_\_\_  
If gas fired, how vented? \_\_\_\_\_ Rated maximum demand per hour \_\_\_\_\_

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? \$4.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

W. J. 8.14.53

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Holland Furnace Co.

Signature of Installer

By: Robert L. ...

INSPECTION COPY

8. 18.53 <sup>NOTES</sup> <sup>NOT TAKEN</sup> <sup>NOT</sup> <sup>NOT</sup>  
Sawyer (in. dept) that has  
damper removed, has not been  
removed.

Permit No.	53/1340
Location	158 Belland St.
Owner	George Mollen
Date of permit	8/14/53
Approved	10-12-53 (PM)

8-24 8-17 10-12  
6.25 9.76



(RA) RESIDENCE ZONE - A  
APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class  
Sept. 9, 1952  
Portland, Maine, 158 Belfort Street

PERMIT ISSUED

SERIAL 4133

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~alter, repair, demolish, or install~~ the following building structure ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 158 Belfort Street Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's name and address George Neil Miller, 158 Belfort St. Telephone 3-6391  
Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractor's name and address Owner Telephone \_\_\_\_\_  
Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
Proposed use of building 2 car garage No. families \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_  
Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Other buildings on same lot Dwelling  
Estimated cost \$ 800. Fee \$ 4.00

General Description of New Work

To construct 2-car frame garage 20' x 22'.

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Permit Issued with Letter:

Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Height average grade to top of plate 6' Height average grade to highest point of roof 16'  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation cedar posts at least 4' below grade Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof hip Rise per foot 5" Roof covering Asphalt Class C Und Lab  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of fuel \_\_\_\_\_  
Framing lumber—Kind hemlock Dressed or full size? dressed  
Corner posts 4x4 Sills 4x6 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2" x 16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor dirt, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x6  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 24"  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot 0, to be accommodated 2 number commercial cars to be accommodated 0  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

APPROVED:

with letter by JGS

Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

George Neil Miller

NOTES

9-10-52 Location O.P. 12 Jhr  
 10-15-52 Framing done. The leaders  
 over door opening as yet. wjm  
 - Leader closed 1.0 at 4.00 one door.  
 11-11-52 Work progressing 7.0 Jhr  
 12-5-52. Framing wjm  
 12-5-52 - 4.0 Jhr. Working on  
 1-7-53. Make completed except for leaders  
 which are 2 x 6's as required to be  
 4 x 8 one piece. do not know if there is  
 2 x 6's behind one exposed no direct  
 bearing of exposed. wjm

Permit No. 531473  
 Location 18421 W  
 Owner Long 4111 Miller  
 Date of permit 9/11/52  
 Notif. closing in  
 Insp. closing in  
 Final Notif.  
 Final Insp. 1-12-53 wjm  
 Cert. of Occupancy issued



AP 158 Belfort Street-I

September 11, 1952

Mr. George N. Miller  
158 Belfort Street  
Portland, Maine

Dear Mr. Miller:

Building permit for construction of a two car wood frame garage 22' x 20' on the lot with your dwelling at 158 Belfort Street is issued herewith subject to the following conditions:

1. Apparently you plan to space the cedar posts supporting the building about six feet on centers. On this basis the 4x6 sills will need to be placed with the 6-inch dimension upright.

2. There is no indication as to the material to be used for protection against the weather on the outside of the walls of the building. The use of wood, asphalt, or asbestos shingles, or wood clapboards or siding will satisfy the requirements of the Building Code, but the use of any type of roll roofing will not do so.

Very truly yours,

Warren McDonald  
Inspector of Buildings

AJS/S

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for garage  
at 158 Relfort Street Date 9/9/52

1. In whose name is the title of the property now recorded? George Neil Miller
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? stakes
3. Is the outline of the proposed work now staked out upon the ground? yes  
If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? \_\_\_\_\_
4. What is to be maximum projection or overhang of eaves or drip? \_\_\_\_\_
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Geo. Neil Miller



(RC) GENERAL RESIDENCE ZONE - C

# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third

Portland, Maine, August 7, 1945

PERMIT ISSUED

AUG 7 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 125 Belfort St. (156-158) Within Fire Limits? no Dist. No. 2-3287  
Owner's name and address Theodore T. Stewart 125 Belfort St. Telephone 2-3287  
Lessee's name and address None Telephone   
Contractor's name and address Owner Telephone   
Architect  Specifications  Plans  No. of sheets   
Proposed use of building Dwelling No. families 1  
Last used dwelling No. families 1  
Material frame No. stories 1 Heat warm air Style of roof  Roofing   
Other buildings on same lot no  
Estimated cost \$ 15. Fee \$ 25

## General Description of New Work

To enclose existing piazza with glass.  
Piazza existing with roof over same prior to Dec. 5, 1938  
More than half the area of the vertical enclosing walls will consist of window sash or glass area of doors

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Details of New Work

Is any plumbing work involved in this work? no Is any electrical work involved in this work? no  
Height average grade to top of plate  Height average grade to highest point of roof   
Size, front  depth  No. stories  solid or filled land?  earth or rock?   
Material of foundation  Thickness, top  bottom  cellar   
Material of underpinning  Height  Thickness   
Kind of roof  Rise per foot  Roof covering   
No. of chimneys  Material of chimneys  of lining  Kind of heat  fuel   
Framing lumber—Kind hemlock Dressed or full size? dressed  
Corner posts  Sills  Girt or ledger board?  Size   
Girders  Size  Columns under girders  Size  Max. on centers   
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor , 2nd , 3rd , roof   
On centers: 1st floor , 2nd , 3rd , roof   
Maximum span: 1st floor , 2nd , 3rd , roof   
If one story building with masonry walls, thickness of walls?  height?

## If a Garage

No. cars now accommodated on same lot , to be accommodated  number commercial cars to be accommodated   
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes Theodore T. Stewart

INSPECTION COPY

Signature of owner

Theodore C. Stewart

Permit No. 45/893

Location 125 Belford St.

Owner Theodore T. Stewart

Date of permit 8/7/45

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 5/14/46

Cert. of Occupancy issued

NOTES

9/18/45 Work Requested

4/7/46 Framing

4/24/46 same Ebb

5/14/45

SAME

RECEIVED  
OFFICE OF THE  
CELESTIAL DEPT.



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED  
2342  
NOV 14 1931

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

November 14, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine,

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 125 Belfort Street (156-158) Use of Building dwelling house  
Name and address of owner Theodore C. Stuart, 125 Belfort St. Ward 9  
Contractor's name and address Owner Telephone P 4008

## General Description of Work

To install one pipe furnace

### IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel concrete  
Material of supports of heater or equipment (concrete floor or what kind) concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, one big register  
from top of smoke pipe \_\_\_\_\_, from front of heater \_\_\_\_\_, from sides or back of heater \_\_\_\_\_

### IF OIL BURNER

Name and type of burner \_\_\_\_\_ Labeled and approved by Underwriters' Laboratories? \_\_\_\_\_  
Will operator be always in attendance? \_\_\_\_\_ Type of oil feed (gravity or pressure) \_\_\_\_\_  
Location oil storage \_\_\_\_\_ No. and capacity of tanks \_\_\_\_\_  
Will all tanks be more than seven feet from any flame? \_\_\_\_\_ How many tanks fireproofed? \_\_\_\_\_  
Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor Theodore C. Stuart

NOTIFICATION BEFORE LAYING  
OR CLOSING-IN IS WAIVED.  
CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED.





(R) GENERAL RESIDENCE ZONE Permit No. 1511  
APPLICATION FOR PERMIT

AUG 26 1931

Class of Building or Type of Structure Third Class

Portland, Maine, August 28, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 125 Belfort Street (156-158) Ward 9 Within Fire Limits? no Dist. No. \_\_\_\_\_

Owner's or Lessee's name and address T. C. Stuart, Belfort St. Telephone P 4008

Contractor's name and address Christian Olesen, 70 Smith St. Telephone \_\_\_\_\_

Architect's name and address \_\_\_\_\_

Proposed use of building dwelling house No. families 1

Other buildings on same lot none

Plans filed as part of this application? yes No. of sheets \_\_\_\_\_

Estimated cost \$ 100 Fee \$ 50

Description of Present Building to be Altered

Material wood No. stories 1 Heat \_\_\_\_\_ Style of roof front Roofing asphalt

Last use dwelling house No. families 1

General Description of New Work

To build 3'5" dormer on front and 7' dormer on side of roof  
To cover entire roof

20' to street line  
15' to side lot line

It is understood that this permit does not include installation of heating apparatus, which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_

To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_

Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of Roof pitch (front) Rise per foot 6" Roof covering Asphalt roofing Class C Und. Lab.

No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_

Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_

Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_

Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof

span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x6

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 18" x 16"

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 14'

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

No. cars now accommodated on same lot \_\_\_\_\_

Total number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto

are observed? yes

Signature of owner Theodore C. Stuart

INSPECTION COPY

front print

5716

Ward 9 Permit No. 31/1611  
 Location Lot 125 Belmont St.  
 Owner T. C. Stewart  
 Date of permit 8/28/31  
 Notif. closing-in \_\_\_\_\_  
 Inspn. closing-in \_\_\_\_\_  
 Final Notif. \_\_\_\_\_  
 Final Inspn. 9/9/31 O.B.  
 Cert. of Occupancy issued None

NOTES

~~7/28/31 - G.T.H. - Also got  
 in touch with Mr.  
 Olson about floor  
 long span 6'2" x 6'  
 rafters - done~~

~~8/29/31 -  
 see serial figures etc.  
 Work not started etc.~~

~~8/31/31 -  
 Work started, no new  
 framing etc.~~

~~8/2/31 -  
 Side dormer framed,  
 front not started, Mr.  
 Olson not working at  
 time. etc.~~

9/9/31.  
 Work covered by this  
 application about done,  
 one roof rafter to be  
 doubled on front dormer,  
 no claim for to be done,  
 Mr. Olson said probably  
 some partitions later on  
 but not now, will get  
 additional permit. O.B.



**YOU!** Location, Ownership and detail must be correct, complete and legible.  
Responsible for complying with the law, whether you know the requirements or not.  
Separate application required for every building.  
Plans must be filed with this application.

## Application for Permit for Alterations, etc.

This Application and  
Get All Questions Settled  
To the BEFORE Commencing Work.

Portland, Me., June 23, 1926 19

INSPECTOR OF BUILDINGS:

The undersigned applies for a permit to alter the following described building:-  
Location lot 125 Belfort Street Ward 9 in fire-limit? no  
Name of Owner or Lessee, T. C. Stuart Address Belfort Street  
" " Contractor, owner " "  
" " Architect, " "  
Description of Present Bldg. Material of Building is wood Style of Roof, pitch Material of Roofing, asphalt  
Size of Building is ..... feet long; ..... feet wide. No. of Stories, .....  
Cellar Wall is constructed of ..... is ..... inches wide on bottom and batters to ..... inches on top.  
Underpinning is ..... is ..... inches thick; is ..... feet in height.  
Height of Building ..... Wall, if Brick; 1st, ..... 2d, ..... 3d, ..... 4th, ..... 5th, .....  
What was Building last used for? dwelling No. of Families? 1  
What will Building now be used for? dwelling 1 family

### Detail of Proposed Work

Put in partition, alter windows

all to comply with the building ordinance

Estimated Cost \$ 100.

### If Extended On Any Side

Size of Extension, No. of feet long? .....; No. of feet wide? .....; No. of feet high above sidewalk? .....  
No. of Stories high? .....; Style of Roof? .....; Material of Roofing? .....  
Of what material will the Extension be built? ..... Foundation? .....  
If of Brick, what will be the thickness of External Walls? ..... inches; and Party Walls ..... inches.  
How will the extension be occupied? ..... How connected with Main Building? .....

### When Moved, Raised or Built Upon

No. of Stories in height when Moved, Raised, or Built upon? ..... Proposed Foundations? .....  
No. of feet high from level of ground to highest part of Roof to be? .....  
How many feet will the External Walls be increased in height? ..... Party Walls .....

### If Any Portion of the External or Party Walls Are Removed

Will an opening be made in the Party or External Walls? ..... in ..... Story.  
Size of the opening? ..... How protected? .....  
How will the remaining portion of the wall be supported? .....

Signature of Owner or  
Authorized Representative

Theodore C. Stuart

Address

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK



Location, ownership and detail must be correct, complete and legible. Separate application required for every building. Plans must be filed with this application.

## APPLICATION FOR PERMIT TO BUILD

(3D CLASS BUILDING)

Portland, Me., July 2, 1919 19

TO THE  
INSPECTOR OF BUILDINGS

The undersigned hereby applies for a permit to build, according to the following Specifications:—

(156-158)  
Location lot 124 Belfort Street Wd. 9  
Name of owner is? Henry Russell Address 49 Hanover St  
Name of mechanic is? Owner  
Name of architect is?  
Proposed occupancy of building (purpose)? Dwelling  
If a dwelling or tenement house, for how many families? 1  
Are there to be stores in lower story? No  
Size of lot, No. of feet front?; No. of feet rear?; No. of feet deep?  
Size of building, No. of feet front? 24 ft; No. of feet rear?; No. of feet deep? 28 ft  
No. of stories, front? 1 1/2; rear?  
No. of feet in height from the mean grade of street to the highest part of the roof? 17 ft  
Distance from lot lines, front? feet; side? feet; side? feet; rear? feet  
Firestop to be used? yes  
Will the building be erected on solid or filled land? solid  
Will the foundation be laid on earth, rock or piles?  
If on piles, No. of rows? distance on centres? length of?  
Diameter, top of? diameter, bottom of?  
Size of posts? 4x6 Studding 2x4 16 O C Sills 4x8 Roof Rafters 2x6 24 O C  
" girts? 4x4  
" floor timbers? 1st floor 2x8 2d 3d 4th  
O. C. " " " 16 O " " "  
Span " " " not over 16 ft, " " "  
Braces, how put in?  
Building, how framed?  
Material of foundation? cement blocks thickness of? 12 in laid with mortar?  
Underpinning, material of? brick height of? 3 ft thickness of? 8 in  
Will the roof be flat, pitch, mansard, or hip? hip Material of roofing? shingles  
Will the building be heated by steam, furnaces, stoves or grates? stone Will the flues be lined? yes  
Will the building conform to the requirements of the law? yes  
No. of brick walls? and where placed?  
Means of egress?

If the building is to be occupied as a Tenement House, give the following particulars:

What is the height of cellar or basement?  
What will be the clear height of first story? second? third?  
State what means of egress is to be provided?  
Scuttle and stepladder to roof?

Estimated Cost,

\$ 1500.

Signature of owner or authorized representative,

Henry G. Russell

Address,

Plans submitted?

Received by?

Plans must be submitted in duplicate, one set to be filed with the Department and the duplicate set thereof (bearing the approval of the Inspector of Buildings) shall be kept on the work and exhibited on demand.

PERMIT MUST BE RECEIVED BEFORE BEGINNING WORK.

# PERMIT TO INSTALL PLUMBING

14921

PERMIT NUMBER

Date: 2/21/65

PORTLAND PLUMBING INSPECTOR

By: J.P. Welch

APPROVED FIRST INSPECTION

Date: 2/23/65

APPROVED FINAL INSPECTION

Date: 2/25/65

JOSEPH P. WELCH

CHIEF PLUMBING INSPECTOR

TYPE OF BUILDING

☐ COMMERCIAL

☐ RESIDENTIAL

☐ SINGLE

☐ MULTI FAMILY

☐ NEW CONSTRUCTION

☐ REMODELING

Address: 150 Delfort Street

Installation For: G. Nell Miller

Owner of Bldg: Same

Owner's Address: Same

Plumber: G.B. Hannaford Jr.

Date: 2/21/65

NEW	REPL	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
	1	HOT WATER TANKS	1	\$2.00
		TANKLESS WATER HEATERS		
		GARBAGE GRINDERS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS (Conn. to house drain)		

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

TOTAL \$2.00





APPLICATION FOR PERMIT  
DEPARTMENT OF BUILDING INSPECTIONS SERVICES  
ELECTRICAL INSTALLATIONS

Date 5/28/92, 19  
Receipt and Permit number 3145

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 158 Belfort St.

OWNER'S NAME: Dennis Roach

ADDRESS: \_\_\_\_\_

FEES

OUTLETS:

Receptacles \_\_\_\_\_ Switches \_\_\_\_\_ Plugmold \_\_\_\_\_ ft. TOTAL \_\_\_\_\_

FIXTURES: (number of)

Incandescent \_\_\_\_\_ Fluorescent \_\_\_\_\_ (not strip) TOTAL \_\_\_\_\_

Strip Fluorescent \_\_\_\_\_ ft. \_\_\_\_\_

SERVICES:

Overhead ☒ Underground \_\_\_\_\_ Temporary \_\_\_\_\_ TOTAL amperes 100 ..

15.00

METERS: (number of) 1 ..

1.00

MOTORS: (number of)

Fractional \_\_\_\_\_

1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING:

Oil or Gas (number of units) \_\_\_\_\_

Electric (number of rooms) \_\_\_\_\_

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler) \_\_\_\_\_

Oil or Gas (by separate units) \_\_\_\_\_

Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

APPLIANCES: (number of)

Ranges \_\_\_\_\_ Water Heaters \_\_\_\_\_

Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_

Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_

Dryers \_\_\_\_\_ Compactors \_\_\_\_\_

Fans \_\_\_\_\_ Others (denote) \_\_\_\_\_

TOTAL \_\_\_\_\_

MISCELLANEOUS: (number of)

Branch Panels \_\_\_\_\_

Transformers \_\_\_\_\_

Air Conditioners Central Unit \_\_\_\_\_

Separate Units (windows) \_\_\_\_\_

Signs 20 sq. ft. and under \_\_\_\_\_

Over 20 sq. ft. \_\_\_\_\_

Swimming Pools Above Ground \_\_\_\_\_

In Ground \_\_\_\_\_

Fire/Burglar Alarms Residential \_\_\_\_\_

Commercial \_\_\_\_\_

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_

over 30 amps \_\_\_\_\_

Circus, Fairs, etc. \_\_\_\_\_

Alterations to wires \_\_\_\_\_

Repairs after fire \_\_\_\_\_

Emergency Lights, battery \_\_\_\_\_

Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE:

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE:

FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....

TOTAL AMOUNT DUE:

16.00

INSPECTION:

Will be ready on \_\_\_\_\_, 19\_\_; or Will Call ☒

CONTRACTOR'S NAME: Steven Stewart

ADDRESS: 16 Label - p11d

TEL.: 797-4611

MASTER LICENSE NO.: #13145

LIMITED LICENSE NO.: \_\_\_\_\_

SIGNATURE OF CONTRACTOR:

*[Signature]*

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN