

103-105 WEST COMMONWEALTH DRIVE

7E



Full cut # 9200 Half cut # 9202R Three cut # 9203R Full cut # 9205R

103 Commonwealth Drive

June 20, 1974

Paul Rheaume, Jr.
103 Commonwealth Drive

cc to: E&E Electrical Co.
57 Portland Street

Dear Mr. Rheaume:

In checking your application to construct a one car cement block garage 20' x 25' at the above named location we find that we are unable to continue processing your application until further information is provided as follows:

1. The work on this garage has already started and our field inspector has given a preliminary inspection and find this garage to be located only 3 feet from the side lot line and 2½ feet from the rear property line. If this is not so you should contact our field inspector, Mr. Ray Reitze here at City Hall and give him the correct lot line so that he may measure from them to your proposed garage. If your garage is only 2½ feet to the rear lot line and work has already been started then this would necessitate that this would have to be appealed to be able to locate this close to the lot line.
2. We will need to know whose roof trusses that you are using. We will need from the manufacturer their computation to show that they are built adequately strong to support the snow load in this part of the country.
3. You show a 4 foot frost wall on your plan, we will need to know the width of this wall. *12" FROST WALL*
4. What size are the cement blocks for this building? *8"*

Very truly yours,

A. Allan Soule
Asst. Director Building & Inspection
Services

AAS:m



APPLICATION FOR PERMIT

PERMIT ISSUED

JUL 24 1974

B.O.C.A. USE GROUP 00691

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION PORTLAND, MAINE, June 20, 1974..

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned her by applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 103 Commonwealth Drive W Fire District #1 [] #2 []
1. Owner's name and address .. Paul Rheaume, Jr., same Telephone 774-2020
2. Lessee's name and address Telephone
3. Contractor's name and address E & E Service Co., 57 Portland St. Telephone
4. Architect Specifications Plan YES No. of sheets 1
Proposed use of building ... 2 car garage No. families
Last use No. families
Material cement blocks stories 1 Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 3,000 plus belated fee-- belated fee-- Fee \$37.00

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451 To construct 20' x 25' one car cement block garage as per plans
Dwelling Ext. 234
Garage
Masonry Bldg. Stamp of Special Conditions
Metal Bldg.
Alterations
Demolitions
Change of Use
Other

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 [] 2 [] 3 [x] 4 []
Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building; with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot ..., to be accommodated ... number commercial cars to be accommodated ...
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER

ZONING: O.P. M.G. 7/24/74

BUILDING CODE: O.P. E.R. 7/24/74

Fire Dept.:

Health Dept.:

Others:

Will work require disturbing of any tree on a public street? ..

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes ...

Signature of Applicant Paul Rheaume Jr. Phone # 774-2020
Type Name of above E & E Service Co. 1 [] 2 [] 3 [x] 4 []

Other
and Address

FIELD INSPECTOR'S COPY


PERMIT (RENEW)

NOTES

7-31-74 (1476) MORE WORK STARTED
 8-9-74 127 127 RAY R
 Sept 10-1974 STILL WORKING ON
 GARAGE RAY REITZ
 Sept 18-1974 " " " RR
 Sept 21-1974 " " " RR
 Sept
 Oct 4- STILL WORKING ON
 GARAGE RAY REITZ
 Oct 25- GARAGE UP FINISHED
 EXCEPT DOORS RAY REITZ
 November 5-1974
 work brought complet Ray Reitz
 11-14-74 WORK FINISHED WORK
 Good RAY REITZ

Permit No. 74/691
 Location 123 Commonwealth Ave
 Owner Paul Revere
 Date of permit 2/24/74
 Approved

RAY
 Reitz





FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT ISSUED
01108
AUG 16 1960
CITY OF PORTLAND

Portland, Maine, August 16, 1960

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location LC3 Commonwealth Drive Use of Building Dwelling No. Stories 2 New Building Existing? Existing

Name and address of owner of appliance Jack French, Cumberland Maine

Installer's name and address Roland Shaw, 216 Middle Rd. Falmouth Telephone 5-2033

General Description of Work

To install Forced hot water heating system and oil burning equipment.

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? none

If so, how protected?

Kind of fuel? oil

Minimum distance to burnable material, from top of appliance or casing top of furnace 3 1/2

From top of smoke pipe 3' From front of appliance over 4' From sides or back of appliance over 3'

Size of chimney flue 8x10 Other connections to same flue none

If gas fired, how vented?

Rated maximum demand per hour

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner American Standard gun type Labelled by underwriters' laboratories? yes

Will operator be always in attendance?

Does oil supply line feed from top or bottom of tank? bottom

Type of floor beneath burner concrete Size of vent pipe 1 1/2"

Location of oil storage basement Number and capacity of tanks 275 gal.

Low water shut off Make No

Will all tanks be more than five feet from any flame? yes How many tanks enclosed?

Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?

If so, how protected?

Height of Legs, if any

Skirting at bottom of appliance?

Distance to combustible material from top of appliance?

From front of appliance From sides and back From top of smoke pipe

Size of chimney flue Other connections to same flue

Is hood to be provided? If so, how vented? Forced or gravity?

If gas fired, how vented?

Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

O. S. E. 8.8. 8/16/60

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Roland Shaw

CITY OF PORTLAND MAINE PRINTING CO.

INSPECTION COPY

Signature of Installer

by:

Roland H. Shaw

Permit No. 601 1108

Location 183 Commercial Pl. N. W.

Owner Jack & Frank

Date of Permit 8/16/60

Approved 5/15/60

| | | |
|----|---------------------------|--|
| 1 | Mill Pipe | |
| 2 | Port Pipe | |
| 3 | Kind of Test | |
| 4 | Number of Tests | |
| 5 | Name of Tester | |
| 6 | Spoke (Material) | |
| 7 | Flange (Material) | |
| 8 | Leakage (Location) | |
| 9 | Pipe Support & Protection | |
| 10 | Valves in Supply Line | |
| 11 | Capacity of Tanks | |
| 12 | Tank Height & Support | |
| 13 | Track Distance | |
| 14 | Oil Spills | |
| 15 | Insulation | |
| 16 | Low Water Stopoff | |

NOTES

Blank lined area for notes.



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, April 21, 1960

PERMIT ISSUED

MAY 5 1960

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 5 45-50 W. Commonwealth Drive (103-105) Within Fire Limits? Dist. No. _____

Owner's name and address Jack French, RFD 1, Cumberland Center Telephone 7a-9-3619

Lessee's name and address _____ Telephone _____

Contractor's name and address owner Telephone _____

Architect _____ Specifications _____ Plans yes No. of sheets 3

Proposed use of building dwelling No. families 1

Last use _____ No. families _____

Material frame _____ No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____

Other building on same lot _____

Estimated cost \$ 11,500. Fee \$ 12.00

General Description of New Work

to construct 1 1/2 story frame dwelling 32' x 24'

Permit Issued with Letter

Approval sustained 4/28/60

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes

Is connection to be made to public sewer? yes If not, what is proposed for sewage? _____

Has septic tank notice been sent? _____ Form notice sent? yes

Height average grade to top of plate 12' Height average grade to highest point of roof 22'

Size, front 32' depth 24' No. stories 1 1/2 solid or filled land? solid earth or rock? earth

Material of foundation concrete at least 4' below grade Thickness, top 10" bottom 10" cellar yes

Material of underpinning _____ Height _____ Thickness _____

Kind of roof pitch Rise 9" Roof covering Asphalt- Class C. Und. Lab.

No. of chimneys 1 Material brick Kind of heat f.h.w. fuel oil

Framing Lumber—Kind hemlock dressed Corner posts 2x4's Sills 2x8

Size Girder 2x10/ 6x8 fs Columns under girders dally Size 3 1/2" Max. on centers 7'7"

Kind and thickness of outside sheathing of exterior walls? _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 3 feet.

Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd _____, roof 2x6

On centers: 1st floor 16", 2nd 16", 3rd _____, roof 16"

Maximum span: 1st floor 12", 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated.

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED: 5/4/60 with letter

Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Jack French


By: Jack w French

INSPECTION COPY

T. Madsen

NOTES

5/19/60 - Form check made
 P.S.S.
 6/28/60 - left G.I. to
 close in P.S.S.
 8/15/60 - work done
 no permit for heat,
 P.S.S.
 8/16/60 - Cert. to be
 issued. P.S.S.



Permit No. 60/493
 Location 806 49th N. Minneapolis
 Owner Jack Street
 Date of permit 5/5/60
 Notif. closing-in 6/27/60
 Inspn. closing-in 6/28/60
 Final Notif. 6/29/60
 Final Inspn.
 Cert. of Occupancy issued 8/17/60
 Staking Out Notice
 Form Check Notice

(COPY)

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION **Lots 49-50 (Nos. 103-105)
Commonwealth Drive**
Date of Issue **August 17, 1960**

Issued to **Jack French
R.F.D. 2, Cumberland Center Maine**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **60/473**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

One family dwelling house

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

Carlo Smith

(Date)

Inspector

Albert J. Sears

Inspector of Building

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

AP 103-105 W Commonwealth Drive- New dwelling for a 1 by Jack French

May 4, 1960

Mr. Jack French
RFB1
Cumberland Center, Maine

cc to: W. T. Fox Company, Inc.
Morrill St.
Att: Mr. Roux

Dear Mr. French:

Building permit for the above dwelling is issued herewith subject to the following conditions. If these conditions are not understood or, if you are unable to comply with them, please contact the undersigned without delay.

- information
1. Please furnish by way of a supplementary plan as follows before notice is given for the required form inspection, otherwise our inspector will not be able to apply his sticker of approval to the permit card which is required before any concrete may be poured.

Indicate how the second floor joists are to be supported over the two bedroom closets, the coat closet and the hall. The first story bearing partition does not continue on through this area so that it is not available to support the second floor joists. The first story partition between the two bedroom closets will no doubt serve all right, but there is no such partition over the coat closet or the hall. If you should decide to use the two partitions at the ends of the coat closet and on either side of the hall, it is likely that the 2x8 first floor joists would be overloaded.

We have not discovered the proposed framing of the side entrance porch. Please show it.

2. A number of omissions from or deficiencies in the plan appear which should be cared for as the work progresses so the difficulties will not arise at the time of required inspections.

The nailing strips on the girder appear to be marked 2x2, the minimum is 2x3.

A stairway is shown to the second floor, but no floor upon the joists. Eventually, there will be, also, perhaps dormer windows may be built later and cross partitions. Probably the trimmer beams at the second floor stairwell will require doubling. If a prospective buyer should desire partitions in the second floor, they, of course, would have to be covered by amendment to the permit now issued, and it is likely that the joists under the non-bearing partitions would require doubling.

Mr. Jack French

Page 2

May 4, 1960

The rafters are shown to bear upon a "ribbon" running across the second floor joists. This is required to be at least 2x6 instead of the 2x4 shown on the plans.

3. On the supplementary plans to be filed before approval is given of pouring concrete, please indicate a cast iron cleanout door at the bottom of the chimney flue with the bottom of the door no more than 12 inches above the bottom of the flue.

Very truly yours,

Warren McDonald
Acting Deputy Insptr. of Bldgs.

WMcD:m

AP 103-105 (Lots 49&50) West Commonwealth Drive

April 21, 1960

Mr. Jack French
RFD 1
Cumberland Center

cc to: Corporation Counsel
cc to: Mr. Lester E. Marston
63 Brook Road
West Falmouth, Maine

Re: Mr. French

Building permit for construction of a single family dwelling 24 feet by 32 feet at the above named location is not issuable under the Zoning Ordinance because the land involved consists of two 30-foot wide lots having a combined width of only 60 feet and a total area of only 5630 square feet instead of the lot width of 65 feet and the lot area of 6500 square feet required by Sections 4-B-5 and 7 of the Ordinance applying to the R-3 Residence Zone in which the property is located.

We understand that the owner would like to exercise his appeal rights concerning these discrepancies. Accordingly we are certifying the case to the Corporation Counsel, to whose office in Room 208, City Hall, you should go to file the appeal. It will be necessary for the present owner of the property to sign the appeal.

Very truly yours,

Albert J. Sears
Inspector of Buildings

AJS:n

*Granted 4/28/60
60/39*

DATE: April 28, 1960

HEARING ON APPEAL UNDER THE ZONING ORDINANCE OF LESTER E. MARSTON

AT 103-105 West Commonwealth Drive

Public Hearing on the above appeal was held before the Board of Appeals.

BOARD OF APPEALS

VOTE

Franklin G. Hinckley
Ralph L. Young
Harry M. Shwartz

| Yes | No |
|-------------------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Record of Hearing:

No opposition.

CITY OF PORTLAND, MAINE
BOARD OF APPEALS

April 22, 1960

MISCELLANEOUS APPEAL

Lester E. Marston, owner of property at 103-105 West Commonwealth Drive under the provisions of Section 23 of the Zoning Ordinance of the City of Portland, hereby respectfully petitions the Board of Appeals to permit construction of a single family dwelling 24 feet by 32 feet at this location. This permit is presently not issuable because the land involved consists of two 30-foot wide lots having a combined width of only 60 feet and a total area of only 5630 square feet instead of the lot width of 65 feet and the lot area of 6500 square feet required by Sections 4-B-9 and 7 of the Ordinance applying to the R-3 Residence Zone in which the property is located.

LEGAL BASIS OF APPEAL:

Such permit may be granted only if the Board of Appeals finds that enforcement of the terms of the Ordinance would result in undue hardship and desirable relief may be granted without substantially departing from the intent and purpose of the Ordinance.

Lester E. Marston
APPELLANT

DECISION

After public hearing held April 28, 1960, the Board of Appeals finds that enforcement of the terms of the Ordinance would result in undue hardship and desirable relief may be granted without substantially departing from the intent and purpose of the Ordinance.

It is, therefore, determined that such permit should be issued.

Franklin D. Hurdley
Edith P. Young
Richard B. Nelson
BOARD OF APPEALS

CITY OF PORTLAND, MAINE
BOARD OF APPEALS

April 25, 1960

Mrs. Phyllis V. Malpass
Sarsfield Street
Portland, Maine

Dear Mrs. Malpass:

The Board of Appeals will hold a public hearing in the Council Chamber at City Hall, Portland, Maine, on Thursday, April 28, 1960, at 4:00 p.m. to hear the appeal of Lester E. Marston requesting an exception to the Zoning Ordinance to permit construction of a single family dwelling 24 feet by 32 feet at 103-105 West Commonwealth Drive.

This permit is presently not issuable because the land involved consists of two 30-foot wide lots having a combined width of only 60 feet and a total area of only 5630 square feet instead of the lot width of 65 feet and the lot area of 6500 square feet required by Sections 4-B-9 and 7 of the Ordinance applying to the R-3 Residence Zone in which the property is located.

All persons interested either for or against this appeal will be heard at the above time and place.

BOARD OF APPEALS

Franklin G. Minckley

Chairman

CITY OF PORTLAND, MAINE
BOARD OF APPEALS

April 23, 1960

Mrs. Phyllis V. Malpass
Sarsfield,

April 25, 1960

Mr. Lester E. Marston
68 Brook Road
West Falmouth, Maine

Dear Mr. Marston:

April 23,

cc: Mr. Jack French
R.F.D.#1
Cumberland Center, Maine

ALBERT J. SEARS
INSPECTOR OF BUILDINGS

CITY OF PORTLAND, MAINE
Department of Building Inspection

AP 103-105 (Lots 49&50) West Commonwealth Drive

April 21, 1960

Mr. Jack French
RFD 1
Cumberland Center

cc to: Corporation Counsel ✓
cc to: Mr. Lester E. Marston
68 Elm. Road
West Portland, Maine

Dear Mr. French:

Building permit for construction of a single family dwelling 24 feet by 32 feet at the above named location is not issuable under the Zoning Ordinance because the land involved consists of two 30-foot wide lots having a combined width of only 60 feet and a total area of only 5630 square feet instead of the lot width of 65 feet and the lot area of 6500 square feet required by Sections 4-B-9 and 7 of the Ordinance applying to the R-3 Residence Zone in which the property is located.

We understand that the owner would like to exercise his appeal rights concerning these discrepancies. Accordingly we are certifying the case to the Corporation Counsel, to whose office in Room 208, City Hall, you should go to file the appeal. It will be necessary for the present owner of the property to sign the appeal.

Very truly yours,

Albert J. Sears
Inspector of Buildings

AJS:m

C
O
P
Y

B PERMIT # 002349

TOWN OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Jack Moran

Address: 103 West Commonwealth Drive, Portland 04105

LOCATION OF CONSTRUCTION 103 West Commonwealth Drive

CONTRACTOR: Seabreeze Renovations CONTRACTORS: XXX 799-2230 or

ADDRESS: 18 Portland North Business Park, Falmouth 870-3449 been

Est. Construction Cost: \$25,000 Type of Use: single family

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain constructing dormer and adding bathroom.

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE 1 set of plans submitted

Residential Buildings Only:

Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Cills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size _____
6. Floor Sheathing Type: _____ Size _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Material _____

For Official Use Only

Date July 18, 1989 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost \$25,000 Permit Expiration: _____
 Value/Structure _____ Ownership: _____ Public _____ Private _____
 Fee \$145.00

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceilings: _____
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____
3. Roof Covering Type _____
4. Other _____

Chimneys:

Type: _____ Number of Fire Places _____

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning:

District: _____ Provided _____
 Required Setbacks _____ Side _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Site Plan _____ Subdivision _____
 Shore and Floodplain _____ Exception _____
 Other (Explain) _____
 Date Approved _____

Permit Received By Name: _____

Signature of Applicant: _____ Date: 7/18/89

Signature of CEO: _____ Date: _____

Inspection Dates: 4

White-Tax Assessor

Yellow-GPCOG

White Tag - C

© Copyright GPCOG 1987

PERMIT ISSUED

JUL 19 1989

City of Portland