

21 Euclid



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

December 27, 1984

L.C. Andrew Custom Homes
28 Depot Road
South Windham, Maine

RE: Lot #21 Euclid Street, Ptd, ME

Dear Sir;

Your application to construct a single family dwelling 24' x 30' 1 story has been reviewed and a building permit is herewith issued subject to the following requirements.

Site Plan Review Requirements

Inspection Division	Approved	Mr. W. Turner 12/26/84
Fire Dept.	N/A	
Public Works	Approved	Mr. R. Roy 12/11/84
Planning Div.	Approved	Ms. B. Barhydt 12/13/84

Building Code Requirements

1. Winter protection of concrete must be obtained.
2. Before calling for a foundation inspection have all lot line marked and lot number posted.
3. 809.4 Emergency escape: Every sleeping room below the fourth story in buildings of Use Groups B-3 and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms must have a minimum net clear opening of 5.7 square feet (0.53m²). The minimum net clear opening height dimension shall be 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm).
Bars, grilles or screens placed over emergency escape windows shall be releasable or removable from the inside without the use of a key, tool or excessive force.



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

EXCEPTIONS

1. Grade floor windows may have a minimum net clear opening of 5 square feet (0.47m²).
2. In buildings of Use Group R-3, where the sleeping room is provided with a door to a corridor having access to two remote exits in opposite directions, then an outside window or an exterior door for emergency escape from each such sleeping room is not required.
4. 1716.3.4 Sleeping areas and dwelling units: In addition to any automatic fire alarm system required by Sections 1716.3.2 and 1716.3.3, a minimum of one single station smoke detector shall be installed in each guest room, suite or sleeping area in buildings of Use Groups R-1 and I-1 and in dwelling units in the immediate vicinity of the bedrooms in buildings of Use Groups R-2 or R-3. When actuated, the detector shall provide an alarm suitable to warn the occupants within the individual unit (see Section 1717.3.1). In buildings of Use Group R-1 and R-2 which have basements an additional smoke detector shall be installed in the basement. In buildings of Use Group R-3, smoke detectors shall be required on every story of the dwelling unit including basements. In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level provided the lower level is less than one full story below the upper level. If there is an intervening door between the adjacent levels, a smoke detector shall be install on both levels. All detectors shall be installed in an approved location. Where more than one detector is required to be installed within an individual dwelling unit, the detectors shall be wired in such a manner that the actuation of one alarm will actuate all the alarms in the individual unit.
5. Please read Mr. Flaherty's memo to Mr. Gray which you will find enclosed.

If you have any questions on these requirements, please call this office.

Sincerely,

P. Samuel Hoffses
Chief of Inspection Services



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 01600

DEC 28 1984

ZONING LOCATION PORTLAND, MAINE Nov. 28, 1984

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION Lot # 21 1/2 Euclid St.
1. Owner's name and address Roland Mercier - Portland
2. Lessee's name and address
3. Contractor's name and address L. G. Andrew Custom Homes, Inc. 28 Depot St. So. Windham
Proposed use of building dwelling
Estimated contractual cost \$ 35,000
FIELD INSPECTOR - Mr. @ 775-5451
Appeal Fees \$
Base Fee 185.00
Late site plan 50.00
TOTAL \$ 235.00

site plan review
To construct ~~single~~ single family dwelling,
24' x 30' 1/2 story, no garage as per
plans 4 sheets of plans.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? yes
Is any electrical work involved in this work? yes
Is connection to be made to public sewer? existing
Has septic tank notice been sent?
Height average grade to top of plate
Material of foundation
Kind of roof
No. of chimneys
Framing Lumber - Kind
Site Girder
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

IF A GARAGE

No. cars now accommodated on same lot
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE
BUILDING INSPECTION - PLAN EXAMINER
ZONING
BUILDING CODE:
Fire Dept.
Health Dept.
Others:
MISCELLANEOUS
Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Applicant Roland Smith for L. G. Andrew
Type Name of above Roland Homes
Other
and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

CITY OF PORTLAND, MAINE

SITE PLAN REVIEW

Processing Form

4/31

L. C. Andrew Custom Homes

Nov. 29, 1984

Applicant 28 Depot Rd. So. Windham

Date _____

Mailing Address single family dwelling

Address of Proposed Site Lot # 21 Euclid Street

Proposed Use of Site 892 sq ft 720 sq ft

Site Identifier(s) from Assessors Maps 307-D-26

Acreage of Site 1/4 Ground Floor Coverage _____

Zoning of Proposed Site R-2

Site Location Review (DEP) Required: () Yes () No

Proposed Number of Floors 1 1/2

Board of Appeals Action Required: () Yes () No

Total Floor Area _____

Planning Board Action Required: () Yes () No

Other Comments: _____

Date Dept. Review Due: _____

BUILDING DEPARTMENT SITE PLAN REVIEW

(Does not include review of construction plans)

- Use does NOT comply with Zoning Ordinance
 - Requires Board of Appeals Action
 - Requires Planning Board/City Council Action

Explanation _____

Use complies with Zoning Ordinance — Staff Review Below

Zoning: SPACE & BULK, as applicable

	DATE	ZONE LOCATION	INTERIOR OR CORNER LOT	40 FT. SETBACK AREA (SEC. 21)	USE	SEWAGE DISPOSAL	REAR YARDS	SIDE YDS	FRONT YARDS	PROJECTIONS	HEIGHT	LOT AREA	BUILDING AREA	AREA PER FAMILY	WIDTH OF LOT	LOT FRONTAGE	OFF-STREET PARKING	LOADING BAYS	
COMPLIES		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	NA	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	NA	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	NA	
COMPLIES CONDITIONALLY																			CONDITIONS SPECIFIED BELOW
DOES NOT COMPLY																			REASONS SPECIFIED BELOW

REASONS: _____

Warren J. Turner
SIGNATURE OF REVIEWING STAFF DATE

**CITY OF PORTLAND, MAINE
SITE PLAN REVIEW**

4/31

Processing Form

Applicant Andrew Custom Homes

Date Nov. 29, 1991

Mailing Address 28 Depot Rd. So. Windham

Date

Proposed Use of Site Private single family dwelling

Address of Proposed Site Lot # 21 Bould Street

Acres of Site / Ground Floor Coverage 0.72/117

Site Identifier(s) from Assessors Maps P-3

Zoning of Proposed Site

Site Location Review (DEP) Required: Yes No

Proposed Number of Floors 1 1/2

Board of Appeals Action Required: Yes No

Total Floor Area

Planning Board Action Required: Yes No

Other Comments:

Date Dept. Review Due:

FIRE DEPARTMENT REVIEW

(Date Received)

	ACCESS TO SITE	ACCESS TO STRUCTURES	SUFFICIENT VEHICLE TURNING ROOM	SAFETY HAZARDS	HYDRANTS	SIAMASE CONNECTIONS	SUFFICIENCY OF WATER SUPPLY	OTHER	
APPROVED									
APPROVED CONDITIONALLY									CONDITIONS SPECIFIED BELOW
DISAPPROVED									REASONS SPECIFIED BELOW

REASONS:

(Attach Separate Sheet if Necessary)

Not required for single family dwelling

SIGNATURE OF REVIEWING STAFF/DATE

FIRE DEPARTMENT COPY

CITY OF PORTLAND, MAINE

SITE PLAN REVIEW

Processing Form

431
Nov. 21, 1984

L. C. Andrew Custas Homes

Applicant 28 Depot Rd. So. Portland

Date

Mailing Address ~~28 Depot Rd. So. Portland~~ single family dwelling

Address of Proposed Site Lot # 2, Euclid Street

Proposed Use of Site

Site Identifier(s) from Assessors Maps B-3

Acres of Site / Ground Floor Coverage

Zoning of Proposed Site

Site Location Review (DEP) Required: () Yes () No

Proposed Number of Floors 2 1/2

Board of Appeals Action Required: () Yes () No

Total Floor Area

Planning Board Action Required: () Yes () No

Other Comments:

Date Dept. Review Due:

FIRE DEPARTMENT REVIEW

(Data Received)

	ACCESS TO SITE	ACCESS TO STRUCTURES	SUFFICIENT VEHICLE TURNING ROOM	SAFETY HAZARDS	HYDRANTS	SIAMISE CONNECTIONS	SUFFICIENCY OF WATER SUPPLY	OTHER	
APPROVED									CONDITIONS SPECIFIED BELOW
APPROVED CONDITIONALLY									
DISAPPROVED									

REASONS:

(Attach Separate Sheet If Necessary)

Not required for single family dwelling

SIGNATURE OF REVIEWING STAFF/DATE

FIRE DEPARTMENT COPY

CITY OF PORTLAND, MAINE

SITE PLAN REVIEW

Processing Form

431

L. G. Andrew (Custom Homes)
 Applicant: 28 Depot Rd. No. Windham
 Mailing Address: ~~28 Depot Rd.~~ single family dwell.
 Proposed Use of Site: /
 Acreage of Site / Ground Floor Coverage: /

Nov. 29, 1984
 Date: /
 Address of Proposed Site: Lot # 21 Euclid Ave.
 Site Identifier(s) from Assessors Maps: /
 Zoning of Proposed Site: R-7

Site Location Review (DEP) Required: () Yes (X) No
 Board of Appeals Action Required: () Yes (X) No
 Planning Board Action Required: () Yes (X) No
 Proposed Number of Floors: 1 1/2
 Total Floor Area: /

Other Comments: Minor Site Plan Review

Date Dept. Review Due: /

PUBLIC WORKS DEPARTMENT REVIEW

(Date Received)

	TRAFFIC CIRCULATION	ACCESS	CURB CUTS	ROAD WIDTH	PARKING	SIGNALIZATION	TURNING MOVEMENTS	LIGHTING	CONFLICT WITH CITY CONSTRUCTION PROJECT	DRAINAGE	SPILL TYPES	SEWERS	CURBING	SIDEWALKS	OTHER	
APPROVED	NA	✓	✓	NA	✓	NA	✓	NA	✓	✓	✓	✓	✓	✓	✓	
APPROVED CONDITIONALLY																CONDITIONS SPECIFIED BELOW
DISAPPROVED																REASONS SPECIFIED BELOW

REASONS: /
 /
 /

(Attach Separate Sheet if Necessary)

Robert J. Ray
 Signature of Reviewing Staff/Date: Dec 11, 1984

PUBLIC WORKS DEPARTMENT COPY

CITY OF PORTLAND, MAINE
SITE PLAN REVIEW
 Processing Form

L. C. Andrew Custom home
 Applicant: 28 Depot Hill, Co. Winslow Date: Nov. 29, 1984
 Mailing Address: single family dwelling Address of Proposed Site: Lot # 21 Euclid Street
 Proposed Use of Site: / Site Identifier(s) from Assessors Maps: B-3
 Acreage of Site / Ground Floor Coverage: _____ Zoning of Proposed Site: _____
 Site Location Review (DEP) Required: () Yes () No Proposed Number of Floors: 1 1/2
 Board of Appeals Action Required: () Yes () No Total Floor Area: _____
 Planning Board Action Required: () Yes () No
 Other Comments: _____
 Date Dept. Review Due: _____

PLANNING DEPARTMENT REVIEW

(Date Received) _____

- Major Development — Requires Planning Board Approval: Review Initiated
 Minor Development — Staff Review Below

	LOADING AREA	PARKING	CIRCULATION PATTERN	ACCESS	PEDESTRIAN WALKWAYS	SCREENING	LANDSCAPING	SPACE & BULK OF STRUCTURES	LIGHTING	CONFLICT WITH CITY PROJECTS	FINANCIAL CAPACITY	CHANGE IN SITE PLAN
APPROVED	/	✓	✓	✓	✓	/	/	✓	/			
APPROVED CONDITIONAL												CONDITIONS SPECIFIED BELOW
DISAPPROVAL												REASONS SPECIFIED BELOW

REASONS: _____

(Attach Separate Sheet If Necessary)

B. Bawly dt 12/13/84
 SIGNATURE OF REVIEWING STAFF/DATE

PLANNING DEPARTMENT COPY



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

December 27, 1984

L.C. Andrew Custom Homes
28 Depot Road
South Windham, Maine

RE: Lot #21 Euclid Street, Ptld, ME

Dear Sir:

Your application to construct a single family dwelling 24' x 30' 1 story has been reviewed and a building permit is herewith issued subject to the following requirements.

Site Plan Review Requirements

Inspection Division	Approved	Mr. W. Turner 12/26/84
Fire Dept.	N/A	
Public Works	Approved	Mr. R. Roy 12/11/84
Planning Div.	Approved	Ms. B. Barhydt 12/13/84

Building Code Requirements

1. Winter protection of concrete must be obtained.
2. Before calling for a foundation inspection have all lot line marked and lot number posted.
3. 809.4 Emergency escape: Every sleeping room below the fourth story in buildings of Use Groups R-3 and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms must have a minimum net clear opening of 5.7 square feet (0.53m²). The minimum net clear opening height dimension shall be 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm).

Bars, grilles or screens placed over emergency escape windows shall be releasable or removable from the inside without the use of a key, tool or excessive force.




CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

EXCEPTIONS

1. Grade floor windows may have a minimum net clear opening of 5 square feet (0.47m²).
2. In buildings of Use Group R-3, where the sleeping room is provided with a door to a corridor having access to two remote exits in opposite directions, then an outside window or an exterior door for emergency escape from each such sleeping room is not required.
4. 1716.3.4 Sleeping areas and dwelling units: In addition to any automatic fire alarm system required by Sections 1716.3.2 and 1716.3.3, a minimum of one single station smoke detector shall be installed in each guest room, suite or sleeping area in buildings of Use Groups R-1 and I-1 and in dwelling units in the immediate vicinity of the bedrooms in buildings of Use Groups R-2 or R-3. When actuated, the detector shall provide an alarm suitable to warn the occupants within the individual unit (see Section 1717.3.1). In buildings of Use Group R-1 and R-2 which have basements an additional smoke detector shall be installed in the basement. In buildings of Use Group R-3, smoke detectors shall be required on every story of the dwelling unit including basements. In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level provided the lower level is less than one full story below the upper level. If there is an intervening door between the adjacent levels, a smoke detector shall be installed on both levels. All detectors shall be installed in an approved location. Where more than one detector is required to be installed within an individual dwelling unit, the detectors shall be wired in such a manner that the actuation of one alarm will actuate all the alarms in the individual unit.
5. Please read Mr. Flaherty's memo to Mr. Gray which you will find enclosed.
If you have any questions on these requirements, please call this office.

Sincerely,


P. Samuel Hoffas
Chief of Inspection Services

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP *B-3*

DEC 28 1961

B.O.C.A. TYPE OF CONSTRUCTION *01600*

ZONING LOCATION *R-3* PORTLAND, MAINE Nov. 28, 1961

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION Lot # 21 1/2 Euclid St. Fire District #1 , #2
 1. Owner's name and address Roland Mercier - Portland Telephone
 2. Lessee's name and address Telephone
 3. Contractor's name and address J. C. Andrew Custom Homes, - 28 Depot St. Telephone 892-3149
 So. Windham No. of sheets
 Proposed use of building *dwelling* No. families *1*
 Last use No. families
 Material No. stories Heat Style of roof Roofing
 Other buildings on same lot
 Estimated contractual cost \$ *35,000* Appeal Fees \$
 FIELD INSPECTOR--Mr. Base Fee 185.00
 @ 775-5451 Life plan 50.00
 TOTAL \$ 235.00

site plan review

To construct ~~single~~ single family dwelling, 24' x 30' 1/2 story, no garage as per plan 4 sheet s of plans.

Stamp / Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? *yes* existing Is any electrical work involved in this work? *yes*
 Is connection to be made to public sewer? If not, what is proposed for sewage?
 Has septic tank notice been sent? Form notice sent?
 Height average grade to top of plate Height average grade to highest point of roof
 Size, front depth No. stories solid or filled land? earth or rock?
 Material of foundation Thickness, top bottom cellar
 Kind of roof Rise per foot Roof covering
 No. of chimneys Material of chimneys of lining Kind of heat fuel
 Framing Lumber--Kind Dressed or full size? Corner posts Sills
 Size Girder Columns under girders Size Max. on centers
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2nd 3rd roof
 On centers: 1st floor 2nd 3rd roof
 Maximum span: 1st floor 2nd 3rd roof
 If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:	DATE	MISCELLANEOUS
BUILDING INSPECTION--PLAN EXAMINER	Will work require disturbing of any tree on a public street?
ZONING:
BUILDING CODE:	Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? <i>yes</i>
Fire Dept.
Health Dept.
Others:

Signature of Applicant *[Signature]* Phone # *same*
 Type Name of above *Roland Smith for J. C. Andrew*
Roland Homes
 Other
 and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY

[Handwritten initials]

NOTES


2/31/85

Location appears OK -
as indicated by stakes
showing lot line etc

About ~~1/2~~ completed -

3/12/85 Final, OK to issue
the Co. of O.

Permit No. 84/1600
 Location 241 Lincoln St.
 Owner Roland Martin
 Date of permit 11-28-84
 Approved 12-28-84
 Dwelling single family
 Garage
 Attention


 10 yr. quiet zone?

PLUMBING APPLICATION

Department of Human Services
Division of Health Engineering
(207) 269-3826

PROPERTY ADDRESS

Town Or Plantation: Portland

Street Subdivision Lot #: EUCLID ST LOT 21

PROPERTY OWNERS NAME

Last: WILSON First: HOWARD

Applicant Name: MARY E WILSON

Mailing Address of Owner/Applicant (if Different): 389 WILSON ST PORTLAND ME

PORTLAND PERMIT # 888 TOWN COPY

Date Permit Issued: 12/1/85 \$ _____ FEE Double Fee Charge

L.P.I. # _____

Franklin J. Gaudin

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Mary E Wilson 2-4-85

Signature of Owner/Applicant Date

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Franklin J. Gaudin APR 23 1985

Local Plumbing Inspector Signature Date Approved

PERMIT INFORMATION

This Application is for:	Type Of Structure To Be Served:	Plumbing To Be Installed By:
1. <input checked="" type="checkbox"/> NEW PLUMBING 2. <input type="checkbox"/> RELOCATED PLUMBING	1. <input checked="" type="checkbox"/> SINGLE FAMILY DWELLING 2. <input type="checkbox"/> MODULAR OR MOBILE HOME 3. <input type="checkbox"/> MULTIPLE FAMILY DWELLING 4. <input type="checkbox"/> OTHER - SPECIFY: _____	1. <input checked="" type="checkbox"/> MASTER PLUMBER 2. <input type="checkbox"/> OIL BURNERMAN 3. <input type="checkbox"/> MFG D. HOUSING DEALER/MECHANIC 4. <input type="checkbox"/> PUBLIC UTILITY EMPLOYEE 5. <input type="checkbox"/> PROPERTY OWNER
LICENSE # <u>023344</u>		

Number	Hook-Ups And Piping Relocation	Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
1	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.	2	Hosebibb / Sillcock	1	Bathtub (and Shower)
			Floor Drain		Shower (Separate)
			Urinal	1	Sink
	HOOK-UP: to an existing subsurface wastewater disposal system.		Drinking Fountain	1	Wash Basin
			Indirect Waste	1	Water Closet (Toilet)
			Water Treatment Softener, Filter, etc.	1	Clothes Washer
	PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures		Grease/Oil Separator		Dish Washer
			Dental Cuspidor	1	Garbage Disposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other: _____	1	Water Heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2	7	Fixtures (Subtotal) Column 1
				2	Fixtures (Subtotal) Column 2
				9	Total Fixtures
\$				20	Fixture Fee
\$				1	Hook-Up Fee
\$				3	Permit Fee (Total)

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Jan. 21, 19 85
 Receipt and Permit number D 02542

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Lot # 21 Euclid Avenue

OWNER'S NAME: L. C. Andrews ADDRESS: So. Windham

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL <u>31-60</u>	<u>5.00</u>
FIXTURES: (number of)					<u>3.50</u>
	Incandescent <u>15</u>	Flourescent _____	(not strip) TOTAL _____		
	Strip Flourescent _____	ft. _____			
SERVICES:	Overhead _____	Underground <u>x</u>	Temporary _____	TOTAL amperes <u>200</u>	<u>3.00</u>
METERS: (number of)	<u>1</u>	<u>50</u>			
MOTORS: (number of)	Fractional _____				
	1 HP or over _____				
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____				
	Electric (number of rooms) <u>6</u>	<u>6.00</u>			
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____				
	Oil or Gas (by separate units) _____				
	Electric Under 20 kws _____	Over 20 kws _____			
APPLIANCES: (number of)	Ranges _____	<u>x</u>	Water Heaters _____	<u>x</u>	
	Cook Tops _____		Disposals _____		
	Wall Ovens _____		Dishwashers _____		
	Dryers _____	<u>x</u>	Compactors _____		
	Fans _____		Others (denote) _____		
	TOTAL:				<u>4.50</u>
MISCELLANEOUS: (number of)	Branch Panels _____				
	Transformers _____				
	Air Conditioners: Central Unit _____				
	Separate Units (windows) _____				
	Signs 20 sq. ft. and under _____				
	Over 20 sq. ft. _____				
	Swimming Pools Above Ground _____				
	In Ground _____				
	Fire/Burglar Alarms Residential _____				
	Commercial _____				
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____				
	over 30 amps _____				
	Circus, Fairs, etc. _____				
	Alterations to wires _____				
	Repairs after fire _____				
	Emergency Lights, battery _____				
	Emergency Generators _____				
	INSTALLATION FEE DUE: _____				
	FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____				
	FOR REMOVAL OF A "STOP ORDER" (304-16.b)				
	TOTAL AMOUNT DUE: _____	<u>22.50</u>			

INSPECTION: service ready, will call onrest
 Will be ready on _____, 19____; or Will Call _____
 CONTRACTOR'S NAME: Bill Gudworth
 ADDRESS: Box 40 Springvale, Me.
 TEL: _____
 MASTER LICENSE NO.: 3685 SIGNATURE OF CONTRACTOR: John W. Gudworth Jr.
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION Lot # 21 Euclid Avenue

Issued to Roland Mercier

Date of Issue March 12, 1985

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 84-1600, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Single family dwelling
no garage

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

3/12/85

(Date)

Inspector

Inspector of Buildings

No fee. This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION Lot # 21 Euclid Avenue

Issued to Rola Mercier

Date of Issue March 12, 1965

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 84-1600, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Single family dwelling
no garage

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building premises, and ought to be transferred from owner or to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

PLUMBING APPLICATION

Department of Human Services
Division of Health Engineering
(207) 289-3526

PROPERTY ADDRESS

Town Or Plantation: Portland
 Street: Lo's 21
 Subdivision Lot #: Lo's 21

PROPERTY OWNERS NAME

Last: Barker First: Wayne

Applicant Name: Jim's Plumbing & Heating

Mailing Address of Owner/Applicant (If Different): 179 Marrett St. Westbrook, Me.

PORTLAND PERMIT # 1,147 TOWN COPY

Date Permitted: 7/10/85 \$ _____ FEE Double Fee Charged

L.P.I. # _____

Local Plumbing Inspector Signature: [Signature]

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any fabrication is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: [Signature] Date: 7-10-85

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature: _____ Date Approved: SEP 17 1985

PERMIT INFORMATION

This Application is for

1. NEW PLUMBING
 2. RELOCATED PLUMBING

Type Of Structure To Be Served:

1. SINGLE FAMILY DWELLING
 2. MODULAR OR MOBILE HOME
 3. MULTIPLE FAMILY DWELLING
 4. OTHER - SPECIFY _____

Plumbing To Be Installed By:

1. MASTER PLUMBER
 2. OIL BURNER/IAN
 3. MFG'D HOUSING DEALER/MECHANIC
 4. PUBLIC UTILITY EMPLOYEE
 5. PROPERTY OWNER

LICENSE # 10194A

JUL 10 1985

Number	Hook-Ups And Piping Relocation	Number	Column 2 Type of Fixture	Number	Column 1 Type Of Fixture
	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.	1	Hosebibb / Sillcock	1	Bathtub (and Shower)
			Floor Drain		Shower (Separate)
			Urinal	1	Sink
	HOOK-UP: to an existing subsurface wastewater disposal system		Drinking Fountain	1	Wash Basin
			Indirect Waste	1	Water Closet (Toilet)
			Water Treatment Softener, Filter, etc	1	Clothes Washer
	PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures		Grease/Oil Separator	1	Dish Washer
			Dental Cuspidor	1	Garbage Disposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other: _____	1	Water Heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2	8	Fixtures (Subtotal) Column 1
				1	Fixtures (Subtotal) Column 2
				9	Total Fixtures
				\$ 27.	Fixture Fee
				\$	Hook-Up Fee
				\$ 27.	Retain Fee (Total)

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE