

CITY OF PORTLAND, MAINE

SITE PLAN REVIEW

Processing Form

Applicant Allworth Street

Date Aug 5, 1986

Mailing Address _____

Address of Proposed Site _____

Proposed Use of Site _____

Site Identifier(s) from Assessors Maps _____

Acres of Site / Ground Floor Coverage _____

Zoning of Proposed Site _____

Site Location Review (DFP) Required: () Yes () No

Proposed Number of Floors _____

Board of Appeals Action Required: () Yes () No

Total Floor Area _____

Planning Board Action Required: () Yes () No

Other Comments: _____

Date Dept. Review Due: _____

FIRE DEPARTMENT REVIEW

(Date Received) _____

	ACCS TO SITE	ACCS TO STRUCTURES	SUFFICIENT VEHICLE TURNING ROOM	SAFETY HAZARDS	HYDRANTS	SIPMSE CONNECTIONS	SUFFICIENCY OF WATER SUPPLY	OTHER	
APPROVED									
APPROVED CONDITIONALLY									CONDITIONS SPECIFIED BELOW
DISAPPROVED									REASONS SPECIFIED BELOW

REASONS: According to submitted plans there are no hydrants. All structures are required to be within 100' of a hydrant. please submit two copies of utility plans with hydr. locations marked.

James P. Collins, Sr.
SIGNATURE OF REVIEWING STAFF/DATE

FIRE DEPARTMENT COPY

8-7-86

CITY OF PORTLAND, MAINE
MEMORANDUM

TO: Alexander Jaegerman, Chief Planner
FROM: Warren J. Turner, Zoning Enforcement Inspector *Warren J. Turner* DATE: August 12, 1986
SUBJECT: Aldworth Street Subdivision

The Fire Prevention Bureau is withholding its approval of the Aldworth Street Subdivision. According to submitted plans, there are no hydrants shown. All structures are required to be within 800 feet of a hydrant. The Fire Department is requesting two copies of utility plans as revised to include hydrants.