

196-199 ALLEN AVENUE

JE

PERMIT TO INSTALL PLUMBING

Date Issued: 5-26-64
 Address: 199 Allen Avenue
 Installation For: Mr. George A. Staples
 Owner of Bldg.: Mr. George A. Staples
 Owner's Address: Same
 Plumber: Portland Gas Light Company Date: 5-26-64

14040
 PERMIT NUMBER

By: J.P. Welch
 PORTLAND PLUMBING INSPECTOR

APPROVED FIRST INSPECTION
 Date: 6-4-64
 By: [Signature]

APPROVED FINAL INSPECTION
 Date: 5-26-64
 By: JOSEPH P. WELCH
 CHIEF PLUMBING INSPECTOR

- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

NEW		REPL	PROPOSED INSTALLATIONS		NUMBER	FEE
			SINKS			
			LAVATORIES			
			TOILETS			
			BATH TUBS			
			SHOWERS			
			DRAINS			
			HOT WATER TANKS			
			TANKLESS WATER HEATERS	2		\$ 4.00
			GARBAGE GRINDERS			
			SEPTIC TANKS			
			HOUSE SEWERS			
			ROOF LEADERS (Conn. to house drain)			

PORTLAND HEALTH DEPT. PLUMBING INSPECTION TOTAL ▶ \$ 4.00

LOCATION *Allen Ave. 199*
 INSPECTION DATE *4/10/73*
 WORK COMPLETED *4/10/73*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	
1 to 30 Outlets	\$ 2.00
31 to 60 Outlets	3.00
Over 60 Outlets, each Outlet05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	3.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit	1.50
MISCELLANEOUS	
Temporary Service, Single Phase	1.00
Temporary Service, Three Phase	2.00
Circuses, Carnivals, Fairs, etc.	10.00
Meters, relocate	1.00
Distribution Cabinet or Panel, per unit	1.00
Transformers, per unit	2.00
Air Conditioners, per unit	2.00
Signs, per unit	2.00
ADDITIONS	
5 Outlets, or less	1.60
Over 5 Outlets, Regular Wiring Rates	



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 1, 1963

PERMIT ISSUED
01255
OCT 1 1963
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 199 Allen Ave. Use of Building Dwelling No. Stories 1 New Building
Name and address of owner of appliance George A. Staples, 199 Allen Ave. Existing
Installer's name and address Ballard Oil & Equipment Co. 135 Marginal Way Telephone _____

General Description of Work

To install Oil burning equipment in connection with existing gravity warm air heat.
(conversion)

IF HEATER, OR POWER BOILER

Location of appliance _____ Any burnable material in floor surface or beneath? _____
If so, how protected? _____ Kind of fuel? _____
Minimum distance to burnable material, from top of appliance or casing top of furnace _____
From top of smoke pipe _____ From front of appliance _____ From sides or back of appliance _____
Size of chimney flue _____ Other connections to same flue _____
If gas fired, how vented? _____ Rated maximum demand per hour _____
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? _____

IF OIL BURNER

Name and type of burner Eso-gunttype Labeled by underwriters' laboratories? yes
Will operator be always in attendance? _____ Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 gal.
Low water shut off _____ Make _____ No. _____
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? _____
Total capacity of any existing storage tanks for furnace burners _____

IF COOKING APPLIANCE

Location of appliance _____ Any burnable material in floor surface or beneath? _____
If so, how protected? _____ Height of Legs, if any _____
Skirting at bottom of appliance? _____ Distance to combustible material from top of appliance? _____
From front of appliance _____ From sides and back _____ From top of smokepipe _____
Size of chimney flue _____ Other connections to same flue _____
Is hood to be provided? _____ If so, how vented? _____ Forced or gravity? _____
If gas fired, how vented? _____ Rated maximum demand per hour _____

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc. \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.R. E.S.S. 10/1/63

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Ballard Oil & Equipment Company

Signature of Installer by Lloyd W. Jordan

CS 300

INSPECTION COPY

J.M.

27/369-T R-2028

January 9, 1928

Holland Furnace Company
90 Congress Street
Portland, Maine

Gentlemen:

Referring to the furnace which you have installed for Mr. B. Allen at 199 Allen Avenue, the inspector from this office reports that the smoke pipe serving this furnace is not installed in accordance with law in that it is closer than 16 inches to the wooden floor joists above it.

You are required to make this smoke pipe comply with the Ordinance on or before January 31st, 1928. No further notice will be given.

Very truly yours,

INSPECTOR OF BUILDINGS

Copy to:
B. Allen
199 Allen Avenue

WM/EP



(R) GENERAL RESIDENCE ZONE

APPLICATION FOR PERMIT

Permit No. 0369

PERMIT ISSUED

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, April 14 1927

The undersigned hereby applies for a permit to install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 199 Allen Ave.

Owner's or Lessee's name and address B. Allen

Contractor's name and address Hocland Farming Co., 199 Allen Ave.

Architect's name and address 590 Congress St.

Proposed use of building dwelling house

Other buildings on same lot no

Material wood

Last use dwelling house

Description of Present Building to be Altered

General Description of New Work

Install warm circulating air furnace

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED.

NOTIFICATION BEFORE LATHING OR CLOSING-IN IS WAIVED.

Size, front depth

Details of New Work

To be erected on solid or filled land?

Material of foundation

Material of underpinning

Kind of roof

No. of chimneys none

Kind of heat warm air

If oil burner, name and model

Capacity and location of oil tanks

Is gas fitting involved?

Corner posts

Material columns under girders

Studs (outside walls and carrying partitions) 2x4-16" O.C.

Joists and rafters:

On centers:

Maximum span:

If one story building with masonry walls, thickness of walls?

No. cars now accommodated on same lot

Total number commercial cars to be accommodated

Will automobiles repairing be done other than minor repairs to cars habitually stored in the proposed building?

Plans filed as part of this application? no

Estimated cost \$250

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Fee \$ 4.75

328 1/2



(R) GENERAL RESIDENCE ZONE Permit No. 1310
APPLICATION FOR PERMIT PERMIT ISSUE

Class of Building or Type of Structure: Third Class SEP 13 1933
Portland, Maine, September 13, 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 195 Allen Avenue Ward 9 Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address Miss Helen Lambert 195 Allen Ave. Telephone _____

Contractor's name and address Clarence Towle 17 Farnham St. Telephone 2-0774

Architect's name and address _____

Proposed use of building Dwelling house No. families 1

Other buildings on same lot _____

Plans filed as part of this application? no No. of sheets _____

Estimated cost \$ 80.00 Fee \$.50

Description of Present Building to be Altered

Material wood No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____

Last use Dwelling house No. families 1

General Description of New Work

To remove existing brick chimney and rebuild new inside brick chimney. A cast iron cleanout door and damer will be provided at the bottom of the chimney flue. Since this a replacement, the flue lining will be omitted.

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation concr. Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys 1 Material of chimneys brick of lining _____

Kind of heat Stove Type of fuel coal Is gas fitting involved? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4 16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

By Miss Helen Lambert

Signature of owner _____

INSPECTION COPY

Clarence Towle

Permit # **912359** City of **Portland** BUILDING PERMIT APPLICATION Fee \$315 Zone _____ Map # _____ Lot# _____
 Please fill out any part which applies to job. Proper plans must accompany form.

Owner: PRVIC Phone # 874-8165
 Address: 196 Allen Ave; Ptld, ME 04103
 LOCATION OF CONSTRUCTION 196 Allen Ave.
 Contractor: Steege Auto Parts Sub.
 Address: Ptld, ME Phone # _____
 Est. Construction Cost: 50,000 Proposed Use: trade school w spray
 Past Use: trade school
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories: _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion Install spray paint booth

For Official Use Only
 Date: 12/10/90 Subdivision: _____
 Inside Fire Limits _____ Name: **PERMIT ISSUED**
 Bltg Code: _____ Lot: _____
 Time Limit: _____ Ownership: FEB 28 1991
 Estimated Cost: 59,000 Private _____
 City of Portland

Foundation: Portland Public Schools (Russell Brigham)
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear 04103 Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____
 Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____
 Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather exposure _____
 10. Masonry Materials _____
 11. Metal Materials _____
 Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

Ceiling:
 1. Ceiling Joists Size: _____
 2. Ceiling Strapping Size _____ Spacing _____
 3. Type Ceilings: _____
 4. Insulation Type _____ Size _____
 5. Ceiling Height: _____
 Roof:
 1. Truss or Rafter Size _____ Span _____
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 Chimneys:
 Type: _____ Number of Fire Places _____
 Heating:
 Type of Heat: _____
 Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____
 Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____
 Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.
 Permit Received By Louise E. Chase
 Signature of Applicant Russell Brigham Date 12/10/90
 Signature of CEO Russell Brigham Date 2-27-91
 Inspection Dates _____

912359 912359

Permit # 912359 City of Portland BUILDING PERMIT APPLICATION Fee \$315 Zone Map # Lot #
(transfer from School Dept.)
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: PRVTC Phone # 974-3155
 Address: 196 Allen Ave; Ptd, ME 04103
 LOCATION OF CONSTRUCTION 196 Allen Ave.
 Contract: Steago Auto Parts Sub.
 Address: Ptd, ME Phone #
 Est. Construction Cost: 50,000 Proposed Use: trade school w spray
 Past Use: trade school
 # of Existing Res. Units # of New Res. Units
 Building Dimensions L W Total Sq. Ft.
 # Stories: # Bedrooms Lot Size
 Is Proposed Use: Seasonal Condominium Conversion
 Explain Conversion Install spray paint booth

For Official Use Only PERMIT ISSUED
 Subdivision: Name: FEB 28 1990
 Date: 12/10/90 Inside Fire Limit: Lot:
 Bldg Code: Ownership: City of Portland
 Time Limit: Estimated Cost: 50,000
 Zoning: Street Frontage Provided:
 Provided Setbacks: Front Back Side Side
 Review Required:
 Zoning Board Approval: Yes No Date:
 Planning Board Approval: Yes No Date:
 Conditional Use: Variance Site Plan Subdivision
 Shoreland Zoning Yes No Floodplain Yes
 Special Exception
 Other (Exp):

Mail Permit: Portland Public Schools (Russell
 Foundation: 331 Veranda St.; Ptd, ME (Brig...)
 1. Type of Soil:
 2. Set Backs - Front Rear 0103 Side(s)
 3. Footings Size:
 4. Foundation Size:
 5. Other

Floor:
 1. Sills Size: Sills must be anchored.
 2. Girder Size:
 3. Lally Column Spacing: Size:
 4. Joists Size: Spacing 16" O.C.
 5. Bridging Type: Size:
 6. Floor Sheathing Type: Size:
 7. Other Material:

Exterior Walls:
 1. Studding Size Spacing
 2. No. windows
 3. No. Doors
 4. Header Sizes Sp... (s)
 5. Bracing: Yes No
 6. Corner Posts Size
 7. Insulation Type Size
 8. Sheathing Type Size
 9. Siding Type Weather Exposure
 10. Masonry Materials
 11. Metal Materials

Interior Walls:
 1. Studding Size Spacing
 2. Header Sizes Span(s)
 3. Wall Covering Type
 4. Fire Wall if required
 5. Other Materials

Ceiling:
 1. Ceiling Joists Size: Not in District for Landmark.
 2. Ceiling Strapping Size Spacing Does not require review.
 3. Type Ceilings:
 4. Insulation Type Size Requires Review.
 5. Ceiling Height:
 Roof:
 1. Truss or Rafter Size Span Action: Approved.
 2. Sheathing Type Size Approved with conditions.
 3. Roof Covering Type Size Denial.
 Chimneys:
 Type: Number of Fire Places Signs
 Heating:
 Type of Heat:
 Electrical:
 Service Entrance Size: Smoke Detector Required Yes No
 Plumbing:
 Approval of soil test if required Yes No
 2. No. of Tubs or Showers
 3. No. of Flushes
 4. No. of Lavatories
 5. No. of Other Fixtures
 Swimming Pools:
 1. Type: Square Footage
 2. Pool Size:
 3. Must conform to National Electrical Code and State Law.

Permit Received By Louise E. Chase
 Signature of Applicant [Signature] Date 12/12/90
 Signature of CEO Russell Arighan Date 2-22-91
 Inspection Dates
 White-Tax Assessor Yellow-GPCOG White Tag-CEO. Copyright GPCOG 1988

PLOT PLAN

N



FEES (Breakdown From Front)
Base Fee \$ 315 (*transfer School Dept*)
Subdivision Fee \$ _____
Site Plan Review Fee \$ _____
Other Fees \$ _____
(Explain) _____
Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS: *5/2/96 is all completed*

Signature of Applicant *Russell J. Esch* Date 12/10/96

**DEVILBISS CONCEPT CURE
PAINT SPRAY BOOTH**

ELECTRICAL RATINGS

Volts	Minimum Circuit Ampacity	Maximum Fuse Size
208	49.5A	50A
230	45A	50A
460	22.5A	25A

GAS INPUT - 970000 Btu/h

**REFER TO NAMEPLATE ON AIR HEATER
UNIT.**

**DEVILBISS CONCEPT/CURE PAINT SPRAY
BOOTH HAS BEEN CLASSIFIED AS
COMPLYING WITH NFPA 33 AND NFPA
86 BY ETL TESTING LABORATORIES,
ROUTE 11, INDUSTRIAL PARK,
CORTLAND, NY 13045**



ETL LISTED
CLASSIFIED
SPRAY PAINT BOOTH
PER REPCRT NO. 481646
00288300000
ETL TESTING LABORATORIES INC.
CORTLAND, NEW YORK 13045

LA-0168

*Lt. Garraway
Fire dept
380 Conje
Cortland*

*FYI.
Jesse Brigha*

For PRUTC Paint Booth.