

B

PERMIT # 513 CITY OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: William C. and Suzanne Gokey

Address: 28 Skylark Road Portland 797-6314

LOCATION OF CONSTRUCTION 28 Skylark Road

CONTRACTOR: Owner SUBCONTRACTORS: _____

ADDRESS: _____

Est. Construction Cost: 1,000 Type of Use: Single family

Past Use: _____

Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories _____ Lot Size _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion - Explain Construct 12' x 18' deck

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: # Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:

- 1. Type of Soil: _____
- 2. Set Backs - Front _____ Rear _____ Side(s) _____
- 3. Footings Size: _____
- 4. Foundation Size: _____
- 5. Other 6" cement sonotubes

Floor:

- 1. Sills Size: _____ Sills must be anchored.
- 2. Girder Size: _____
- 3. Lally Column Spacing: _____ Size: _____
- 4. Joists Size: ~~XXXX~~ 4 x 4 pressure treated spacing 16" O.C.
- 5. Bridging Type: 2 x 6 pressure treated Size: _____
- 6. Floor Sheathing Type: _____ Size: _____
- 7. Other Material: 3" railing 2 x 4, and 2 x 2

Exterior Walls:

- 1. Studding Size _____ Spacing _____
- 2. No. windows _____
- 3. No. Doors _____
- 4. Header Sires _____ Span(s) _____
- 5. Bracing: Yes _____ No _____
- 6. Corner Posts Size _____
- 7. Insulation Type _____ Size _____
- 8. Sheathing Type _____ Size _____
- 9. Siding Type _____ Weather Exposure _____
- 10. Masonry Materials _____
- 11. Metal Materials _____

Interior Walls:

- 1. Studding Size _____ Spacing _____
- 2. Header Sires _____ Span(s) _____
- 3. Wall Covering Type _____
- 4. Fire Wall if required _____
- 5. Other Materials _____

For Official Use Only	
Date: <u>May 11, 1988</u>	Subdivision: Yes <input type="checkbox"/> No <input type="checkbox"/>
Inside Fire Limits: _____	Name: _____
Bldg Code: _____	Lot: _____
Time Limit: _____	Block: _____
Estimated Cost: <u>1,000</u>	Permit Expiration: _____
Value/Structure: _____	Ownership: _____
Fee: <u>25</u>	Public <input type="checkbox"/> Private <input type="checkbox"/>

Ceiling:

- 1. Ceiling Joists Size: _____
- 2. Ceiling Strapping Size _____ Spacing PERMIT ISSUED
- 3. Type Ceilings: _____
- 4. Insulation Type _____ Size MAY 16 1988
- 5. Ceiling Height: _____

Roof:

- 1. Truss or Rafter Size _____ Spacing 6" on center
- 2. Sheathing Type _____ Size _____
- 3. Roof Covering Type _____
- 4. Other _____

Chimneys: Type: _____ Number of Fire Places: _____

Heating: Type of Heat: _____

Electrical: Service Entrance Size: _____ Smoke Detector Required Yes No

Plumbing:

- 1. Approval of soil test if required Yes No
- 2. No. of Tubs or Showers _____
- 3. No. of Flushes _____
- 4. No. of Lavatories _____
- 5. No. of Other Fixtures _____

Swimming Pools:

- 1. Type: _____
- 2. Pool Size: _____ x _____ Square Footage _____
- 3. Must conform to National Electrical Code and State Law.

Zoning: District: _____ Street Frontage Req.: _____ Provided _____

Required Setbacks: Front _____ Back _____ Side _____

Review Required:

Zoning Board Approval: Yes No Date: _____

Planning Board Approval: Yes No Date: _____

Conditional Use: _____ Variance: _____ Site Plan: _____ Subdivision: _____

Shore and Floodplain Mgmt: _____ Special Exception: _____

Other: (Explain) _____

Date Approved: _____

Permit Received By Lynne Benoit

Signature of Applicant William C. Gokey Date 5/11/88

Signature of CEO William C. Gokey Date _____

Inspection Dates: _____



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, September 27 1963

PERMIT ISSUED
01571
NOV 26 1963

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot D North St. Maple Brook Use of Building Dwelling No. Stories 1 1/2 New Building Existing

Name and address of owner of appliance Charles H. Hanson, 193 Allen Ave.

Installer's name and address Joseph Letellier & Sons 207 Pool St. Biddeford Telephone

General Description of Work

To install Forced hot water heating system and oil burning equipment.

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none

If so, how protected? Kind of fuel? oil

Minimum distance to burnable material, from top of appliance or casing top of furnace 3'

From top of smoke pipe 3' From front of appliance over 4' From sides or back of appliance over 3'

Size of chimney flue 8x8 Other connections to same flue none

If gas fired, how vented? Rated maximum demand per hour

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Came-gun type Labelled by underwriters' laboratories? yes

Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom

Type of floor beneath burner concrete Size of vent pipe 1 1/2"

Location of oil storage basement Number and capacity of tanks 275 gal.

Low water shut off Make No.

Will all tanks be more than five feet from any flame? yes How many tanks enclosed?

Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?

If so, how protected? Height of Legs, if any

Skirting at bottom of appliance? Distance to combustible material from top of appliance?

From front of appliance From sides and back From top of smoke pipe

Size of chimney flue Other connections to same flue

Is hood to be provided? If so, how vented? Forced or gravity?

If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:
E.S.L. 11/26/63

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Joseph Letellier & Sons

Signature of Installer by [Signature]

INSPECTION COPY

CS:300

Permit No. 63/1571

Location Mt. Airy, N. C.

Owner D. L. B. B. Co.

Date of permit 1/26/63

Approved 5/20/64

NOTES

A large rectangular area with horizontal lines, intended for handwritten notes or observations, is present. It is currently blank.

PERMIT TO INSTALL PLUMBING

24-28 Skyline Road

13328

Date Issued 9-26-63
 PORTLAND PLUMBING INSPECTOR

Address Lot D, North Street PERMIT NUMBER
 Installation For: C. H. Hanson Co.
 Owner of Bldg. C. H. Hanson Co.
 Owner's Address: 193 Allen Avenue

By J. P. Welch

Plumber: Joseph A. Estallier Date: 9-26-63

APPROVED FIRST INSPECTION

Date 9-26-63

By Klein

APPROVED FINAL INSPECTION

Date JOSEPH P. WELCH

CHIEF PLUMBING INSPECTOR

By June 17, 64

TYPE OF BUILDING
 COMMERCIAL
 RESIDENTIAL
 SINGLE
 MULTI FAMILY
 NEW CONSTRUCTION
 REMODELING

NEW		REP.	PROPOSED INSTALLATIONS	NUMBER	TEE
1			SINKS	1	\$ 2.00
1			LAVATORIES	1	2.00
1			TOILETS	1	2.00
1			BATH TUBS	1	2.00
			SHOWERS		
1			DRAINS	1	2.00
			HOT WATER TANKS		
			TANKLESS WATER HEATERS	1	.60
			GARBAGE GRINDERS		
			SEPTIC TANKS		
			HOUSE SEWERS		
			ROOF LEADERS (Conn. to house drain)		
1			Auto Wrecker	1	.60

PORTLAND HEALTH DEPT. PLUMBING INSPECTION TOTAL ▶ \$11.20

REMODELING

PORTLAND HEALTH DEPT. PLUMBING INSPECTION TOTAL ▶ \$ 2.00

CHIEF OF PLUMBING INSPECTION

JOSEPH H. MERRIFIELD

WELCH PLUMBING INSPECTION

13335

WELCH PLUMBING INSPECTION

WELCH PLUMBING INSPECTION

WELCH PLUMBING

13335

WELCH PLUMBING INSPECTION

PERMIT TO INSTALL PLUMBING

13335

PERMIT NUMBER

Date Issue: 9-26-63
PORTLAND PLUMBING INSPECTOR

Address: Lot D, Bertha Street

Installation For: C. H. Hanson Co.

Owner of Bldg: C. H. Hanson Co.

Owner's Address: 193 Allen Avenue

Plumber: Joseph T. Intallier

Date: 9-26-63

By: J. P. Welch

APPROVED FIRST INSPECTION

Date: Sept. 26, 1963

By: JOSEPH E. WELCH

APPROVED FINAL INSPECTION

Date: Sept. 26, 1963

By: JOSEPH E. WELCH

- TYPE OF BUILDING
- COMMERCIAL
- RESIDENTIAL
- SINGLE
- MULTI FAMILY
- NEW CONSTRUCTION
- REMODELING

NEW	REPL	PROPOSED INSTALLATIONS	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
		GARBAGE GRINDERS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS (Conn. to house drain)	1	\$ 2.00

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

TOTAL \$ 2.00

(COPY)

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION Pt. lots 195, 196 (Lot D) ^{Stephens Road} Bertha St.

Issued to Charles H Hanson
193 Allen Ave.

Date of Issue May 22, 1964

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 63/1566, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

One family dwelling house.

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notwithstanding to whom transferred from
owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

SURVEY BY G.M. WHEATON AND SURVEY
PLAN IS AVAILABLE


EAVES PROJECT 12"

LOT D

STRIP OF LOT 193 REC. PLAN THE HOLMSTEDS

ENTIRE 194 " " " "

196



BERTHA STREET

PROPOSED DWELLING
 OWNER CONTRACTOR CHAS. H. HANSON
 PLAN G.M. WHEATON
 MADE MAP 218 10 65 SCALE 1"=20'



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, November 20, 1963

PERMIT ISSUED

NOV 22 1963

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location (Pt. lots 195, 196) Lot 47 Bertha St. DeLack Road Within Fire Limits? 2 Dist. No. _____
Owner's name and address Charles H Hanson, 193 Aflen Ave. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone _____
Architect _____ Telephone 797-3335
Proposed use of building Dwelling Specifications _____ Plans yes No. of sheets 4
Last use _____ No. families 1
Material frame No. stories 1 1/2 Heat _____ Style of roof _____ No. families _____
Other buildings on same lot _____ Roofing _____
Estimated cost \$ 11,000.00 Fee \$ 22.00

General Description of New Work

To construct 1 1/2-story frame dwelling 26' x 32'

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO owner**

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? yes If not, what is proposed for sewer? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate 11' Height average grade to highest point of roof 22'
Size, front 32' depth 26' No. stories 1 1/2 solid or filled land? solid earth or rock? earth
Material of foundation concrete at least 4' below grade 1 thickness, top 10" bottom 10" cellar yes
Kind of roof pitch Rise per foot 9 1/2" Roof covering Asphalt Class C Wnd. Label
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat f.u. water oil
Framing Lumber-Kind hemlock Dressed or full size? dressed Corner posts 4x6 Sills 2x8 box
Size Girder 6x10 Columns under girders Lally Size 3 1/2" Max. on centers 6'10"
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd _____, roof 2x8
On centers: 1st floor 12" & 16", 2nd 12" & 16", 3rd _____, roof 16"
Maximum span: 1st floor 13', 2nd 13', 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

J. E. H.

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Charles H Hanson

Signature of owner by: Charles H Hanson
DmH.

CS 301

INSPECTION COPY

NOTES

12/1/63 - ~~Paused & checked~~
 2/15/64 - ~~Hanson in to~~
~~annual plan &~~
~~substituted annual~~
~~business in case of~~
~~Company Const. E. S. S.~~
 4/1/64 - ~~Left G.T. to~~
~~check in. E.S.S.~~
 5/21/64 - Cert. to be
 issued - ~~EF~~

~~X~~

1744 ~~24~~ 4114
 110 ~~10~~ 244
 Permit No. 63/1526
 Location: 1st to 19th Street, Bldg. A
 Owner: ~~Alison R. Brown~~
 Date of permit: 11/27/63
 Notif. closing-in: 11/1/64
 Inspn. closing-in: 4/1/64
 Final Notif.: 4/1/64
 Final Inspn.:
 Cert. of Occupancy issued: 5/21/60 H.C.M.
 Staking Out Notice
 Form Check Notice

For D

11/17

BOUNDARY LINE

65'

OWNER
WILLIAM C. AND SUZANNE E. GOKEY

NEW DECK PLAN


28 SKYLARK ROAD
PORTLAND MAINE

APPROX. COST
\$ 6,000.00

BOUNDARY LINE

BOUNDARY LINE


143'



28 SKYLARK ROAD
PORTLAND MAINE

PLOT PLAN

*Site nothing yet.
Site plan some pieces in OK
4/9. Completed OK*



FEES (Breakdown or From Front)

Base Fee \$ _____
Subdivision Fee \$ _____
Site Plan Review Fee \$ _____
Other Fees \$ _____
(Explain) _____
Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS

Signature of Applicant *M. D. [unclear] [unclear]*

Date _____

PERMIT # 000513 CITY OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT# _____

Fill in any part which applies to job. Proper plans must accompany form.

Owner William C. and Suzar Cokey
 Address 228 SkyLark Road Portland 972-6714

LOCATION OF CONSTRUCTION 228 SkyLark Road

Contractor Owner SUBCONTRACTORS: _____

ADDRESS: _____

Est. Construction Cost: 1,000 Type of Use: Single family

Part Use: _____

Building Dimensions: 12' x 18' Sq. Ft. _____ Stories _____ Lot Size _____

Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____

Conversion: Explain Construct 12' x 18' deck

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: _____
 # of Dwelling Units: _____ # of Non-Dwelling Units: _____

Foundation: _____

1. Type of Soil: _____
2. Set Backs: Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other: 3" cement sonotubes

Floor: _____

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: 2 x 4 PRESSURE TREATED Spacing 16" O.C.
5. Bridging Type: 2" x 6 PRESSURE TREATED Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: 3" railing 2 x 4, and 1 x 4

Exterior Walls: _____

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls: _____

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

For Official Use Only

Date: 5/11/86 Subdivision: Yes / No _____

Issued For: License Name _____

Block Code: _____ Block _____

Time Limit: _____ Permit Expiration _____

Estimated Cost: 1,000 Ownership: _____ Public _____ Private _____

Value of Structure: _____

Fee: 23

PERMIT ISSUED

- Callings:
1. Ceiling Joists Size: _____
 2. Ceiling Strapping Size _____ Spacing _____
 3. Type Ceiling: _____
 4. Insulation Type _____ Size _____
 5. Ceiling Height: _____

- Roof:
1. Truss or Rafter Size _____ Spar _____
 2. Sheathing Type _____ Size _____
 3. Roo. Covering Type _____
 4. Other: _____

Chimneys: _____

Heating: _____

Electric: _____

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing: _____

1. Approval of soil test, if required: Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools: _____

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Zoning: _____

District: R-3 Street Frontage Req: _____

Required Setbacks: Front _____ Back _____ Side _____

Review Required: _____

Zoning Board Approval: Yes _____ No _____ Date: _____

Planning Board Approval: Yes _____ No _____ Date: _____

Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____

Shore and Floodplain Mgmt: _____ Special Exception _____

Other: (Explain) _____

Date Approved: OK by Stationary Bay 5/11/86

Permit Received By: LYNN **PERMIT ISSUED**

Signature of Applicant: WILLIAM COKEY Date: 5/11/86

Signature of CEO: William C. Cokey Date: _____

Inspection Dates: _____

LYNN TAYLOR

In buildings of Use Groups R-1 and R-2 which have basements, an additional smoke detector shall be installed in the basement. In buildings of Use Group R-3, smoke detectors shall be required on every story of the dwelling unit, including basements.

In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level provided the lower level is less than one full story below the upper level. If there is an intervening door between the adjacent levels, a smoke detector shall be installed on both levels.


All detectors shall be installed in an approved location. Where more than one detector is required to be installed within an individual dwelling unit, the detectors shall be wired in such a manner that the actuation of one alarm will actuate all the alarms in the individual unit.

- 6.) Private garages located beneath rooms in buildings of Use Groups R-1, R-2, R-3 or I-1 shall have walls, partitions, floors and ceilings separating the garage space from the adjacent interior spaces constructed of not less than 1-hour fire-resistance rating. Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by means of 1/2-inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and adjacent interior spaces shall be raised not less than 4 inches (102 mm) above the garage floor. The door opening protectives shall be 1 3/4-inch solid core wood doors or approved equivalent.

X 7.) A guardrail system located near the open side of deck or elevated walking surfaces shall be constructed. Guards in buildings of Use Group R-3 shall be not less than 36 inches in height. Open guards shall have intermediate rails, balusters or other construction such that a sphere with a diameter of 6 inches cannot pass through any opening.

- 3.) Section 25-135 of the Municipal Code for the City of Portland states: "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year."

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services

/ks-
11/9/87

BUILDING PERMIT REPORT

DATE: 12/11/1988

ADDRESS: 28 S. Kuyback Bldg.

REASON FOR PERMIT: 12' x 18' deck

BUILDING OWNER: Gokey

CONTRACTOR: 11

PERMIT APPLICANT: CC

APPROVED: [Signature] DENIED

CONDITION OF APPROVAL OR DENIAL:

- 1.) All vertical openings shall be enclosed with construction having a fire rating of at least one(1) hour, including fire doors with self-closers.
- 2.) Each apartment shall have access to two(2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 3.) The boiler shall be protected by enclosing with one(1) hour fire rated construction including fire doors and ceiling, or by placing over the boiler, two(2) residential sprinkler heads supplied from the domestic water.
- 4.) Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118 mm) above the floor. All egress or rescue windows from sleeping rooms must have minimum net clear openings of 5.7 square feet (0.53m²). The minimum net clear opening height dimension shall be 24 inches (610 mm). The minimum net clear opening width dimension shall be 20 inches (508 mm).
- 5.) In addition to any automatic fire alarm system required by Sections 1016.3.5, a minimum of one single station smoke detector shall be installed in each guest room, suite or sleeping area in buildings of Use Groups R-1 and I-1 and in dwelling units in the immediate vicinity of the bedrooms in buildings of Use Group R-2 or R-3. When actuated, the detector shall provide an alarm suitable to warn the occupants within the individual unit (see Section 1717.3.1).



CITY OF PORTLAND, MAINE

399 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

May 12, 1988

RE: 28 Skylark Road

Mr William C. Gokey
28 Skylark Road
Portland, Maine 04103


Dear Sir:

Your application to construct a 12' X 18' deck has been reviewed and a permit is herewith issued subject to the following requirements:

1. All lot lines shall be clearly marked before calling for a foundation inspection.
2. 8" sono tubes are required 4' below grade.
3. Please read and implement item #7 of the attached building permit report.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses
Chief of Inspection Services

/el