


Applicant: Edward Stalle 69 Morning Street 04101  
Date: June 14, 1987 773-1039  
Address: Lot #13, Daring Run Drive  
Assessors No.:

Daring Run Subdivision  
Phase I

CHECK-LIST AGAINST ZONING ORDINANCE

Date -  
Zone Location - R-2 Residence  
Interior or corner lot - Interior  
Use - Single Family w/attached garage (2 car)  
Sewage Disposal - City  
Rear Yards - 70' 25' required  
Side Yards - 8' and 14' (5' and 14')  
Front Yards - 25' 25' required  
Projections -  
Height - 2 story  
Lot Area - ~~34,523.2 sq ft.~~ 11,808 sq ft.  
Building Area - 3,012 sq ft.  
Area per Family - 10,000 sq ft.  
Width of Lot - 90'  
Lot Frontage - 89.99'  
Off-street Parking - O.K.  
Loading Bays -  
Site Plan -  
Shoreland Zoning -  
Flood Plains -

This is a recent  
new subdivision  
off Washington Ave  
(south side) beyond contemitted  
Drive. Astorner



DEERING RUN DRIVE

# PLOT PLAN

OF PROPOSED RESIDENTIAL  
DWELLING ON DEERING RUN  
ROAD PORTLAND, MAINE

SCALE :

**LEGEND**  
LOT LINE      - - - - -  
CURB            = = = = =

set back side yard  
see section 14-432



# APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1  
Portland, Maine, July 9, 1987

PERMIT ISSUED

JUL 10 1987

City Of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. .... pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Lot 13 Deering Run Drive Within Fire Limits? ..... Dist. No. ....  
 Owner's name and address Edward Galli - 69 Morning Street Telephone 773-1838  
 Lessee's name and address ..... Telephone .....  
 Contractor's name and address OWNER Telephone .....  
 Architect ..... Plans filed ..... No. of sheets .....  
 Proposed use of building single family dwelling No. families .....  
 Last use vacant No. families .....  
 Increased cost of work none Additional fee .....

### Description of Proposed Work

flip the plan over they are swapping the garage and the house positions with same setbacks everything else is the same

### Details of New Work

Is any plumbing involved in this work? ..... Is any electrical work involved in this work? .....  
 Height average grade to top of plate ..... Height average grade to highest point of roof .....  
 Size, front ..... depth ..... No. stories ..... solid or filled land? ..... earth or rock? .....  
 Material of foundation ..... Thickness, top ..... bottom ..... cellar .....  
 Material of underpinning ..... Height ..... Thickness .....  
 Kind of roof ..... Rise per foot ..... Roof covering .....  
 No. of chimneys ..... Material of chimneys ..... of lining .....  
 Framing lumber—Kind ..... Dressed or full size? .....  
 Corner posts ..... Sills ..... Girt or ledger board? ..... Size .....  
 Columns ..... Size ..... Columns under girders ..... Size ..... Max. on centers .....  
 Joists (outside walls and carrying partitions) 2x4-18" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor....., 2nd....., 3rd....., roof .....  
 Joists on centers: 1st floor....., 2nd....., 3rd....., roof .....  
 Maximum span: 1st floor....., 2nd....., 3rd....., roof .....

Signature of Owner Edward Galli  
 Approved: [Signature] Inspector of Buildings

2 O.K. W.D. Turner July 9, 1987

OWNER'S COPY  
 (4) K. Taylor

INSPECTOR'S COPY

\*6.) In addition to any automatic fire alarm system required by Sections 1716.3.2 and 1716.3.3, a minimum of one single station smoke detector shall be installed in each guest room, suite or sleeping area in buildings of Use Groups R-1 and I-1, and in dwelling units in the immediate vicinity of the bedrooms in buildings of Use Group R-2 or R-3. When actuated, the detector shall provide an alarm suitable to warn the occupants within the individual unit (see Section 1717.3.1).


In buildings of Use Groups R-1 and R-2 which have basements, an additional smoke detector shall be installed in the basement. In buildings of Use Group R-3, smoke detectors shall be required on every story of the dwelling unit, including basements.

In dwelling units with split levels, a smoke detector installed on the upper level shall suffice for the adjacent lower level provided the lower level is less than one full story below the upper level. If there is an intervening door between the adjacent levels, a smoke detector shall be installed on both levels.

All detectors shall be installed in an approved location. Where more than one detector is required to be installed within an individual dwelling unit, the detectors shall be wired in such a manner that the actuation of one alarm will actuate all the alarms in the individual unit.

\*7- 608.1 Attached garages: Private garages located beneath rooms in buildings of Use Groups R-1, R-2, R-3 or I-1 shall have walls, partitions, floors, and ceilings separating the garage space from the adjacent interior spaces constructed of not less than 1 hour fire-resistance rating. Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by means of ½-inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and adjacent interior spaces shall be raised not less than 4 inches (102mm) above the garage floor. The door opening protectives shall be 1 3/4-inch solid core wood doors or approved equivalent.

608.1.1 Separation by breezeway: A garage separated by a breezeway not less than 10 feet (3048mm) in length from a building of Use Group R-3 may be of type 5B construction, but the junction of the garage and breezeway shall be firestopped to comply with the requirements of Section 1420.0.



BUILDING PERMIT REPORT

DATE: 16 June 1987  
ADDRESS: Lot # 13 Dorring Run  
REASON FOR PERMIT: Single Family dwelling with  
2 car garage  
BUILDING OWNER: Edward Galli  
CONTRACTOR: owner  
PERMIT APPLICANT: 1  
APPROVED: 5 June 87 ~~DENIED~~

CONDITION OF APPROVAL OR DENIAL:

- 1.) All vertical openings shall be enclosed with construction having a fire rating of at least one(1) hour, including fire doors with self-closers.
- 2.) Each apartment shall have access to two(2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 3.) Each apartment shall be equipped with an approved single station smoke detector powered by the house current. The detector shall be located in an area which will provide protection for the sleeping areas.
- 4.) The boiler shall be protected by enclosing with one(1) hour fire rated construction including fire doors and ceiling, or by placing over the boiler, two(2) residential sprinkler heads supplied from the domestic water.
- \*5.) Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118 mm) above the floor. All egress or rescue windows from sleeping rooms must have minimum net clear openings of 5.7 square feet (0.53m<sup>2</sup>). The minimum net clear opening height dimension shall be 24 inches (610 mm). The minimum net clear opening width dimension shall be 20 inches (508 mm).



## CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

June 15, 1987

Mr. Edward Galli  
69 Morning Street  
Portland, Maine 04101

Re: Lot #13 Deering Run

Dear Sir:

Your application to construct a single family dwelling with a 2-car garage has been reviewed and a building permit is herewith issued subject to the following requirements:

1. All lot lines and the lot shall be clearly marked before calling for a foundation inspection.
2. Please read and implement items 5, 6, and 7 of the attached worksheet.
3. Your roof truss systems must be designed for a 50 PSF live load.

If you have any questions on these requirements, please call this office.

Sincerely,

P. Samuel Hoffer  
Chief of Inspection Services

PSH/jmr

Enclosure

PERMIT # \_\_\_\_\_ **PORTLAND BUILDING PERMIT APPLICATION** DATE 5/10/87 **PERMIT ISSUED**

**I. GENERAL INFORMATION**

Location/address of construction: Deering Run Lot #13  
 1. Owner's name Edward Galli Tel. 773-1838  
 Address 69 Morning Street 04101  
 2. Lessee's name \_\_\_\_\_ Tel. \_\_\_\_\_  
 Address \_\_\_\_\_  
 3. Contractor's name Sama Tel. ##685  
 Address \_\_\_\_\_  
 4. Is this a legally recorded lot? yes  no \_\_\_\_\_

JUN 16 1987  
**City Of Portland**

**II. DESCRIPTION OF WORK:**

to construct single family 68 x 33 dwelling with attached 2 car garage as per plan

**III. BUILDING DIMENSIONS:** length 68 width 33 square footage 2244 height \_\_\_\_\_ #stories 2

**IV. ZONE** \_\_\_\_\_ Street frontage \_\_\_\_\_ Zoning board approval: no  yes  date \_\_\_\_\_  
 Setbacks: front \_\_\_\_\_ back \_\_\_\_\_ side \_\_\_\_\_ side \_\_\_\_\_ Planning board approval: no  yes  date \_\_\_\_\_

**V. REVIEW REQUIRED:** variance \_\_\_\_\_ other \_\_\_\_\_ Number of off-street parking spaces:  
 site plan \_\_\_\_\_ subdivision \_\_\_\_\_ shore \_\_\_\_\_ floodplain mgmt \_\_\_\_\_ enclosed \_\_\_\_\_ outdoors \_\_\_\_\_

**VI. FEES:**  
 base fee \_\_\_\_\_ other fees \_\_\_\_\_  
 subdivision fee \_\_\_\_\_ late fee \_\_\_\_\_  
 site plan review fee \_\_\_\_\_ **TOTAL \$245.00**

**VII. DETAILS OF WORK**

1. WATER SUPPLY: <input checked="" type="checkbox"/> public <input type="checkbox"/> private	7. ELECTRICAL: service entrance size _____ # smoke detectors _____	8. CHIMNEY: # flues _____ material _____ # fireplaces _____
2. SEWER: <input checked="" type="checkbox"/> public <input type="checkbox"/> private, type _____	9. FRAMING: floor joists _____ size _____ max. on center _____ ceiling joists _____ rafters _____ studs _____ wall studs _____	
3. HEAT: type _____ fuel _____	10. If 1-story building w/masonry walls: wall thickness _____ height _____	11. BEDROOM WINDOWS height _____ width _____ sill height _____ egress window? yes <input type="checkbox"/> no <input type="checkbox"/>
4. FOUNDATION: type _____ thickness _____ footing _____		
5. ROOF: type _____ pitch _____ covering _____ load _____		
6. PLUMBING: SPRINKLER SYSTEM? yes <input type="checkbox"/> no <input type="checkbox"/>		

<b>VIII. OFFICE USE:</b> TAX MAP # _____ LOT # _____ VALUE/STRUCTURE _____ PERMIT EXPIRATION _____	<b>IX. NEW OR PHASED SUBDIVISION REFERENCE:</b> Name _____ Lot _____ Block _____
--	---

CODE \_\_\_\_\_ if other, explain \_\_\_\_\_ Seasonal \_\_\_\_\_ Condominium \_\_\_\_\_ Apartment \_\_\_\_\_  
 X. PROPOSED USE: 101 - single  
 XI. PAST USE: 114 - vacant  
 XII. OWNERSHIP: \_\_\_\_\_ PUBLIC \_\_\_\_\_ PRIVATE \_\_\_\_\_

XIII. EST. CONSTRUCTION COST: \$8,000 XIV. GR. SQ. FT. OF LOT \_\_\_\_\_  
 BUILDING \_\_\_\_\_

**COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE**

<b>XV. RESIDENTIAL BUILDINGS ONLY:</b> # NEW DWELLING UNITS WITH: _____ # EXISTING DWELLING UNITS WITH: _____	<b>BEDROOMS</b> 1 BDRM _____ 2 BDRMS _____ 3 BDRMS _____	<b>XVI. # RESIDENTIAL UNITS:</b> # NEW DWELLINGS _____ # EXISTING DWELLINGS _____ TOTAL RESIDENTIAL UNITS _____
---	---	--

<b>APPROVALS BY:</b> _____ DATE _____ BUILDING INSPECTION - PLAN EXAMINER _____ ZONING: _____ C.E.O. _____ FIRE DEPT. _____	<b>MISCELLANEOUS</b> Will work require disturbing of any tree on a public street? _____ Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? _____
---	---

**NOTE TO APPLICANT:** Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanicals.

District No. <u>4</u>	XVII SIGNATURE OF APPLICANT <u>Edward Galli</u> PHONE # _____ TYPE NAME OF ABOVE <u>Edward Galli</u>
-----------------------	--

**PLUMBING APPLICATION**

**PROPERTY OWNERS NAME:** #13 Terra Bay  
Portland  
Street  
Subdivision Lot #

**Applicant:** Gaill, Anthony  
First: Anthony

**Name:** Gerber, L. Lynn  
Mailing Address of Owner/Applicant: 7 Anderson Street  
Portland, ME 04101  
(if Different)

**Owner/Applicant Statement**  
I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.  
*L. Lynn Gerber* 5-19-88  
Date

Signature of Owner/Applicant  
Date

**PERMIT INFORMATION**

**Local Plumbing Inspector Signature**  
*Jan 6 - 1988*  
Date Approved

PERMIT # 2575  
PORTLAND  
19-0587  
L.P.I.# 301  
FEE \$301

**Local Plumbing Inspector Signature**  
*Jan 6 - 1988*

**Caution: Inspection Required**  
I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

This Application is for:

1.  NEW PLUMBING  
2.  RELOCATED PLUMBING  
SEP 25 1987

Type Of Structure To Be Served:

1.  SINGLE FAMILY DWELLING  
2.  MODULAR OR MOBILE HOME  
3.  MULTIPLE FAMILY DWELLING  
4.  OTHER - SPECIFY: \_\_\_\_\_

Plumbing To Be Installed By:

1.  MASTER PLUMBER  
2.  OIL BURNERMAN  
3.  MFG.D. HOUSING DEALER/MECHANIC  
4.  PUBLIC UTILITY EMPLOYEE  
5.  PROPERTY OWNER

LICENSE # 00072

Number	Hook-Ups And Piping Relocation	Number	Type of Fixture	Column 2	Number	Type of Fixture	Column 1
	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.	2	Hosebib / Sillcock		1	Bathtub (and Shower)	Column 1
	HOOK-UP: to an existing subsurface waste water disposal system.		Indirect Waste		2	Water Closet (Toilet)	Number
	PIPING RELOCATION: of sanitary lines, drains, and piping will not new fixtures.		Water Treatment Softener, Filter, etc.		1	Clothes Washer	Type of Fixture
			Grease/Oil Separator		1	Dish Washer	
			Dental Cuspldor		1	Garbage Disposal	
			Bidet			Laundry Tub	
			Other: _____		1	Water Heater	
\$	Hook-Ups (Subtotal)				9	Fixtures (Subtotal)	Column 2
	Hook-Up Fee					Fixtures (Subtotal)	Column 1
					2	Fixtures (Subtotal)	Column 2
						Fixtures (Subtotal)	Column 1
						Total Fixtures	
						Fixtures	
						Hook-Up Fee	
						Permit Fee	
						Total Fee	

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE

TOWN COPY





# APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1

Portland, Maine, July 9, 1907

**PERMIT ISSUED**

JUL 10 1907

**City Of Portland**

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. .... pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Lot 13 Deering Run Drive Within Fire Limits? ..... Dist. No. ....  
 Owner's name and address Edward Galli - 59 Morning Street Telephone 773-1838  
 Lessee's name and address ..... Telephone .....  
 Contractor's name and address CONOR Telephone .....  
 Architect ..... Plans filed ..... No. of sheets .....  
 Proposed use of building single family dwelling No. families .....  
 Last use vacant No. families .....  
 Increased cost of work none Additional fee .....

### Description of Proposed Work

flip the plan over they are swapping the garage and the house positions with same setbacks everything else is the same

### Details of New Work

Is any plumbing involved in this work? ..... Is any electrical work involved in this work? .....  
 Height average grade to top of plate ..... Height average grade to highest point of roof .....  
 Size, front ..... depth ..... No. stories ..... solid or filled land? ..... earth or rock? .....  
 Material of foundation ..... Thickness, top ..... bottom ..... cellar .....  
 Material of underpinning ..... Height ..... Thickness .....  
 Kind of roof ..... Rise per foot ..... Roof covering .....  
 No. of chimneys ..... Material of chimneys ..... of lining .....  
 Framing lumber—Kind ..... Dressed or full size? .....  
 Corner posts ..... Sills ..... Girt or ledger board? ..... Size .....  
 Girders ..... Size ..... Columns under girders ..... Size ..... Max. on centers .....  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
 Joists and rafters: 1st floor....., 2nd....., 3rd....., roof.....  
 On centers: 1st floor....., 2nd....., 3rd....., roof.....  
 Maximum span: 1st floor ....., 2nd ....., 3rd....., roof.....

Approved:

Signature of Owner *[Signature]*

Approved: .....

Inspector of Buildings

INSPECTION COPY

FILE COPY

APPLICANT'S COPY

ASSESSOR'S COPY

Taylor



CITY OF PORTLAND, MAINE  
Department of Building Inspection

## Certificate of Occupancy

LOCATION *Lot 13 Deering Run*

Issued to *Edward Galli*

Date of Issue *February 19, 1938*

*This is to certify* that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. *87-865*, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

*entire*

APPROVED OCCUPANCY

*single family dwelling with  
attached garage*

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

*W. H. Taylor*  
(Date) *Inspector*

*[Signature]*  
*Inspector of Buildings*

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND, MAINE  
Department of Building Inspection

## Certificate of Occupancy

LOCATION *Lot 13 Dearing Run*

Issued to *Edward Galli*

Date of Issue *February 19, 1988*

**This is to certify** that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. *87-685*, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

*entire*

APPROVED OCCUPANCY

*single family dwelling with  
attached garage*

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

*Alfred K. Taylor*  
.....  
(Date) Inspector

*[Signature]*  
.....  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

B

**PERMIT** **PORTLAND BUILDING PERMIT APPLICATION** DATE 6/13/87 **PERMIT ISSUED**  
**JUN 16 1987**  
**City Of Portland**

**I. GENERAL INFORMATION**  
 Location/address of construction Deering Run Lot #13  
 1. Owner's name Edward Halli Tel. 722-1838  
 Address 69 Morchins Street 04101  
 2. Lessee's name \_\_\_\_\_ Tel. \_\_\_\_\_  
 Address \_\_\_\_\_ Tel. \_\_\_\_\_  
 3. Contractor's name Sims Tel. #685  
 Address \_\_\_\_\_ Tel. \_\_\_\_\_

4. Is this a legally recorded lot? yes  no   
**II. DESCRIPTION OF WORK:**  
to construct single family 58 x 37 dwelling with attached 2 car garage as per plans

**III. BUILDING DIMENSIONS:** length 38 width 37 square footage 1406 height \_\_\_\_\_ #stories 2  
**IV. ZONE** \_\_\_\_\_ Street frontage \_\_\_\_\_ Zoning board approval: no  yes  date \_\_\_\_\_  
 Setbacks: front \_\_\_\_\_ back \_\_\_\_\_ side \_\_\_\_\_ side \_\_\_\_\_ Planning board approval: no  yes  date \_\_\_\_\_  
**V. REVIEW REQUIRED:** variance \_\_\_\_\_ other \_\_\_\_\_  
 site plan \_\_\_\_\_ subdivision \_\_\_\_\_ shore \_\_\_\_\_ floodplain mgmt \_\_\_\_\_  
**VI. FEES:** Number of off-street parking spaces: \_\_\_\_\_ enclosed \_\_\_\_\_ outdoors \_\_\_\_\_  
 base fee \_\_\_\_\_ other fees \_\_\_\_\_  
 subdivision fee \_\_\_\_\_ late fee \_\_\_\_\_  
 site plan review fee \_\_\_\_\_ TOTAL \$245.00

**VII. DETAILS OF WORK**

1. WATER SUPPLY: <input checked="" type="checkbox"/> public <input type="checkbox"/> private	7. ELECTRICAL: service entrance size _____ # smoke detectors _____	8. CHIMNEY: # flues _____ material _____ # fireplaces _____
2. SEWER: <input checked="" type="checkbox"/> public <input type="checkbox"/> private, type _____	9. FRAMING: floor joists _____ size _____ rafters _____ m.c.t. on center _____ ceiling joists _____ studs _____ wall studs _____	11. BEDROOM WINDOWS: height _____ width _____ sill height _____ egress window? yes <input type="checkbox"/> no <input type="checkbox"/>
3. HEAT: type _____ fuel _____	10. If 1-story building w/masonry walls: wall thickness _____ height _____	
4. FOUNDATION: type _____ thickness _____ footing _____		
5. ROOF: type _____ pitch _____ covering _____ load _____		
6. PLUMBING: SPRINKLER SYSTEM? yes <input type="checkbox"/> no <input type="checkbox"/>		

**VIII. OFFICE USE:** TAX MAP # \_\_\_\_\_ LOT # \_\_\_\_\_ VALUE/STRUCTURE \_\_\_\_\_ PERMIT EXPIRATION \_\_\_\_\_  
**IX. NEW OR PHASED SUBDIVISION REFERENCE:** Name \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_

**X. PROPOSED USE:** 1-1 SINGLE FAMILY Seasonal \_\_\_\_\_ Condominium \_\_\_\_\_ Apartment \_\_\_\_\_  
**XI. PAST USE:** \_\_\_\_\_  
**XII. OWNERSHIP:** PUBLIC  PRIVATE \_\_\_\_\_

**XIII. EST. CONSTRUCTION COST:** 15,000 **XIV. GR. SQ. FT. OF LOT BUILDING:** \_\_\_\_\_

**XV. RESIDENTIAL BUILDINGS ONLY:** COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE

# NEW DWELLING UNITS WITH: 1: BDRM. _____ 2: BDRMS. _____ 3: BDRMS. _____	<b>XVI. RESIDENTIAL UNITS:</b> # NEW DWELLINGS _____ # EXISTING DWELLINGS _____ TOTAL RESIDENTIAL UNITS _____
--	--

**APPROVALS BY:** DATE \_\_\_\_\_  
 BUILDING INSPECTION - PLAN EXAMINER \_\_\_\_\_  
 ZONING: \_\_\_\_\_  
 C.E.O. \_\_\_\_\_  
 FIRE DEPT. \_\_\_\_\_

**MISCELLANEOUS**  
 Will work require disturbing of any tree on a public street? \_\_\_\_\_  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? \_\_\_\_\_

**NOTE TO APPLICANT:** Separate permits are required for the installers and subcontractors of heating, plumbing, electrical, and mechanic

District No. 4 **XVII. SIGNATURE OF APPLICANT:** \_\_\_\_\_ **PHONE #** \_\_\_\_\_  
 TYPE NAME OF ABOVE \_\_\_\_\_



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date August 17, 19 87  
 Receipt and Permit number 22229

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Lot #13 Deering Run Drive

OWNER'S NAME: Edward Galli ADDRESS: Eastern Prom., Portland

OUTLETS: FEES

Receptacles X Switches X Plugmold \_\_\_\_\_ ft. TOTAL 80 ..... 7.00

FIXTURES: (number of)

Incandescent x Fluorescent \_\_\_\_\_ (not strip) TOTAL 20 ..... 5.00

Strip Fluorescent \_\_\_\_\_ ft. ....

SERVICES: 60 - Temp.

Overhead \_\_\_\_\_ Underground X Temporary X TOTAL amperes 200 .. 5.00

METERS: (number of) 1 ..... 50

MOTORS: (number of)

Fractional \_\_\_\_\_

1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING:

Oil or Gas (number of units) \_\_\_\_\_

Electric (number of rooms) \_\_\_\_\_

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler) \_\_\_\_\_

Oil or Gas (by separate units) \_\_\_\_\_

Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

APPLIANCES: (number of)

Ranges \_\_\_\_\_ 1 \_\_\_\_\_ Water Heaters \_\_\_\_\_

Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_ 1 \_\_\_\_\_

Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_ 1 \_\_\_\_\_

Dryers \_\_\_\_\_ 1 \_\_\_\_\_ Compactors \_\_\_\_\_

Fans \_\_\_\_\_ 2 \_\_\_\_\_ Others (denote) \_\_\_\_\_

TOTAL 6 ..... 9.00

MISCELLANEOUS: (number of)

Branch Panels \_\_\_\_\_

Transformers \_\_\_\_\_

Air Conditioners Central Unit \_\_\_\_\_

Separate Units (windows) \_\_\_\_\_

Signs 20 sq. ft. and under \_\_\_\_\_

Over 20 sq. ft. \_\_\_\_\_

Swimming Pools Above Ground \_\_\_\_\_

In Ground \_\_\_\_\_

Fire/Burglar Alarms Residential \_\_\_\_\_

Commercial \_\_\_\_\_

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_

over 30 amps \_\_\_\_\_

Circus, Fairs, etc. \_\_\_\_\_

Alterations to wires \_\_\_\_\_

Repairs after fire \_\_\_\_\_

Emergency Lights, battery \_\_\_\_\_

Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE:

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE:

FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....

TOTAL AMOUNT DUE:

27.50

INSPECTION:

Temp.  
 AUGUST 17 - READY

Will be ready on Aug. 17, 1987; or Will Call \_\_\_\_\_

CONTRACTOR'S NAME: Tim Napolitano

ADDRESS: 51 Lawrence Lane St., S. P. 04106

TEL.: 799-0538

MASTER LICENSE NO.: 7765

LIMITED LICENSE NO.: \_\_\_\_\_

SIGNATURE OF CONTRACTOR:

Tim Napolitano

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

INSPECTIONS: *200 Amp* by *Reno*  
Service called in *8/20/87* by *Reno*  
Closing-in *9/16/87* by *Reno*

PROGRESS INSPECTIONS:  
\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_

Permit Number *22229*  
Location *707 #13 Conway*  
Owner *Edward Hald*  
Date of Permit *8/17/87*  
Final Inspection *9/17/87*  
By Inspector *D. J. Reno*  
Permit Application Register Page No. *7*

DATE:	REMARKS:
<i>8/20/87</i>	<i>Temporary service called in to C.M.P.</i>
<i>2/14/88</i>	<i>Final for C.O.S. - Bathroom G.F.C.I. Defective - Panel needs to be worked. G.F.C.I. protected receptacle needed in basement. Conduit outside of meter needs to be secured to the building frame.</i>

CODE  
COMPLETED  
COMPLETED  
DATE *2/22/88*