



# CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

August 2, 1984

Debra D. Cavallaro  
97 Brook Rd.,  
Portland, Me.

Dear Ms. Cavallaro,

Your application to construct a 22' X 24' attached garage has been reviewed and a building permit is herewith issued subject to the following requirement.

613.1 Dwellings: Private garages located beneath dwellings shall have walls, partitions, floors and ceilings separating the garage space from the dwellings constructed of not less than one hour fireresistance rating. Private garages attached to dwellings shall be completely separated from the dwellings and their attic area by means of one half inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and dwellings shall be raised not less than 4 inches (102mm) above the garage floor. The door opening protectives shall be 1 3/4 inch solid core doors or approved equivalent.

If you have any question on this requirement please call this office.

Sincerely,

P. Samuel Hoffes  
Chief of Insp. Services

APPLICATION FOR PERMIT

PERMIT ISSUED  
AUG 2 1984  
CITY of PORTLAND

B.O.C.A. USE GROUP .....  
B.O.C.A. TYPE OF CONSTRUCTION ..... 927  
ZONING LOCATION ..... PORTLAND, MAINE Aug. 1, 1984

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE.  
The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION ..... 97 Brook Road  
1. Owner's name and address ..... Debra D. Cavallaro - 97 Brook Road ..... Fire District #1  #2   
2. Lessee's name and address ..... Telephone 797-3973  
2. Contractor's name and address ..... John Donstella - 69 Platt St., Portland 04103 ..... Telephone 772-7568  
Proposed use of building ..... Attached 1-car garage ..... No. of sheets ..... 1  
Last use ..... No. families ..... 1  
Material ..... No. stories ..... Heat ..... Style of f ..... Roofing .....  
Other buildings on same lot .....  
Estimated contractual cost \$ ..... 3,000.00

FIELD INSPECTOR--Mr. ....  
@ 775-5451  
Appeal Fees \$ .....  
Base Fee .....  
Late Fee .....  
TOTAL \$ ..... 25.00

To construct 1-car attached garage on right side of existing single fam. dwelling, 22' x 24', as per plan.

ISSUE PERMIT TO \$1 Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals

DETAILS OF NEW WORK

Is any plumbing involved in this work? ..... Is any electrical work involved in this work? ..... yes  
Is connection to be made to public sewer? ..... If not, what is proposed for sewage? .....  
Has septic tank notice been sent? ..... Form notice sent? .....  
Height average grade to top of plate ..... Height average grade to highest point of roof .....  
Size, front ..... depth ..... No. stories ..... solid or filled land? ..... earth or rock? .....  
Material of foundation ..... Thickness, top ..... bottom ..... cellar .....  
Kind of roof ..... Rise per foot ..... Roof covering .....  
No. of chimneys ..... Material of chimneys ..... of lining ..... Kind of heat ..... fuel .....  
Framing Lumber--Kind ..... Dressed or full size? ..... Corner posts ..... Sills .....  
Size Girder ..... Columns under girders ..... Size ..... Max. on centers .....  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor ..... 2nd ..... 3rd ..... roof .....  
On centers: 1st floor ..... 2nd ..... 3rd ..... roof .....  
Maximum span: 1st floor ..... 2nd ..... 3rd ..... roof .....  
If one story building with masonry walls, thickness of walls? ..... height? .....

IF A GARAGE

No. cars now accommodated on same lot ..... to be accommodated ..... number commercial cars to be accommodated .....  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? .....

APPROVALS BY: ..... DATE ..... MISCELLANEOUS  
BUILDING INSPECTION--PLAN EXAMINER ..... Will work require disturbing of any tree on a public street? no.  
ZONING: .....  
BUILDING CODE: ..... Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes.  
Fire Dept.: .....  
Health Dept.: .....  
Others: .....

Signature of Applicant ..... Phone # .....  
Type Name of above ..... Louis Cavallara .....  
Other .....  
and Address .....

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



## CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

August 2, 1984

Debra D. Cavallaro  
97 Brook Rd.,  
Portland, Me.

Dear Ms. Cavallaro,

Your application to construct a 22' X 24' attached garage has been reviewed and a building permit is herewith issued subject to the following requirement.

613.1 Dwellings: Private garages located beneath dwellings shall have walls, partitions, floors and ceilings separating the garage space from the dwellings constructed of not less than one hour fire-resistance rating. Private garages attached to dwellings shall be completely separated from the dwellings and their attic area by means of one half inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and dwellings shall be raised not less than 4 inches (102mm) above the garage floor. The door opening protectives shall be 1 3/4 inch solid core wood doors or approved equivalent.

If you have any question on this requirement please call this office.

Sincerely,

P. Samuel Morris  
Chief of Insp. Services

APPLICATION FOR PERMIT

PERMIT ISSUED

AUG 2 1984

CITY of PORTLAND

B.O.C.A. USE GROUP ... 927
B.O.C.A. TYPE OF CONSTRUCTION ...
ZONING LOCATION ... PORTLAND, MAINE Aug. 1, 1984

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE.

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION ... 97 Brook Road ... Fire District #1 [ ] #2 [ ]
1. Owner's name and address Debra D. Cavallaro ... Telephone 797-3973
2. Lessee's name and address ... Telephone
3. Contractor's name and address John Donatella ... 69 Pitt St., Portland ... Telephone 772-7569
Proposed use of building ... Attached 1-car garage ... No. of sheets ... 3
Last use ... No. families ... 1
Material ... No. stories ... Heat ... Style of roof ... Roofing
Other buildings on same lot
Estimated contractual cost \$ 3,000.00

FIELD INSPECTOR—Mr. @ 775-5451
Appeal Fees \$
Base Fee
Late Fee
TOTAL \$ 25.60

To construct 1-car attached garage on right side of existing single fam. dwelling, 22' x 24', as per plan.

Stamp of Special Conditions

ISSUE PERMIT TO \$1

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work? yes
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flr roof span over 8 feet.
Joists and rafters 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

cars now accommodated on same lot to be accommodated number commercial to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? no.
ZONING: Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes.
BUILDING CODE:
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant ... Phone # ...
Type Name of above Debra D. Cavallara ... 2 [ ] 3 [ ] 4 [ ]

Other and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY



## CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

August 2, 1984

Debra D. Cavallaro  
97 Brook Rd.,  
Portland, Me.

Dear Ms. Cavallaro,

Your application to construct a 22' X 24' attached garage has been reviewed and a building permit is herewith issued subject to the following requirement.

613.1 Dwellings: Private garages located beneath dwellings shall have walls, partitions, floors and ceilings separating the garage space from the dwellings constructed of not less than one hour fire resistance rating. Private garages attached to dwellings shall be completely separated from the dwellings and their attic area by means of one half inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and dwellings shall be raised not less than 4 inches (102mm) above the garage floor. The door opening protectives shall be 1 3/4 inch solid core wood doors or approved equivalent.

If you have any question on this requirement please call this office.

Sincerely,

P. Samuel Hoffses  
Chief of Insp. Services



NOTES

*Edgell Law Shop*

Permit No. *84/937*

Location *97 3rd Street*

Owner *John Cavallaro*

Date of permit *8-1-84*

Approved *A. J. - TV*

Dwelling


Garage *1 car attached*

Alteration

*9/17/84 Progress Inspt*

*11/16/84 About completed  
Dry wall between garage  
& house not installed yet  
& some minor finish work  
No dry e. door in place  
as yet.*

*5/15/85 Completed*





**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date July 11, 19 79  
 Receipt and Permit number A 28832

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Lot # 16 Brook Road

OWNER'S NAME: Louis Cavallaro ADDRESS: 54 Olympia Street

FEE\$

**OUTLETS:**

Receptacles \_\_\_\_\_ Switches \_\_\_\_\_ Plugmold \_\_\_\_\_ ft. TOTAL \_\_\_\_\_

**FIXTURES: (number of)**

Incandescent \_\_\_\_\_ Fluorescent \_\_\_\_\_ (not strip) TOTAL \_\_\_\_\_

Strip Fluorescent \_\_\_\_\_ ft. \_\_\_\_\_

**SERVICES:**

Overhead \_\_\_\_\_ Underground \_\_\_\_\_ Temporary  TOTAL 100 3.00

METERS: (number of) 1 \_\_\_\_\_ .50

**MOTORS: (number of)**

Fractional \_\_\_\_\_

1 HP or over \_\_\_\_\_

**RESIDENTIAL HEATING:**

Oil or Gas (number of units) \_\_\_\_\_

Electric (number of rooms) \_\_\_\_\_

**COMMERCIAL OR INDUSTRIAL HEATING:**

Oil or Gas (by a main boiler) \_\_\_\_\_

Oil or Gas (by separate units) \_\_\_\_\_

Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

**APPLIANCES: (number of)**

Ranges \_\_\_\_\_ Water Heaters \_\_\_\_\_

Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_

Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_

Dryers \_\_\_\_\_ Compactors \_\_\_\_\_

Fans \_\_\_\_\_ Others (denote) \_\_\_\_\_

TOTAL \_\_\_\_\_

**MISCELLANEOUS: (number of)**

Branch Panels \_\_\_\_\_

Transformers \_\_\_\_\_

Air Conditioners Central Unit \_\_\_\_\_

Separate Units (windows) \_\_\_\_\_

Signs 20 sq. ft. and under \_\_\_\_\_

Over 20 sq. ft. \_\_\_\_\_

Swimming Pools Above Ground \_\_\_\_\_

In Ground \_\_\_\_\_

Fire/Burglar Alarms Residential \_\_\_\_\_

Commercial \_\_\_\_\_

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_

over 30 amps \_\_\_\_\_

Circus, Fairs, etc. \_\_\_\_\_

Alterations to wires \_\_\_\_\_

Repairs after fire \_\_\_\_\_

Emergency Lights, battery \_\_\_\_\_

Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE:

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE:

FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....

TOTAL AMOUNT DUE:

3.50

**INSPECTION:**

Will be ready on \_\_\_\_\_, 19\_\_; or Will Call

CONTRACTOR'S NAME: Corey Electric

ADDRESS: 184 Read St.

TEL.: 775-1380

MASTER LICENSE NO.: 3630

LIMITED LICENSE NO.: \_\_\_\_\_

SIGNATURE OF CONTRACTOR:  
*Stephen M. Corey*

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN







**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date Sept. 6, 19 79  
 Receipt and Permit number A 34731

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Lot # 16 Brook Road 772-1716  
 OWNER'S NAME: Louis Cavallaro ADDRESS: 54 Olympia St.

OUTLETS: Receptacles \_\_\_\_\_ Switches \_\_\_\_\_ Plugmold \_\_\_\_\_ ft. TOTAL 1-30 **FEES** 3.00

FIXTURES: (number of) Incandescent \_\_\_\_\_ Fluorescent \_\_\_\_\_ (not strip) TOTAL \_\_\_\_\_  
 Strip Fluorescent \_\_\_\_\_ ft. \_\_\_\_\_

SERVICES: Overhead \_\_\_\_\_ Underground  Temporary \_\_\_\_\_ TOTAL amperes 200 **FEES** 3.00

METERS: (number of) 1 \_\_\_\_\_ **FEES** .50

MOTORS: (number of) Fractional \_\_\_\_\_  
 1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING: Oil or Gas (number of units) \_\_\_\_\_  
 Electric (number of rooms) 5 **FEES** 5.00

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) \_\_\_\_\_  
 Oil or Gas (by separate units) \_\_\_\_\_  
 Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

APPLIANCES: (number of) Ranges \_\_\_\_\_  Water Heaters \_\_\_\_\_   
 Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_   
 Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_   
 Dryers \_\_\_\_\_  Compactors \_\_\_\_\_  
 Fans \_\_\_\_\_ Others (denote) \_\_\_\_\_  
 TOTAL \_\_\_\_\_ **FEES** 7.50

MISCELLANEOUS: (number of) Branch Panels \_\_\_\_\_  
 Transformers \_\_\_\_\_  
 Air Conditioners Central Unit \_\_\_\_\_  
 Separate Units (windows) \_\_\_\_\_  
 Signs 20 sq. ft. and under \_\_\_\_\_  
 Over 20 sq. ft. \_\_\_\_\_  
 Swimming Pools Above Ground \_\_\_\_\_  
 In Ground \_\_\_\_\_  
 Fire/Burglar Alarms Residential \_\_\_\_\_  
 Commercial \_\_\_\_\_  
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_  
 over 30 amps \_\_\_\_\_  
 Circus, Fairs, etc. \_\_\_\_\_  
 Alterations to wires \_\_\_\_\_  
 Repairs after fire \_\_\_\_\_  
 Emergency Lights, battery \_\_\_\_\_  
 Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE: \_\_\_\_\_  
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE: \_\_\_\_\_  
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....  
 TOTAL AMOUNT DUE: 19.00

**INSPECTION:**

Will be ready on \_\_\_\_\_, 19 \_\_\_\_; or Will Call \_\_\_\_\_

CONTRACTOR'S NAME: C. Grey Electric

ADDRESS: 184 Read St.

TEL.: 775-1380

MASTER LICENSE NO.: 3630 SIGNATURE OF CONTRACTOR: \_\_\_\_\_

LIMITED LICENSE NO.: \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 34731

Location Lot 16 Brook Rd

Owner L. Casella

Date of Permit 9-6-79

Final Inspection 1-30-80

By Inspector Libby

Permit Application Register Page No. 35

INSPECTIONS: Service ✓ by Libby

Service called in 9-28-79

Closing-in 9-17-79 by Libby

PROGRESS INSPECTIONS: 9-7-79

12-3-79 NOT

1-8-80

1-30-80

CODE COMPLIANCE COMPLETED DATE 1-30-80

DATE	REMARKS:
9-7-79	What are going in for ceiling lites flushbacks? Paj must be removed from receptacle circuit 210-23(a) exception
	OK



CITY OF PORTLAND, MAINE  
Department of Building Inspection

## Certificate of Occupancy

LOCATION Lot # 16 Brook Road

Issued to Debra L. Donatello

Date of Issue Dec. 14, 1979

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 79/183, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Single Family Dwelling

Limiting Conditions:

This certificate supersedes  
certificate issued

Approved:

12/14/79 *H. P. King*  
(Date) Inspector

*Walter W. Hill*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

Applicant: *D. L. HOFFTRICK*

Date: *3/28/49*

Address: *93-97 CROOK PL.*

Assessors #: *376-C-12*

CHECK LIST AGAINST ZONING ORDINANCE

Date - *NEW*

Zone Location - *R-3*

Interior or ~~corner~~ lot -

~~40 ft. setback area (Section 21)-~~

Use - *25'x40' DWELLING*

Sewage Disposal - *PUBLIC*

Rear Yards - *25' ± - 25' MIN.*

Side Yards - *10' - 30' - 8' - 20' MIN.*

Front Yards - *25' - 25' MIN.*

Projections - *NONE*

Height - *TWO STORY - 35' MAX.*

Lot Area - *8,800 ± - 6,500 ± MIN.*

Building Area - *1,000 ± - 2,200 ± MAX.*

Area per Family - *8,800 ± - 6,500 ± MIN.*

Width of Lot - *80' - 65' MIN.*

Lot Frontage *80' - 50' MIN.*

Off-street Parking - *YES*

~~Loading bays -~~

~~Site Plan -~~

~~Shoreland Zoning -~~

~~Flood Plains -~~



# APPLICATION FOR PERMIT

**PERMIT ISSUED**

B.O.C.A. USE GROUP .....

B.O.C.A. TYPE OF CONSTRUCTION ..... 000183

MAR 28 1979

ZONING LOCATION R-3 PORTLAND, MAINE, March 28, 1979

**CITY of PORTLAND**

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION Lot # 16 Brook Road Fire District #1  #2

1. Owner's name and address Debra Louise Donatelle - 69 Pitt St. Telephone 772-7568

2. Lessee's name and address .....

3. Contractor's name and address Donatelle Bldrs. - 69 Pitt St. Telephone same

4. Architect .....

Proposed use of building dwelling Specifications .....

Last use .....

Material .....

Other buildings on same lot .....

Estimated contractual cost \$ 25,000 .....

Fee \$ 113.50 .....

FIELD INSPECTOR—Mr. .... GENERAL DESCRIPTION

This application is for: @ 775-5451

Dwelling xx 1 Ext. 234

Garage .....

Masonry Bldg. ....

Metal Bldg. ....

Alterations .....

Demolitions .....

Change of Use .....

Other .....

To construct single family dwelling, 40 x ~~24~~ 24 with no garage as per plans 3 sheets of plans.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1  2  3  4

Other: .....

### DETAILS OF NEW WORK

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes

Is connection to be made to public sewer? yes If not, what is proposed for sewage? .....

Has septic tank notice been sent? .....

Form notice sent? .....

Height average grade to top of plate 7 ft. 3 in. Height average grade to highest point of roof 18 ft.

Size, front 40 depth 24 No. stories 1 solid or filled land? solid earth or rock? earth

Material of foundation concrete Thickness, top 12 in. bottom 12 in. ancillary full

Kind of roof pitch Rise per foot .....

Roof covering asphalt shingles

No. of chimneys 1 Material of chimneys brick Kind of heat electrical

Framing Lumber—Kind pine Dressed or full size? .....

Corner posts 2 x 6 Sills 2 x 10

Size Girder spruce Columns under girders .....

Size .....

Max. on centers .....

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2 x 10, 2nd ....., 3rd ....., roof 2 x 6

On centers: 1st floor 16, 2nd ....., 3rd ....., roof trusses

Maximum span: 1st floor ....., 2nd ....., 3rd ....., roof .....

If one story building with masonry walls, thickness of walls? .....

height? .....

### IF A GARAGE

No. cars now accommodated on same lot ....., to be accommodated ... number commercial cars to be accommodated ...

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? .....

### APPROVALS BY:

BUILDING INSPECTION—PLAN EXAMINER .....

ZONING: O.R.M.C.O. 3/28/79

BUILDING CODE: .....

Fire Dept.: .....

Health Dept.: .....

Others: .....

### DATE

### MISCELLANEOUS

Will work require disturbing of any tree on a public street? .....

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? .....

Signature of Applicant [Signature] Phone # same

Type Name of above Donatelle Builders 1  2  3  4

FIELD INSPECTOR'S COPY

Other .....

and Address .....

NOTES

April 17/79

Property & the dwelling location are staked out. No excavation for foundation.

Permit No. 79/183  
Location #16  
Owner [unclear]  
Date of permit 3-28-79  
Approved 3-28-79

May 4/79 OK to place foundation.

May 7/79 Back filling today.

The owner said it will be a month before the foundation is done. I told him to be sure to erect a fence or barrier of something to prevent someone falling in. He said he would.

Oct 13/79 About completed. All calculations to be submitted. All room fixtures - Outside grading incomplete.

Nov 5/79 About the same. Builder said it would be completed in about 2 wks. It may be spring before the property gets graded etc.

Dec 12/79 OK to issue the CO of C for the entire single family dwelling.

