

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Cottage Park Development		Owner: Ric Weinschenk		Phone: 767-3800		Permit No: 940732	
Owner Address: 16 Park Circle Cape Elizabeth, ME 04107		Lease/Buyer's Name:		Phone:		Business Name: Macy Greisk	
Contractor Name: Ric Weinschenk		Address:		Phone:		Permit Issued: JUL 21 1994	
Past Use: Vacant Lot		Proposed Use:		COST OF WORK: \$ 8,000.		PERMIT FEE: \$ 60.00	
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
Proposed Project Description: Construct Pavillion as per plans.		Signature:		Signature:		Zoning Approval: WOA	
		PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.)		Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input checked="" type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
		Signature:		Date:		Zoning Appeal: <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *Rick Wortley* ADDRESS: _____ DATE: 20 July 1994 PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:
 Approved
 Approved with Conditions
 Denied

Date: 7/20/94

D. Andrews

CEO DISTRICT **7**

M.R. Webster

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Office Park Development		Owner: Kic Wainschenk	Phone: 767-31100	Permit No: 840782
Owner Address: 221 18 Park Circle Cape Elizabeth, ME 04107		Lease/Buyer's Name:	Phone:	Business Name:
Contractor Name: Kic Wainschenk		Address:		Phone:
Past Use: Vacant Lot	Proposed Use:	COST OF WORK: \$ 2,500.	PERMIT FEE: \$ 50.00	Permit Issued: PERMIT ISSUED JUL 21 1994 ZONE: CBF CITY: PORTLAND
Proposed Project Description: Construct Pavilion as per plans.		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type:	
		Signature:	Signature:	Zoning Approval: <i>WDA</i> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input checked="" type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.		PEDESTRIAN ACTIVITIES DISTRICT (P.U.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Date: <i>9/20/94</i>	
SIGNATURE OF APPLICANT <i>Kic Wainschenk</i>		ADDRESS:	DATE: 10 July 1994	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		PHONE:		CEO DISTRICT 7 <i>M. Webster</i>
		White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector		


COMMENTS

Foundation is OK per plans

5-2-95 - Framing Insp.

6-19-95 - Pavilion completed / no rot O needed / Guard rail damaged / walk way rail weak

(Guard rail damaged w/rod is req (Steel Beams in ramp system) by curved section of guard rail damaged (Post support strong enough) Post on ramp to structure weak/loose) 1" x 1 3/4" ballist. top rail 1" x 1 3/4" + 2" x 4" bottom rail 1" x 1 3/4" (ramp rail system Post 12' or 2" x 4" top rail + 2" x 4" + 1" x 1 3/4"



Curved guard rail
2" x 4" top rail
1" x 1 3/4" below top rail
1" x 1 3/4" ballist (4" between)
1" x 1 3/4" bottom rail

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: <u>Close</u>	<u>6-19-95</u>
Other: _____	_____

