

LOT 20 BRICK ROAD

202/107

9700-31

A.P.- 107 Brook Road

April 2, 1968

Carmina DiFilippo
107 Brook Road

Dear Mr. DiFilippo:

Permit to demolish existing side platform and to construct 1-story 10'x10' addition on left hand side of dwelling is being issued subject to plans received with application and in compliance with Building Code restrictions as follows:

1. Foundation shall have concrete footing at least 8" thick and at least 2" wider than block wall above.
2. Rafters will need to be supported on a continuous horizontal member not less than 2x6 inches nominal dimension instead of the 2x4 inch plate shown on plans.

Very truly yours,

A. Allan Soule
Acting Deputy Building Inspector

AAS:m



R3 RESIDENCE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, April 2, 1968

PERMIT ISSUED

APR 2 1968

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 107 Brook Road Within Fire Limits? _____ Dist. No. _____
Owner's name and address Carmino DiFilippo, 107 Brook Road Telephone 797-5197
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone _____
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building Dwelling No. families 1
Last use _____ " _____ No. families 1
Material frame No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 500. Fee \$ 3.00

General Description of New Work

To ~~er~~ demolish existing side platform and to construct 1-story 10'x10' addition on left hand side of dwelling

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate 9'6" Height average grade to highest point of roof 12'
Size, front _____ depth _____ No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation concrete block at least 4' below grade Thickness, top 12" bottom 12" cellar no
Kind of roof pitch Rise per foot 5" Roof covering asphalt roofing Class G Und. Lab. _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber--Kind hardlock Dressed or full size? dressed Corner posts 4x6 Sills box
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8 2nd _____ 3rd _____ roof 2x6
On centers: 1st floor 16" 2nd _____ 3rd _____ roof 16"
Maximum span: 1st floor 10' 2nd _____ 3rd _____ roof 10'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

A.K. - 4/2/68 - Allen W. Allen

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

CS 301

INSPECTION COPY

Signature of owner

Carmino W. DiFilippo


PH

Permit No. 68/ 271
Location 107 Bank Park
Owner Carmine DiFilippo
Date of permit 4/7/68
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. _____
Cert. of Occupancy issued _____
Staking Out Notice _____
Form Check Notice _____

NOTES

4/8/68 - For final p. issued

6/19/68 - work done E. S. S.



CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. 55036
Issued _____
Portland, Maine, 19 ..

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Resident in Philadelphia Tel. _____
Contractor's Name and Address Bryggan and Son Tel. _____
Location 207 1/2 Birch St Use of Building _____
Number of Families 1 Apartments _____ Stores _____ Number of Stories 2
Description of Wiring: New Work _____ Additions _____ Alterations _____

Pipe	Cable	Metal Molding	BX Cable	Plug Molding (No. of feet)	
No. Light Outlets		Plugs	Light Circuits	Plug Circuits	
FIXTURES: No.		Light Switches	Fluor. or Strip Lighting (No. feet)		
SERVICE: Pipe	Cable	Underground	No. of Wires	Size	
METERS: Relocated		Added	Total No. Meters		
MOTORS: Number	Phase	H. P.	Amps	Volts	Starter
HEATING UNITS	Domestic (Oil)	<input checked="" type="checkbox"/> No. Motors	Phase	H.P.	
	Commercial (Oil)	No. Motors	Phase	H.P.	
		Electric Heat (No. of Rooms)			
APPLIANCES: No. Ranges		Watts	Brand Feeds (Size and No.)		
	Elec. Heaters	Watts			
	Miscellaneous	Watts	Extra Cabinets or Panels		
Transformers		Air Conditioners (No. Units)	Signs (No. Units)		
Will commence	<u>19</u>	Ready to cover in	<u>19</u>	Inspection	<u>19</u>
Amount of Fee \$.	<u>2.00</u>				

Signed [Signature]

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1	2	3
4	5	6
7	8	9
10	11	12

REMARKS:

INSPECTED BY [Signature]
(OVER)

LOCATION *Brookings Rd. Lot 10*
 INSPECTION DATE *9/26/66*
 WORK COMPLETED *9/24/66*
 TOTAL NO. INSPECTIONS *1*
 REMARKS:

FEE SCHEDULE FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING		
1 to 30 Outlets	(including switches)	\$ 2.00
31 to 60 Outlets	(including switches)	3.00
Over 60 Outlets, each Outlet	(including switches)	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).		
SERVICES		
Single Phase		2.00
Three Phase		4.00
MOTORS		
Not exceeding 50 H.P.		3.00
Over 50 H.P.		4.00
HEATING UNITS		
Domestic (Oil)		2.00
Commercial (Oil)		4.00
Electric Heat (Each Room)		.75
APPLIANCES		
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers — Each Unit		1.50
TEMPORARY WORK (Valid for 6 months from date of permit)		
Service, Single Phase		1.00
Service, Three Phase		2.00
Wiring, 1-50 Outlets		1.00
Wiring, each additional outlet over 50		.02
Circuses, Carnivals, Fairs, etc.		10.00
MISCELLANEOUS		
Distribution Cabinet or Panel, per unit		1.00
Transformers, per unit		2.00
Air Conditioners, per unit		2.00
Signs, per unit		2.00
ADDITIONS		
5 Outlets, or less		1.00
Over 5 Outlets, Regular Wiring Rates		

CITY OF PORTLAND, MAINE
 Application for Permit to Install Wires

Permit No. 55025

Portland, Maine issued July 21, 1966

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address *Carmen Di Silippo* Tel.
 Contractor's Name and Address *Ernest M. Carayon* Tel. *77-26224*
 Location *LOT 20 BROOK RD* Use of Building *HOME*
 Number of Families *1* Apartments Stores Number of Stories *2*
 Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
 No. Light Outlets Plugs *12* Light Circuits Plug Circuits
 FIXTURES: No. *5* Light Switches *5* Floor. or Strip Lighting (No. feet)
 SERVICE: Pipe Cable Underground No. of Wires *3* Size *23-1-0*
 METERS: Relocated Added Total No. Meters
 MOTORS: Number Phase H. P. Amps Volts Starter
 HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
 Commercial (Oil) No. Motors Phase H.P.
 Electric Heat (No. of Rooms)
 APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
 Elec. Heaters Watts
 Miscellaneous Watts Extra Cabinets or Panels
 Transformers Air Conditioners (No. Units) Signs (No. Units)
 Will commence 19... Ready to cover in 19... Inspection 19...
 Amount of Fee \$ *5.50*
 Signed *Ernest M. Carayon*

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1	2	3
7	8	9
10	11	12

REMARKS:

INSPECTED BY *F.W. Hubert* (OVER)

*22
21
20
19
18
17
16
15*

*Blue-Box
7/21/66*

LOCATION *Brook Rd. Lot #20*
 INSPECTION DATE *7/21/66*
 WORK COMPLETED *7/21/66*
 TOTAL NO. INSPECTIONS *1*
 REMARKS:

FEE S FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	
1 to 30 Outlets	(including switches) \$ 2.00
31 to 60 Outlets	(including switches) 3.00
Over 60 Outlets, each Outlet	(including switches)05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	5.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers, etc. -- Each Unit	1.50
TEMPORARY WORK (Limited to 6 months from date of permit)	
Service, Single Phase	1.00
Service, Three Phase	2.00
Wiring, 1-50 Outlets	1.00
Wiring, each additional outlet over 50	1.00
Circuses, Carnivals, Fairs, etc.	10.00
MISCELLANEOUS	
Distribution Cabinet or Panel, per unit	1.00
Transformers, per unit	2.00
Air Conditioners, per unit	2.00
Signs, per unit	2.00
ADDITIONS	
5 Outlets, or less	1.00
Over 5 Outlets, Regular Wiring Rates	



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 27 1966

PERMIT ISSUED 00684 JUL 27 1966

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 20 Brook Road Use of Building Dwelling No Stories 2 New Building Existing
Name and address of owner of appliance Carmine DiFillippo, 80 1/2 Congress St.
Installer's name and address Breggy Oil Service, 8 1/2 Congress St. Telephone

General Description of Work

To install Oil-fired forced hot water heating system

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3'
From top of smoke pipe 20" From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 6x8 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Federal-gumtype Labeled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 gals.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.K. E.S.S. 7/27/66

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Breggy Oil Service

Signature of Installer by: [Signature]

INSPECTION COPY

CS 300

7m

Permit No. 66/664
 Location Lot 20 Brook Road
 Owner Charmine Or Filippa
 Date of permit 7/27/66
 Approved 10/19/66

NOTES

1	...	-----
2	Vent	-----
3	Kind of Heat	-----
4	Burner Reg. Air	-----
5	Name of	-----
6	Stack Dia	-----
7	Height	-----
8	Remote Control	-----
9	Pipng. Gas. Part. Protection	-----
10	Valves	-----
11	Capacity of Tanks	-----
12	Tank Rel. Intv	-----
13	Tank Capacity	-----
14	Oil Diag	-----
15	Instruction Card	-----
16	Low Water Shut off	-----

Large blank area with vertical lines, possibly for additional notes or a diagram.

PERMIT TO INSTALL PLUMBING

PERMIT NUMBER 16232

Date Issued 5/23/66
 - Portland Plumbing Inspector
 By ERNOLD R. GOODWIN

Address Lot 20 Brook Road
 Installation For: Dwelling
 Owner of Bldg.: Cecilia Phillips
 Owner's Address: Brook Road
 Plumber: [unclear] [unclear]
 Date: 5/23/66

App. First Insp.
 Date MAY 24 1966
 By ERNOLD R. GOODWIN

CHIEF PLUMBING INSPECTOR
 App. Final Insp.
 Date MAY 24 1966
 By ERNOLD R. GOODWIN

CHIEF PLUMBING INSPECTOR
 Type of Bldg.

- Commercial
- Residential
- Single
- Multi Family
- New Construction
- Remodeling

NEW	REPL.	Item	Fee
		SINKS	
		LAVATORIES	
		TOILETS	
		BATH TUBS	
		SHOWERS	
		DRAINS FLOOR SURFACE	
		HOT WATER TANKS	
		TANKLESS WATER HEATERS	
		GARBAGE DISPOSALS	
		SEPTIC TANKS	
1		HOUSE SEWERS	
		ROOF LEADERS	
		AUTOMATIC WASHERS	1 2.00
		DISHWASHERS	
		OTHER	
		TOTAL	2.00

Building and Inspection Services Dept.: Plumbing Inspection

(COPY)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION Lot 20 Brook Road

Issued to **Carmino DiFilippo**
204 Congress St.

Date of Issue **October 19, 1966**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **66/358**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

One family dwelling.

Limiting Conditions:

This certificate supersedes
certificate issued

Approved: *Carl Smith*
(Date) Inspector

Gerald E. Mayberry
Inspector of Building

CS 147

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

A.P.- Lot 20 Brook Rd.

May 6, 1966

Carmine DiFillippo
804 Congress Street

Dear Mr. DiFillippo:

In checking your application to construct a 2-story frame dwelling 38'x24'-4" at the above named location we find that we are unable to continue processing your permit until further information is provided as follows:

1. We will need an off-street parking area, eight feet wide and eighteen feet long shown on a new plot plan or on the plot plan filed here at the office with application.
2. It is called to your attention that the City of Portland Building Code requires that in two-story buildings the corner posts are to extend in one piece with 18 inch lap splices allowed from either the solid sill or from the first floor shoe (sole plate) where a box sill is allowed to the double plate which supports the roof rafters at the cave level. The second floor studs in the exterior walls are to extend down to the double 2x4 inch plate upon which the second floor joists rest with the second floor joists being spiked to these studs. Only on the wall above the garrison overhang where it is not possible to extend the corner posts in one piece from sill to the plate of the top floor and where studs cannot be carried to the plate of the floor below can both the studs and corner posts rest on the shoe. (sole plate)
3. We will need a framing plan of the second floor. If the floor joists run the same as the first floor then we will need to know how the overhang is to be framed and what is to support the floor joists over the dining area. If floor joists are to run from front to rear as rest of the second floor then we will need to know what will support the floor joists over the center of the living room.
4. Anchor bolts for the sills are required at the corners and not more than six feet from center to center between corners.
5. What size headers and on what spans for picture windows on the front and rear of the living room?

*fir needed
1x6 or* } → 4x16 -

May 6, 1966

6. If floor joists are not to rest on top of the girder then they will need to rest on a 2x3 inch nailer strip.

Fir → 7. The 6x10 inch girder will need to be a 6x10 inch Douglas fir or a larger member.

Concrete block with fastings

8. How will porches be framed? what will be used for a foundation?

Very truly yours,

A. Allan Soule
Inspector

AAS:m

A.P.- Lot 20 Brook Road

May 12, 1966

Carmine DiFillippo
804 Congress Street

Dear Mr. DiFillippo:

Permit to construct a 2-story frame dwelling 38'x24'-4" at the above named location is being issued subject to plans received with application and in compliance with Zoning Ordinance and Building Code restrictions as follows:

1. Headers over picture windows on front and rear of living room on a span of eight feet will need to be 4x10 inch fir members.
2. This building can be constructed 8 feet from the right side lot line as you face the lot from the street. It is brought to your attention that the left side will need to have a 20 foot side yard if it is proposed to construct a garage or any other structure on this side in the future unless the street shown on the development plan can be discontinued by the Planning Board and City Council action.

Very truly yours,

A. Allan Soule
Inspector

AAS:na

Lot 20 Brook Rd.
2-story dwelling

5/5/66

Allen

R3 -

Corner lot

CHECK AGAINST ZONING ORDINANCE

- ✓ Date - New - O.K.
- ✓ Zone Location - R-3-O.K.
- Interior or corner Lot -
- ✓ 40 ft. setback area? (Section 21) NO - O.K.
- ✓ Use - Dwelling - O.K.
- ✓ Sewage Disposal - Sewer - O.K.
- ✓ Rear Yards - $\frac{42}{31} - 81$ O.K. 2F' - Addition 41' - 66'
- ✓ Side Yards - ~~8'~~ 28' - O.K.
- ✓ Front Yards - 30' - O.K.
- ✓ Projections - Chimney, bulkhead, porch, overhang
- ✓ Height - O.K.
- ✓ Lot Area - 9,360' - O.K.
- ✓ Building Area - 2,340' - Dwelling 935' - O.K. Addition 100 Total 1035'
- ✓ Area per Family - O.K.
- ✓ Width of Lot - O.K.
- ✓ Lot Frontage - O.K.
- ✓ ~~lot~~ Off-street Parking - O.K.



APPLICATION FOR PERMIT

R3 ZONE

PERMIT ISSUED

MAY 13 1966

Class of Building or Type of Structure Third Class
Portland, Maine, May 2, 1966

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lct 20 Brook Road Within Fire Limits? _____ Dist. No. _____
Owner's name and address Carmine DiFillippo, 804 Congress St. Telephone 773-5147
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone 773-5147
Architect Payne 797-3475 Specifications _____ Plans yes No. of sheets 4
Proposed use of building Dwelling No. families _____
Last use _____ No. families 1
Material frame No. stories 2 Heat _____ Style of roof _____ Roofing _____

Other buildings on same lot _____ Fee \$ 26.00
Estimated cost \$ 12,500.00 Add. cost 4,000.00 **General Description of New Work** \$ 8.00 add. 1.00
6-6-166-16,500.00 \$34.00 6-6-60

To construct 2-story frame dwelling 38' x 24'4"

It is understood that this permit does not include installation of heating apparatus which shall be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO**

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? yes If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? yes
Height average grade to top of plate 18' Height average grade to highest point of roof 24'
Size, front 38' depth 24'4" No. stories 2 solid or filled land? solid earth or rock? earth
Material of foundation concrete at least _____ Thickness, top 10" bottom 10" cellar yes
Kind of roof pitch Rise per foot 0" Roof covering Asphalt Class C Und Label.
No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat f.h. water fuel oil
Framing Lumber—Kind hemlock Dressed or full size? pressed Corner posts 4x4 Sills 2x5 box
Size Girder 6x10 Columns under girders Lally Size 2 1/2" Max. on centers 8'
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet. ceiling timb.
Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd 2x6 roof 2x8
On centers: 1st floor 16", 2nd 15", 3rd 16" roof 16"
Maximum span: 1st floor 12', 2nd 12', 3rd _____, roof 12 1/2'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:
O.K. - 5/13/66 - Allen w/letter

Carmine DiFillippo

CS 301
INSPECTION COPY Signature of owner by: Carmine DiFillippo

NOTES

5/15/66 - I have left word with Mr. Di Filippo in regard to the Planning Board about development plans - Allen

5/19/66 - Call Mr. Di Filippo and told him that planning board would have difficulties plans sent down tomorrow Allen

5/29/66 - Form insp. made - 33' from curb line. E.H.

6/7/66 - Frame dug to 2nd floor. T. L. B. B. B. to carry stuff down to plot and carrying materials. E.H.


6/28/66 - F. inspec against studding plot existing on chimney. Not high enough above roof line. E. S. D.

7/21/66 - Locked up window to get in. E.H.

9/22/66 - Closed in without connection. T. L. B. B. B. to the sure and call for further info. E. S. D.

9/27/66 - MO cleared - no chimney. MO scale platform + steps. E. S. D.

10/19/66 - Out to be revised. E.H.



Permit No. 66/355
 Location: 30 Canal Lane
 Owner: Dennis P. Filippone
 Date of permit: 5/13/66
 Notif. closing-in
 Inspn. Closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued 10/19/66. E.S.D.
 Spiking Out Notice 5/26/66
 Form Check Notice 5/26/66

66/355
11/11