

Inspection Services
Samuel P. Hoffbes
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

February 27, 1981

RE: Lot #21 Bramblewood Drive, Portland, ME.

Carland Construction Inc.
22 Crestwood Drive
Westbrook, Maine 04092

Dear Sir:

Your application to construct a single family dwelling with attached 2-car garage has been reviewed and a permit is herewith issued subject to the following requirements:

No certificate of occupancy can be issued until all requirements of this letter are met.

Site Plan Review

Public Works Approval is granted on condition that a catch basin with 3' sump and casco trap be installed at connection to existing drain. W. Boothby


Inspection Services Approved William Giroux

Building Code Requirements

Please read and implement items 1,2,6,7,8,9 and 10 of the attached building permit report.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffbes
Chief of Inspection Services

cc: Steve Harris, Public Works
P. Niehoff, Public Works

BUILDING PERMIT REPORT

ADDRESS Lot #21 Bramblewood DR. DATE: 28/Feb/91

REASON FOR PERMIT: To Construct A Single Family Dwelling with garage.

BUILDING OWNER: Albert Axelsen

CONTRACTOR: Carlson Const.

PERMIT APPLICANT: _____

APPROVED: *1, *2, *6, *7, *8, *9, *10

CONDITION OF APPROVAL:

- * 1.) Before concrete for foundation is placed, approvals from Public Works and Inspection Services must be obtained.
- * 2.) Precaution must be taken to protect concrete from freezing.
- 3.) All vertical openings shall be enclosed with construction having a fire rating of at least one(1) hour, including fire doors with self-closers.
- 4.) Each apartment shall have access to two(2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 5.) The boiler shall be protected by enclosing with one(1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide 0.15 gallons per minute, per square foot of floor throughout the entire area. An INDICATING shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4 inch copper or 1 inch steel. Maximum coverage area of a residential sprinkler is 144 square feet per sprinkler.
- * 6.) Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside opening without the use of separate tools. Where windows are provided as a means of egress or rescue, they shall have a sill height not more than 44 inches (1118 mm) above the floor. All egress or rescue windows from sleeping rooms must have minimum net clear openings of 5.7 square feet (0.53m²). The minimum net clear opening height dimension shall be 24 inches (610 mm). The minimum net clear opening width dimension shall be 20 inches (508 mm).
- * 7.) All single and multiple-station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the building code (BOCA National Building Code 1990, and N.F.P.A. 74).

*8.) Private garages located beneath rooms in buildings of Use Groups R-1, R-2, R-3 or I-1 shall have walls, partitions, floors and ceilings separating the garage space from the adjacent interior spaces constructed of not less than 1-hour fire-resistance rating. Attached private garages shall be completely separated from the adjacent interior spaces and the attic area by means of 1/2-inch gypsum board or equivalent applied to the garage side. The sills of all door openings between the garage and adjacent interior spaces shall be raised not less than 4 inches (102 mm) above the garage floor. The door opening protectives shall be 1 3/4-inch solid core wood doors or approved equivalent.

*9.) A guardrail system located near the open side of deck or elevated walking surfaces shall be constructed. Guards in buildings of Use Group R-3 shall be not less than 36 inches in height. Open guards shall have intermediate rails, balusters or other construction such that a sphere with a diameter of 4 inches cannot pass through any opening.

*10.) Section 25-135 of the Municipal Code for the City of Portland states: "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year.

11.) The builder of a facility to which Section 4594-C of the Maine State Human Rights Act, Title 5 M.R.S.A. refers, shall obtain a certification from a design professional that the plans of the facility meet the standards of construction required by this section. Prior to commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.

Sincerely,

P. Samuel Hoffses
Chief of Inspection Services

/el
11/16/88
11/27/90

Applicant:

Date:

Address:

Assessors No.:

CHECK LIST AGAINST ZONING ORDINANCE

Date - 2-26-91

Zone Location - R-3

Interior or corner lot -

Use - single

Sewage Disposal - city

Rear Yards - 40' 25' req

Side Yards - on side street 35' 20' req other 38'

Front Yards - 30' 25' req.

Projections - none

Height - 2 story

Lot Area - OK

Building Area - 74 x 28 = 2072#

Area per Family - entire

Width of Lot - 146' OK

Lot Frontage - OK

Off-street Parking - 2 cars

Loading Bays - N/A

Site Plan -

Shoreland Zoning -

Flood Plains -

front yard and street address
should be on Allen Avenue

**CITY OF PORTLAND, MAINE
SITE PLAN REVIEW
Processing Form**

Applicant: Albert Axelsen Date: 2/8/91
 Mailing Address: 59 Bramblewood Dr; Ptld, ME 04103
 Address of Proposed Site: Lot 21, Bramblewood Dr.
 Proposed Use of Site: 1-family dwelling w attached 2-car garage Site Identifier(s) from Assessors Maps: R-3
 Acreage of Site / Ground Floor Coverage: 14,439 sq ft / 28'x46' Zoning of Proposed Site: _____
 Site Location Review (DEP) Required: () Yes () No Proposed Number of Floors: _____
 Board of Appeals Action Required: () Yes () No Total Floor Area: _____
 Planning Board Action Required: () Yes () No
 Other Comments: contact person: Christopher Carland - 797-7510 - contractor
 Date Dept. Review Due: _____

 MINOR MINOR SITE PLAN

BUILDING DEPARTMENT SITE PLAN REVIEW
 (Does not include review of construction plans)

- Use does NOT comply with Zoning Ordinance
- Requires Board of Appeals Action
- Requires Planning Board/City Council Action

Explanation: _____
 Use complies with Zoning Ordinance — Staff Review Below

Zoning: SPACE & BULK, as applicable	DATE	ZONE LOCATION	INTERIOR OR CORNER LOT	40 FT. SETBACK AREA (SEC. 21)	'USE	SEWAGE DISPOSAL	REAR YARDS	SIDE YARDS	FRONT YARDS	PROJECTIONS	HEIGHT	LOT AREA	BUILDING AREA	AREA PER FAMILY	WIDTH OF LOT	LOT FRONTAGE	OFF-STREET PARKING	LOADING BAYS		
																				COMPLIES

REASONS: OK WDJ - P 2-26-91

SIGNATURE OF REVIEWING STAFF/DATE
 BUILDING DEPARTMENT—ORIGINAL



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date 4/3/91, 19
 Receipt and Permit number 01980

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: Lot #21, Bramblewood Drive
 OWNER'S NAME: Albert Axelsen ADDRESS: 59 Bramblewood Dr.

	FEES
OUTLET:	
Receptacles <u>60</u> Switches <u>30</u> Plugmold _____ ft. TOTAL <u>90</u>	<u>12.00</u>
FIXTURES: (number of)	
Incandescent <u>18</u> Fluorescent _____ (not strip) TOTAL <u>18</u>	<u>3.60</u>
Strip Fluorescent _____ ft.	
SERVICES:	
Overhead _____ Underground <u>x</u> Temporary _____ TOTAL amperes <u>100</u> ..	<u>15.00</u>
METERS: (number of) <u>1</u>	<u>1.00</u>
MOTORS: (number of)	
Fractional	
1 HP or over	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) <u>1</u>	<u>5.00</u>
Electric (number of rooms)	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler)	
Oil or Gas (by separate units)	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges <u>1</u>	
Cook Tops _____	
Wall Ovens _____	
Dryers <u>1</u>	
Fans <u>1</u>	
Water Heaters _____	
Disposals <u>1</u>	
Dishwashers _____	
Compactors _____	
Others (denote) _____	
TOTAL <u>5</u>	<u>10.00</u>
MISCELLANEOUS: (number of)	
Branch Panels	
Transformers	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc.	
Alterations to wires	
Repairs after fire	
Emergency Lights, battery	
Emergency Generators	
INSTALLATION FEE DUE:	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	DOUBLE FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	
TOTAL AMOUNT DUE:	
	<u>52.60</u>

INSPECTION:

Will be ready on 4/10 pm, 1991; or Will Call _____

CONTRACTOR'S NAME: Place Electric

ADDRESS: Summit St; Ptd

TEL: 797-9954

MASTER LICENSE NO.: Ch Place # 10626 SIGNATURE OF CONTRACTOR: _____

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS —

Permit Number 01980

Location Lot 21 Bramblewood Dr.

Owner Robert Axelson

Date of Permit 4-3-91

Final Inspection 5-29-91

By Inspector [Signature]

Permit Application Register Page No. 106

INSPECTIONS: Service 4-10-91 by SB
Service called in 4-10-91 - 11:00 AM
Closing-in 4-10-91 by SB

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:	REMARKS:
<u>5-29-91</u>	<u>Final / CO / OK / SB</u>

EXHIBIT 1
APPROVED FOR THE CITY OF DENVER
DIRECTOR OF DEPARTMENT OF UTILITIES
[Signature]

PLUMBING APPLICATION

PROPERTY ADDRESS

Town Or Plantation: Portland

Street Subdivision Lot #: 5 Bramblewood Dr.

PROPERTY OWNERS NAME

Last: Arkeson First: 41

Applicant Name: Carlson

Mailing Address of Owner/Applicant (If Different): 175

PORTLAND 4140 TOWN COPY

Fee: 12.14/91 \$ 13.64 FEE Charged Double Fee Charged

S. Samuel Hill L.P.I. # 01241

Chief Plumbing Inspector

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Richard Carlson 3-14-91
Signature of Owner/Applicant Date

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature: _____ Date Approved: _____

PERMIT INFORMATION

This Application is for	Type Of Structure To Be Served:	Plumbing To Be Installed By:
1. <input checked="" type="checkbox"/> NEW PLUMBING	1. <input checked="" type="checkbox"/> SINGLE FAMILY DWELLING	1. <input checked="" type="checkbox"/> MASTER PLUMBER
2. <input type="checkbox"/> RELOCATED PLUMBING	2. <input type="checkbox"/> MODULAR OR MOBILE HOME	2. <input type="checkbox"/> OIL BURNERMAN
	3. <input type="checkbox"/> MULTIPLE FAMILY DWELLING	3. <input type="checkbox"/> MFG'D. HOUSING DEALER/MECHANIC
	4. <input type="checkbox"/> OTHER - SPECIFY _____	4. <input type="checkbox"/> PUBLIC UTILITY EMPLOYEE
		5. <input type="checkbox"/> PROPERTY OWNER
		LICENSE # <u>010338</u>

Hook-Up & Piping Relocation Maximum of 1 Hook-Up	Column 2 Type of Fixture		Column 1 Type of Fixture	
	Number	Type of Fixture	Number	Type of Fixture
OR HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District. HOOK-UP: to an existing subsurface wastewater disposal system. PIPING RELOCATION: of sanitary lines, drains, and piping with new fixtures.	0, 2	Hose/bib / Silcock	0, 2	Bathtub (and Shower)
	0, 1	Floor Drain		Shower (Separate)
		Urinal	0, 1	Sink
		Drinking Fountain	0, 2	Wash Basin
		Indirect Waste	0, 2	Water Closet (Toilet)
		Water Treatment Softener, Filter, etc.	0, 1	Clothes Washer
		Grease/Oil Separator	0, 1	Dish Washer
		Dental Cuspidor	0, 1	Garbage Disposal
		Bidet		Laundry Tub
		Other: _____		Water Heater
Number of Hook-Ups & Relocations				
Hook-Up & Relocation Fee		Fixtures (Subtotal) Column 2	10	Fixtures (Subtotal) Column 1
			3	Fixtures (Subtotal) Column 2
			13	Total Fixtures
			\$.	Fixture Fee
			\$.	Hook-Up & Relocation Fee
			\$ 36.00	Permit Fee (Total)

would like an inspection - 3-14-91

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 5 Bramblewood Dr.

Issued to: Albert Axelsen

Date of Issue 5/4/91

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No 91/2355, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Single-family dwelling

Limiting Conditions:

This certificate supersedes
certificates issued

Approved:

5/13/91
Meda Gray
Inspector

[Signature]
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

912355

Permit # 912355 City of Portland BUILDING PERMIT APPLICATION Fee 337.50 Zone _____ Map # _____ Lot# _____
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Albert Axelsen Phone # _____
Address: 59 Bramblewood Dr; Ptld, OR 97103
LOCATION OF CONSTRUCTION Lot #27; Bramblewood Dr.
Contractor: Carland Const. Inc. Sub. #57 Phone # 797-7510
Address: 22 Crestwood Dr; Westbrook Phone # NE 04092
Est. Construction Cost: \$70,000 Proposed Use: 1-fam dwlg
Past Use: vacant lot
of Existing Res. Units _____ # of New Res. Units _____
Building Dimensions L 46' W 28' Total Sq. Ft. _____
Stories: 1 1/2 # Bedrooms 2 Lot Size: 14,430 sq ft
Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
Explain Conversion Construct one-family dwelling w attached

For Official Use Only
Date: 2/7/91 Subdivision: _____
Inside Fire Limits: _____ Name: _____
Bldg Code: _____ Lot: FEG 97-1004
Time Limit: _____ Ownership: _____
Estimated Cost: \$70,000 City of Portland
Zoning: R-3 Street Frontage Provided: _____ Back _____ Side _____
Provided Setbacks: Front _____ Back _____ Side _____
Review Required:
Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other: (Explain) OK to build 2-26-91

Foundation: _____
1. Type of Soil: _____ Rear _____ Side(s) _____
2. Set Backs - Front _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other: _____

Floor: _____
1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____ Size: _____
3. Lally Column Spacing: _____ Spacing 16" O.C.
4. Joists Size: _____ Size: _____
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____
7. Other Material: _____

Exterior Walls: _____
1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls: _____
1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

Ceiling: _____
1. Ceiling Joists Size: _____ Spacing _____
2. Ceiling Strapping Size _____
3. Type Ceilings: _____ Size _____
4. Insulation Type _____
5. Ceiling Height: _____

Roof: _____
1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____

Chimneys: _____
Type: _____ Number of Fire Places _____

Heating: _____
Type of Heat: _____

Electrical: _____
Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing: _____
1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools: _____
1. Type: _____ Square Footage _____
2. Pool Size: _____ x _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Luisa E. Glass
Signature of Applicant Ch. Carland Date 2-8-91
Signature of CEO _____
Inspection Dates _____
White Tag CEQ 124 Copyright GPCOG 1988
WMA ready 4/

PERMIT ISSUED WITH LETTER

PERMIT ISSUED WITH LETTER

1P-8-C

White-Tax Assesor

Yellow-GPCOG

White Tag

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ 370
 Subdivision Fee \$ _____
 Plan Review Fee \$ 50
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Type

Inspection Record

Date

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS

3-17-91 Set back of foundation. OK 3-15. Rough plumbing work
 follows complete. 4-10-91 Framing of all completed.
 5/29 - Final called for - inadequate railing + Ballistic builder notified to
 correct

Signature of Applicant

Chris Carlson

Date

2-8-91

912475



FILL IN AND SIGN WITH INK
APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Me. 4/11/91

PERMIT ISSUED
APR 11 1991
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location: 52 Rt. (The Woods) Dr. Use of Building: 1-family No. Stories: New Building Existing
Name and address of owner of appliance: All Axelsen
Installer's name and address: E J Carling & Son 797-8489 Telephone: 35 Sixth St; Portland, ME 04103

General Description of Work

To install: install new heating system

IF HEATER, OR POWER BOILER

Location of appliance: Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material, from top of appliance or casing top of furnace:
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner: Peerless-gunttype Labeled by underwriters' laboratories? YES
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner: cement Size of vent pipe: 6 inch
Location of oil storage: boiler room Number and capacity of tanks: one - 275-gln
Low water shut off: yes Make: Miller No. W 8 8 5
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? MAX none
Total capacity of any existing storage tanks for furnace burners: 275 gln

IF COOKING APPLIANCE

Location of appliance: Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Estimated cost/work: \$550

Edward J. Carling - master plumber - license # 338

Amount of fee enclosed? \$50

APPROVED:

[Signature line]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

[Signature: Edward Carling]


912475

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 4/11/91



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 5 Bramblewood Dr. Use of Building 1-family No. Stories New Building Existing
Name and address of owner of appliance A.L. Axelsen
Installer's name and address E.J. Carling & Son 797-8489 Telephone
35 Sixth St; Ptd, ME 04103
General Description of Work

To install install new heating system

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe con?

IF OIL BURNER

Name and type of burner Peerless gun type Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner cement Size of vent pipe 6 inch
Location of oil storage boiler room Number and capacity of tanks one - 275-gal
Low water shut off yes Make Miller No. M.B. 8.5
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 275 gal

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of applia From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

estimated cost/work = \$5500
1. 1 1/2" VENT PIPE
2. 1 1/4" VENT PIPE
3. Kind of fuel oil
4. Burner, piping & support
5. Name & Label
6. Remote control
Amount of oil enclosed \$50.
8. Make of oil burner
9. Low water cutoff

APPROVED 10. High limit control
11. Piping on a protection
12. Valve on oil line
13. Capacity of tank
14. Tank & support
15. Oil gauge
16. Instruction card
17. Oil leaks

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Installer Edward Carling

INSPECTION 18. Adequate ventilation
19. Smokepipe to combustion
20. Thermal control
ASSESSOR'S COPY

Signature of Assessor (4) Leary

NOTES

PERMIT

PORT

6-4-91 Heating system installed

Permit No.

Location

Owner

Date of permit

Approved

1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of fuel
4. Burner rigidity & support
5. Name & label
6. Remote control
7. High limit control
8. Main burner switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction card
17. Oil leaks
18. Adequate ventilation
19. Smoke pipe to combustibles
20. Thermal control switch