

499-503 AUBURN STREET

SHAW-WALKER
2718-31



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date Sept. 25, 1980 19
 Receipt and Permit number A51738

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 501 Auburn St.
 OWNER'S NAME: John Grigsley ADDRESS: same

OUTLETS:	Receptacles _____	Switches _____	Plugnold _____	ft. TOTAL _____	_____
FIXTURES: (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____	_____	_____
	Strip Flourescent _____	ft. _____	_____	_____	_____
SERVICES:	Overhead _____	Underground _____	Temporary _____	TOTAL amperes _____	_____
METERS: (number of)	_____	_____	_____	_____	_____
MOTORS: (number of)	Fractional _____	_____	_____	_____	_____
	1 HP or over _____	_____	_____	_____	_____
RESIDENTIAL HEATING:	Oil or Gas (number of units) <u>x</u> _____	_____	_____	_____	<u>3.00</u>
	Electric (number of rooms) _____	_____	_____	_____	_____
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____	_____	_____	_____	_____
	Oil or Gas (by separate units) _____	_____	_____	_____	_____
	Electric Under 20 kws _____	Over 20 kws _____	_____	_____	_____
APPLIANCES: (number of)	Ranges _____	Water Heaters _____	_____	_____	_____
	Cook Tops _____	Disposals _____	_____	_____	_____
	Wall Ovens _____	Dishwashers _____	_____	_____	_____
	Dryers _____	Compactors _____	_____	_____	_____
	Fans _____	Others (denote) _____	_____	_____	_____
	TOTAL _____	_____	_____	_____	_____
MISCELLANEOUS: (number of)	Branch Panels _____	_____	_____	_____	_____
	Transformers _____	_____	_____	_____	_____
	Air Conditioners Central Unit _____	_____	_____	_____	_____
	Separate Units (windows) _____	_____	_____	_____	_____
	Signs 20 sq. ft. and under _____	_____	_____	_____	_____
	Over 20 sq. ft. _____	_____	_____	_____	_____
	Swimming Pools Above Ground _____	_____	_____	_____	_____
	In Ground _____	_____	_____	_____	_____
	Fire/Burglar Alarms Residential _____	_____	_____	_____	_____
	Commercial _____	_____	_____	_____	_____
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	_____	_____	_____	_____
	over 30 amps _____	_____	_____	_____	_____
	Circus, Fairs, etc. _____	_____	_____	_____	_____
	Alterations to wires _____	_____	_____	_____	_____
	Repairs after fire _____	_____	_____	_____	_____
	Emergency Lights, battery _____	_____	_____	_____	_____
	Emergency Generators _____	_____	_____	_____	_____
	INSTALLATION FEE DUE:	_____	_____	_____	<u>3.00</u>
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT	DOUBLE FEE DUE:	_____	_____	_____	_____
FOR REMOVAL OF A "STOP ORDER" (304-16.b)	_____	_____	_____	_____	_____
	TOTAL AMOUNT DUE:	_____	_____	_____	<u>3.00</u>

INSPECTION:

Will be ready on _____, 19__ ; or Will Call x

CONTRACTOR'S NAME: Jim's Plumbing & Heating

ADDRESS: 179 Marett St. Westbrook

TEL: _____

MASTER LICENSE NO.: on file SIGNATURE OF CONTRACTOR:

LIMITED LICENSE NO.: _____ *Carlton W. Baldwin*

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date Dec. 26, 19 79
 Receipt and Permit number A39815

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 503 Auburn St.
 OWNER'S NAME: Mr. Stevens ADDRESS: _____

OUTLETS:	RECEPTACLES	SWITCHES	PLUGMOLD	ft. TOTAL	FEE
RECEPTACLES (number of)	_____	_____	_____	_____	_____
INCANDESCENT	_____	FLUORESCENT (not strip)	_____	TOTAL	_____
STRIP FLUORESCENT	_____	ft.	_____	_____	_____
SERVICES:	OVERHEAD	UNDERGROUND	TEMPORARY	TOTAL AMPERES	FEE
METERS: (number of)	_____	_____	_____	_____	_____
MOTORS: (number of)	_____	_____	_____	_____	_____
FRACTIONAL	_____	_____	_____	_____	_____
1 HP or over	_____	_____	_____	_____	_____
RESIDENTIAL HEATING:	OIL OR GAS (number of units)	_____	_____	_____	_____
ELECTRIC (number of rooms)	_____	_____	_____	_____	_____
COMMERCIAL OR INDUSTRIAL HEATING:	OIL OR GAS (by a main boiler)	_____	_____	_____	_____
OIL OR GAS (by separate units)	_____	_____	_____	_____	_____
ELECTRIC UNDER 20 kws	_____	OVER 20 kws	_____	_____	_____
APPLIANCES: (number of)	RANGES	_____	WATER HEATERS	_____	_____
COOK TOPS	_____	DISPOSALS	_____	_____	_____
WALL OVENS	_____	DISHWASHERS	_____	_____	_____
DRYERS	_____	COMPACTORS	_____	_____	_____
FANS	_____	OTHERS (denote)	_____	_____	_____
TOTAL	_____	_____	_____	_____	_____
MISCELLANEOUS: (number of)	BRANCH PANELS	_____	_____	_____	_____
TRANSFORMERS	_____	_____	_____	_____	_____
AIR CONDITIONERS CENTRAL UNIT	_____	SEPARATE UNITS (WINDOWS)	_____	_____	_____
SIGNS 20 sq. ft. and under	_____	OVER 20 sq. ft.	_____	_____	_____
SWIMMING POOLS ABOVE GROUND	_____	IN GROUND	_____	_____	_____
FIRE/BURGLAR ALARMS RESIDENTIAL	_____	COMMERCIAL	_____	_____	_____
HEAVY DUTY OUTLETS, 220 Volt (such as welders)	30 amps and under	_____	over 30 amps	_____	_____
CIRCUS, FAIRS, etc.	_____	_____	_____	_____	_____
ALTERATIONS TO WIRES	_____	_____	_____	_____	_____
REPAIRS AFTER FIRE	_____	_____	_____	_____	_____
EMERGENCY LIGHTS, BATTERY	_____	_____	_____	_____	_____
EMERGENCY GENERATORS	_____	_____	_____	_____	_____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: 3.50
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____
 TOTAL AMOUNT DUE: 3.50

INSPECTION: Will be ready on Thursday, 19 79; or Will Call _____
 CONTRACTOR'S NAME: Economy Electric
 ADDRESS: 123 Skillings St. - so. portland
 TEL.: 774-4919
 MASTER LICENSE NO.: 3015 SIGNATURE OF CONTRACTOR: _____
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

0863 SEP 16 1974

ZONING LOCATION PORTLAND, MAINE, Sep. 16, 1974.

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

501 Auburn St

LOCATION Fire District #1 [] #2 []
1. Owner's name and address John Grigsby, same Telephone 797-3855
2. Lessee's name and address Telephone
3. Contractor's name and address owner Telephone
4. Architect Specifications Plans No. of sheets
Proposed use of building tool shed No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 125.00 Fee \$ 5.00

FIELD INSPECTOR—Mr. Ray Reitze

GENERAL DESCRIPTION

This application is for: @ 775-5451 to construct a 10 x 10 tool shed, set on cement blocks, all 2x4 members 16" oc with asphalt shingle roof.
Garage Ext. 234
Masonry Bldg.
Metal Bldg.
Alterations
Demolitions
Change of Use
Other

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 [x] 2 [] 3 [] 4 []
Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? no Is any electrical work involved in this work? no
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE
BUILDING INSPECTION—PLAN EXAMINER
ZONING:
BUILDING CODE:
Fire Dept.:
Health Dept.:
Others:

MISCELLANEOUS
Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Applicant Jeannette Grigsby Phone #
Type Name of above Mrs. John Grigsby 1 [x] 2 [] 3 [] 4 []

FIELD INSPECTOR'S COPY Other and Address

PERMIT TO INSTALL PLUMBING

PERMIT NUMBER **16789**

Date Issued **11/14/66**
 Portland Plumbing Inspector
 By **ERNOLD R. GOODWIN**

App. First Insp.
 Date **NOV 15 1966**
 By **ERNOLD R. GOODWIN**

CHIEF PLUMBING INSPECTOR
 App. Final Insp.
 Date **NOV 15 1966**
 By **ERNOLD R. GOODWIN**

- Type of Bldg.
- Commercial
 - Residential
 - Single
 - Multi Family
 - New Construction
 - Remodeling

Address 501 Auburn Street		PERMIT NUMBER 16789	
Installation For: Dwelling			
Owner of Bldg.: John Grigsby			
Owner's Address: 501 Auburn Street			
Plumber: Walter M. Walker		Date: 11/14/66	
NEW	REPL.		
		SINKS	
		LAVATORIES	
		TOILETS	
		BATH TUBS	
		SHOWERS	
		DRAINS FLOOR SURFACE	
		HOT WATER TANKS	
		TANKLESS WATER HEATERS	
		GARBAGE DISPOSALS	
		SEPTIC TANKS	
1		HOUSE SEWERS	2.00
		ROOF LEADERS	
		AUTOMATIC WASHERS	
		DISHWASHERS	
		OTHER	
TOTAL 1			2.00

Building and Inspection Services Dept.: Plumbing Inspection



PLANNED ZONE - A
 CITY OF PORTLAND, MAINE
 DEPARTMENT OF BUILDING INSPECTION
COMPLAINT

CS-66

501 Auburn St.

Location:

INSPECTION COPY

COMPLAINT NO. 57/6

Date Received 2/19/57

Location 501 Auburn St.

Use of Building _____

Owner's name and address Dr. Charles G. Martin, 501 Auburn St.

Telephone _____

Tenant's name and address _____

Telephone _____

Complainant's name and address Dr. Martin

Telephone _____

Description: Building built by Stanley Brown and bought by Dr. Martin in August, 1956 after C. O. had been issued to Mr. Brown. Chimney has woodwork against it at roof.

NOTES:

No firestop around chimney at 2nd floor or 1st story ceiling?
 Rafters have drawn away from ridge board about 1/2 inch.
 Some defect inside or outside at peak of gable at left side.

2/4/57 - No rotten floor work on inside of second in floor. Nothing much we can do now but special fast - stop should be provided in a clear space chimney - WJD

Dr. Martin is to telephone and I will call him then

2/19/57 - made the visit with WJD and bldg permit appl. - WJD



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 24, 1956

PERMIT ISSUED 01102 JUL 25 1956 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 492-503 Auburn St. Use of Building dwelling house No. Stories 1 New Building Existing
Name and address of owner of appliance Stanley Brown, R. F. D. #1, Cumberland Center
Installer's name and address William C. Miles, 125 Ridgeland Ave., So. Port Telephone 5-0537

General Description of Work

To install forced hot water heating system and oil burning equipment

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3'
From top of smoke pipe 2 1/2' From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 2 x 12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? YES

IF OIL BURNER

Name and type of burner Federal Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 1-275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: O.N. - 7/25/56 - agl

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES

CITY OF PORTLAND PRINTING CO.

INSPECTION COPY agl

Signature of Installer William C. Miles

CS MAINE PRINTING CO., PORTLAND

(COPY)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 499-503 Auburn St.

Issued to Stanley Brown

Date of Issue Aug. 13, 1956

This is to certify that the building, premises, or part thereof, at the above location, built—~~altered~~
~~—erected~~ under Building Permit No. 56/318, has had final inspection, has been found to conform
substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for
occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

One-family Dwelling House

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

8/13/56
(Date)

Earl Smith
Inspector

Waverly
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from
owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

RFU WMcD 4/1/57

March 19, 1957

BF 499-503 Auburn Street

Mr. Stanley Brown
R.F.D. #1
Cumberland Center, Me.

Copy to Dr. Charles G. Martin
501 Auburn Street

Dear Mr. Brown:

Upon personal inspection of the dwelling at 499-503 Auburn St., of Dr. Martin, for which the required certificate of occupancy was issued to you on August 13th, 1956, I was troubled by two particular items on which the Building Code has definite bearing--items which seem to be somewhat defective.

Beside the chimney there is a partitioned off space which runs from the underflooring of the first floor to the attic which is open to the attic, having been closed by the owner by stuffing something into it at the attic level. I did not have the plans with me but now that I have returned to the office no indication of it is found on the plan. That is not important; but the fact that the boards of the underfloor of the first story have sizeable cracks between them introduces an important fire hazard if fire should take place in the cellar. I could stand in the attic and look down through this small shaftway between the boards into the cellar. Though we have issued the certificate of occupancy, our field inspector apparently being unaware of this situation, I feel sure that you will agree that you ought now to go back there and introduce a firestop by way of a solid sheet of material, metal or asbestos lumber or the like, beneath the first floor boards at this point to provide an adequate firestop to prevent any fire in the cellar from passing quickly to the attic.

You evidently provided the firestop at first story ceiling level around the chimney but the space between the attic floor framing in the chimney should also be filled with mineral wool or the like. At the same time, if the owner agrees, it would be well to cover tightly at the attic level this small shaftway referred to above.

It was puzzling to see that in many cases the mitred end of the rafters did not fit tight against the full depth of the ridgeboard. In each of these cases the top of the rafter was tight against the ridgeboard but the bottom of the mitre appears to be a quarter to a half an inch away from the vertical surface of the ridgeboard. How this could happen is not quite clear because it is my impression that rafters in such a case are all cut on the same angle and some of these rafters fit against the ridgeboard nicely.

Whether or not this condition was present at time of final inspection is not known, but how it could occur after that without distortion of exterior walls of the building is difficult to see, and no distortion of these walls was noted. You or someone have driven small wedges-- they look like pieces of shingle--in these openings, which closes the gap and probably will care for the situation if they are fastened in place. If they are not fastened in place it is likely that natural shrinkage will cause them later to fall out. It seems to me that you

Mr. Stanley Brown - - - - 12

March 19, 1957

should make sure, with the consent of the owner, that these wedges fit tightly in each case where needed and that they would be fastened in place so that they will always remain to make up for the deficient bearing of the rafters against the ridgeboard.

I am not trying to be unduly critical, Mr. Brown, but I feel sure that you will want to make these points as complete as it is possible now to do, and that you will take care to avoid similar difficulties in future work under the supervision of this department. Will you not do so before April 1st, and it will be appreciated if you will notify me when it is done.

If you should care to talk the matter over with me, will you call in advance and arrange to come in some afternoon?

Very truly yours,

Warren McDonald.
Inspector of Buildings /

WHCD/G

CITY OF PORTLAND, MAINE
Department of Building Inspection

March 16, 1956

Location - Lot 1 Auburn Street (501)
Owner - Stanley Brown
Type Bldg. - Dwelling

To the Health Director:

Application for building permit identified as above has been filed in this office; indicating that a septic tank installation is proposed, as a means of sewage disposal. Applicant represents that connection to a public sewer is not feasible. Copy to owner and contractor is attached.

Your approval as to the method of sewage disposal is requested before a building permit is issued, therefore will you complete and return the appended report as expeditiously as possible.

Warren McDonald
Inspector of Buildings *W*

Attachment:
Copy of this notice

Proposed sewage disposal method is ~~is not~~ approved.

Remarks:

Edward With
Health Director 3/20/56

RECEIVED
MAR 20 1956
DEPT. OF B.C. INSP.
CITY OF PORTLAND

August 7, 1956

Location - 499-503 Auburn St.

Mr. Stanley Brown
R.F.D. #1
Sunderland Center, Mo.
Mr. Charles Martin
499-503 Auburn St.

Owner - Charles Martin

Job - New Dwelling

Gentlemen:-

Upon inspection of the above job on August 6, 1956, the following omission was found which prevents us from issuing the certificate of occupancy--required by law to be in possession of the owner before the building may be lawfully occupied:

Cleanout not usable in chimney because opening is not broken in flue lining.

It is important that the above condition be corrected before August 14, 1956 and that you notify this office of readiness for another inspection, so that, if all is found in order, the certificate of occupancy required by law may be issued.

Very truly yours,

Earlo S. Smith
Field Inspector

ES/S

March 16, 1956

Mr. Stanley Brown,
RFD #1,
Cumberland Center, Maine

Dear Mr. Brown:

Application today by you to construct a dwelling at 501 Auburn Street (Lot 1) indicates that no connection is possible to a public sewer, and that sewage disposal is proposed by septic tank.

The Building Code directs, where connection to a public sewer is not possible, that the proposed method of sewage disposal must be approved by the Health Officer before any building permit is issued.

That the Health Department may be aware of the proposed method of sewage disposal, you should explain, by plan or otherwise, the details and location of the septic tank system, including nature of the soil where overflow lines will be located, to Sanitary Engineer Norman Winch.

Very truly yours,

#

Inspector of Buildings



(C-1) RESIDENCE ZONE - 5

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, March 16, 1956

00358
MAR 22 1956

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect ~~alter, repair, demolish or~~ the following building structure ~~in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:~~

Location 4995503 Auburn St., Lot 1 Within Fire Limits? no Dist. No. _____
 Owner's name and address Stanley Brown, R. F. D. #1, Cumberland Center Telephone 9-3293
 Lessee's name and address _____ Telephone _____
 Contractor's name and address owner Telephone _____
 Architect _____ Specifications _____ Plans yes No. of sheets 4
 Proposed use of building dwelling house No. families 1
 Last use _____ No. families _____
 Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____
 Estimated cost \$ 9,000. Fee \$ 9.00

General Description of New Work

To construct 1 1/2-story frame dwelling house 24' 9" x 32' 9".

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
 Is connection to be made to public sewer? yes no _____ If not, what is proposed for sewage? septic tank
 Has septic tank notice been sent? _____ Form notice sent?
 Height average grade to top of plate 9 1/2' Height average grade to highest point of roof 18'
 Size, front 32' 9" depth 24' 9" No. stories 1 1/2 solid or filled land? solid earth or rock? earth
 Material of foundation concrete at least 4' below grade Thickness, top 10" bottom 12" cellar yes
 Material of underpinning _____ to sill _____ Height _____ Thickness _____
 Kind of roof pitch-gable Rise per foot 9" Roof covering Asphalt Class C Und Lab
 No. of chimneys 1 Material of chimneys brick of lining tile Kind of heat h.w. fuel oil
 Framing lumber—Kind hemlock Dressed or full size? dressed
 Corner posts 4x6 Sills 2x8 box Girt or ledger board? _____ Size _____
 Girders yes Size 6x8 D.A. dressed Columns under girders Lally Size 3 1/2" Max. on centers 7'
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x8, 2nd 2x8 stairway, 3rd _____, roof 2x8
 On centers: 1st floor 16", 2nd 18", 3rd _____, roof 20"
 Maximum span: 1st floor 12', 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

OK - 3/21/56 - ags

Miscellaneous

Will work require disturbing of any trees on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Stanley Brown



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 0.0731

JUL 20 1983

ZONING LOCATION PORTLAND, MAINE July 16, 1983 CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 501 Auburn Street - 01103
1. Owner's name and address Jeannette & John Grigsby - same Telephone 797-3855
2. Lessee's name and address Telephone
3. Contractor's name and address John Grigsby - same Telephone same
Proposed use of building Dwelling with addition No. of sheets
Last use No. families 1
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 2,000 Appeal Fees \$ 20.00
FIELD INSPECTOR-Mr. @ 775-5451 Base Fee
Late Fee
TOTAL \$ 20.00

To construct 10' x 12' addition to side of dwelling as per plans. 3 sheets of plans.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? yes If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS no
BUILDING INSPECTION-PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING: Will there be in charge of the above work a person competent
BUILDING CODE: to see that the State and City requirements pertaining thereto
Fire Dept.: are observed?
Health Dept.:
Others:

Signature of Applicant John Grigsby Phone # same
Type Name of above John Grigsby 1 2 3 4
Other and Address



FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

10

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

MAY 13 1985

B.G.C.A. TYPE OF CONSTRUCTION 0132

ZONING LOCATION PORTLAND, MAINE 5/6/85

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 501 Auburn Street Fire District #1 #2

1. Owner's name and address John G. Grigby, et al Telephone 797-3855

2. Lessee's name and address

3. Contractor's name and address C. W. Er Telephone

..... No. of sheets

Proposed use of building No. families

Last use No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot 403.00

Estimated contractual cost \$

FIELD INSPECTOR—Mr. Appeal Fees \$

@ 775-5451 Base Fee

to construct 16 x 14 deck on rear of existing Late Fee

filling as shown TOTAL \$ 15.00

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom collar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING:
BUILDING CODE: Will there be in charge of the above work a person competent
Fire Dept.: to see that the State and City requirements pertaining thereto
Health Dept.: are observed?
Others:

Signature of Applicant Jeannett Grigby Phone #

Type Name of above 1 2 3 4

Other and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date April 19, 1984
 Receipt and Permit number 21606

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 501 Auburn Street

OWNER'S NAME: John & Jeannette ADDRESS: same

Grigsby

OUTLETS: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL 1-30 FEES 3.00

FIXTURES: (number of) Incandescent _____ Fluorescent _____ (not strip) TOTAL 1-10 FEES 3.00

Strip Fluorescent _____ ft. _____

SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____

METERS: (number of) _____

MOTORS: (number of) Fractional _____

1 HP or over _____

RESIDENTIAL HEATING: Oil or Gas (number of units) _____

Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____

Oil or Gas (by separate units) _____

Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of) Ranges _____ Water Heaters _____

Cook Tops _____ Disposals _____

Wall Ovens _____ Dishwashers _____

Dryers _____ Compactors _____

Fans _____ Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of) Branch Panels _____

Transformers _____

Air Conditioners Central Unit _____

Separate Units (windows) _____

Signs 20 sq. ft. and under _____

Over 20 sq. ft. _____

Swimming Pools Above Ground _____

In Ground _____

Fire/Burglar Alarms Residential _____

Commercial _____

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____

over: 30 amps _____

Circus, Fairs, etc. _____

Alterations to wires _____

Repairs after fire _____

Emergency Lights, battery _____

Emergency Generators _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____

TOTAL AMOUNT DUE: 6.00

INSPECTION: Will be ready on _____, 19__; or Will Call x

CONTRACTOR'S NAME: owner

ADDRESS: _____

TEL.: _____

MASTER LICENSE NO.: _____ SIGNATURE OF CONTRACTOR: Jeannette Grigsby


LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

MAY 10 1985
 RECEIVED
 OFFICE OF PUBLIC WORKS
 CITY OF PORTLAND



CC BLOCK TIER
 BELOW FROST LINE

1	2	3	4	5
6	7	8	9	$\frac{1}{2}$

JOHN GRIGSBY
 CIVIL ENGINEER
 PORTLAND, OREGON


DR. BY: JOHN GRIGSBY
 CK. BY:

COURSE:
 SECTION:

SCALE:
 DATE:


front

HOUSE



\$ 8
 3000.400 est.
 JOHN GRIBBY
 501 Auburn St
 Portland, Me
 over 10'

2/6
 2/4
 1/4
 2/2
 6 2x6"



hang your /

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 0 452
ZONING LOCATION R-3 PORTLAND, MAINE 5/6/85

MAY 13 1985

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and following specifications:

LOCATION 501 Auburn Street Fire District #1 [] #2 []
1. Owner's name and address John Grigsby, same Grigsby, same Telephone 797-3855
2. Lessee's name and address Telephone
3. Contractor's name and address owner Telephone
Proposed use of building No. of sheets
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot 400.00
Estimated contractual cost \$ Appeal Fees \$
FIELD INSPECTOR—Mr. @ 775-5451 Base Fee
Late Fee
TOTAL \$ 15.00
to construct 16 x 14 deck on rear of existing dwelling as shown

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point on roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING: DATE Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?
BUILDING CODE
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant Jeannette Grigsby Phone #
Type Name of above Jeannette Grigsby 1 [] 2 [] 3 [] 4 []
Other
and Address

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY

NOTES

5 May 2/85 Stopped work because of insufficient plans, in detail for masonry and other deck construction. In list of materials to be used.

Believe built by the home owner. I am that in my opinion lack any or little knowledge of construction.

He wanted to the owner to have a set of plans drawn up. I explained the type of construction necessary to meet the City Building Code etc.

I found all other work already supported on each end by 8" concrete blocks resting on the ground. Two columns of 4" hollow pipe for center, or all centers including beam?

To support an 8" span of 2x12" joists. I kept inquiring instructions of what the code would require and to call me that I could see the rules for support, require if below grade, in regard placing the deck etc.

May 17/85. No one home. Deck completed. Unable to verify if any columns were placed. The 8" concrete blocks remain as is etc. One of the opinions there is nothing farther below grade and that the deck is not built per code. If the owner or son did not follow all my instructions, I will recommend that they owner be set a letter of warning. This was a written reply as to the depth of the column supporting the carrying joists. I instructed them to place under the joint etc.

May 30/85. No one home. Deck. I left message to call me. Owner satisfied with deck. I told owner I was not doing it as built per code. They did not call me and instructed them to verify depth of supporting column etc.

Permit No. 85/450
Location 501 Columbia St.
Owner James Smith
Date of permit 5-6-85
Approved 5-13-85
Dwelling sun deck
Garage
Alteration

Handwritten signature or initials at the bottom of the page.



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 30, 1989, 19
 Receipt and Permit number 00356

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 305 Auburn Street 501
 OWNER'S NAME: Grigsby ADDRESS: _____

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	
SERVICES:	
Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground <u>1</u> _____	10.00
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	

INSTALLATION FEE DUE: _____
 FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____
 FOR REMOVAL OF A "STOP ORDER" (304-16.b)
 TOTAL AMOUNT DUE: 10.00

INSPECTION: _____ or 72 hrs.
 Will be ready on May 30, 1989; or Will Call _____
 CONTRACTOR'S NAME: Herbert Elec
 ADDRESS: 798 Main St. So Ptd
 TEL.: _____
 MASTER LICENSE NO.: 2576 SIGNATURE OF CONTRACTOR: _____
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number 00356
Location 305 Auburn St
Owner J. G. Kelly
Date of Permit 5/15/89
Final Inspection C. G. Kelly
By Inspector C. G. Kelly
Permit Application Register Page No. 64

INSPECTIONS: Service _____ by _____
Service called in _____
Closing-in See Remarks by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:	REMARKS:
6/2/89	Wrong address - 501 Auburn St in phase book

CODE COMPLIANCE COMPLETED
DATE: 6/5/89

PERMIT # 001922 CITY OF Portland BUILDING PERMIT APPLICATION MAP # _____ LOT# _____

WILL PICKUP

Please fill out any part which applies to job. Proper plans must accompany form.
 Owner: John and Jeanette Grigsby 04103
 Address: 501 Auburn Street 797-3855
 LOCATION OF CONSTRUCTION same
 CONTRACTOR: M T Pools SUBCONTRACTORS: 353-8406
 ADDRESS: Route 196 Lisbon Rd. Lisbon Me 04250
 Est. Construction Cost: 6,000 Type of Use: single family
 Past Use: _____
 Building Dimensions L _____ W _____ Sq. Ft. _____ # Stories: _____ Lot Size: _____
 Is Proposed Use: _____ Seasonal _____ Condominium _____ Apartment _____
 Conversion - Explain install a new swimming pool as per plan

For Official Use Only

Date April 11, 1989 Subdivision: Yes / No _____
 Inside Fire Limits _____ Name _____
 Bid Code _____ Lot _____
 Time Limit _____ Block _____
 Estimated Cost: 6,000 Permit Expiration: _____ Public _____
 Value Structure _____ Ownership: _____ Private _____
 Fee: 50.00

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE
 Residential Buildings Only:
 # Of Dwelling Units _____ # Of New Dwelling Units _____

Foundation:
 1. Type of Soil: _____
 2. Set Backs - Front _____ Rear _____ Side(s) _____
 3. Footings Size: _____
 4. Foundation Size: _____
 5. Other _____

Floor:
 1. Sills Size: _____ Sills must be anchored.
 2. Girder Size: _____
 3. Lally Column Spacing: _____ Size: _____
 4. Joists Size: _____ Spacing 16" O.C.
 5. Bridging Type: _____ Size: _____
 6. Floor Sheathing Type: _____ Size: _____
 7. Other Material: _____

Exterior Walls:
 1. Studding Size _____ Spacing _____
 2. No. windows _____
 3. No. Doors _____
 4. Header Sizes _____ Span(s) _____
 5. Bracing: Yes _____ No _____
 6. Corner Posts Size _____
 7. Insulation Type _____ Size _____
 8. Sheathing Type _____ Size _____
 9. Siding Type _____ Weather Exposure _____
 10. Masonry Materials _____
 11. Metal Materials _____

Interior Walls:
 1. Studding Size _____ Spacing _____
 2. Header Sizes _____ Span(s) _____
 3. Wall Covering Type _____
 4. Fire Wall if required _____
 5. Other Materials _____

PERMIT ISSUED

APR 12 1989

City Of Portland

Ceiling:
 1. Ceiling Joists Size: _____ Spacing _____
 2. Ceiling Strapping Size _____
 3. Type Ceilings: _____
 4. Insulation Type _____
 5. Ceiling Height: _____

Roof:
 1. Truss or Rafter Size _____ Spacing _____
 2. Sheathing Type _____ Size _____
 3. Roof Covering Type _____
 4. Other _____

Chimneys:
 Type: _____ Number of Fire Places _____

Heating:
 Type of Heat: _____

Electrical:
 Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:
 1. Approval of soil test if required Yes _____ No _____
 2. No. of Tubs or Showers _____
 3. No. of Flushes _____
 4. No. of Lavatories _____
 5. No. of Other Fixtures _____

Swimming Pools:
 1. Type: _____
 2. Pool Size: _____ x _____ Square Footage _____
 3. Must conform to National Electrical Code and State Law.

Zoning:
 District _____ Street Frontage Req.: _____ Provided _____
 Required Setbacks: Front _____ Back _____ Side _____

Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shore and Floodplain Mgmt. _____ Special Exception _____
 Other (Explain) _____
 Date Approved _____

Permit Received By Deborah Goode
 Signature of Applicant _____ Date _____
 Signature of CEO (Signature) Date _____
 Inspection Dates _____

PLOT PLAN



FEES (Breakdown From Front)

Base Fee \$ 25.00 _____

Subdivision Fee \$ _____

Site Plan Review Fee \$ _____

Other Fees \$ 25.00 _____

(Explain) _____

Late Fee \$ _____

Type	Inspection Record	Date
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____
_____	_____	____/____/____

COMMENTS 4-20-89 Pool has been dug out. Walls have been put in for
 concrete pouring of all
 4-24-89 Concrete poured for walls. 4-27- Pool liner has been installed.
 Some water is being pumped in.
 5-5-89 Tank wall complete!

Signature of Applicant Jamette Douglas


Date 4-12-89


JOHN GRIGSBY
501 AUBURN ST.
PORTLAND ME.
4-11-89

RECEIVED

APR 11 1989

DEPT. OF BUILDING INSPECTIONS
CITY OF PORTLAND





M-T
POOLS, INC.
ROUTE 196 - LISBON ROAD
LISBON, MAINE 04250
PHONE (207) 353-8406

Name: John F. Higgins
Address: 501 Anderson St Portland ME 04103
Office Phone: _____ Site Phone: 797-3855
Pool Design: Garcin
Greatest Width: 18' Greatest Length: 28'
Depth: 3' To: 8'
Wall Structure: galu. 1/2" plastic conduit
external copper & chlor

CONSTRUCTION SPECIFICATIONS

CONTRACTOR TO:

1. Layout pool prior to excavation (customer approval)
2. Excavate pool.
3. Stockpile top soil on site (re-spreading by customer)
4. Back fill pool using subsoil from excavation.
 - a) additional fill to be supplied at customers expense
 - b) additional subsoil to be hauled off at customers expense
5. Remove stumps in immediate pool area. Trees to be removed by customer.
6. Supply pool piping and complete hook up between filter and pool. Pool piping shall be 1/2" or 3/4" virgin polyethylene.
7. Filter type: Micro Clean DE
8. Supply portable backwash hose. If any other backwash systems are required by local regulations, customers to supply.
9. Supply water test kit, vacuum head, pole and hose and chemical starter kit.
10. One three step stainless steel in pool ladder.
11. Safety lines and floats.

NOT INCLUDED:

12. Pool base bottom
13. Optional accessories not included above: 8' DE cover w/ handrail
14. Main Drain
15. 8' Drain Board
16. 12' x 24" DE light
17. external copper & chlor
18. _____

APR 11 1989

DEPT. OF BUILDING INSPECTIONS
CITY OF PORTLAND

POOL PRICE	<u>96.25</u>
Taxable Materials	<u>63.40</u>
Sales Tax	<u>3.15</u>
Labor & Non-Taxable Materials	<u>43.12</u>
Total	<u>109.92</u>

19. Fence _____
 20. Patio to be decided in agreement
- TOTAL CONTRACT PRICE** 109.92

You may cancel this agreement if it has been consummated by a party thereto at a place other than an address of the seller, which may be his main office or branch thereof, provided you notify the seller in writing at his main office or branch by ordinary mail posted, by telegram sent or by delivery, not later than midnight of the third business day following the signing of this agreement.

Use of pool shall constitute acceptance of work specified in this contract. The undersigned, jointly and severally, agree that this contract includes the above terms, conditions, and specifications AS WELL AS THOSE ON THE REVERSE SIDE, all of which are incorporated herein, and further acknowledges that each of them has read and understood this entire contract and has received a copy hereof.

Date of Acceptance: 9/7/88
Signed: Mr. John F. Higgins
Date: _____